

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7910300187 DOC. DATE: 79/10/25 NOTARIZED: NO DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410  
 AUTH. NAME: AUTHOR AFFILIATION  
 RHODE, G.K. Niagara Mohawk Power Corp.  
 RECIPIENT AFFILIATION  
 DENTON, H.R. Office of Nuclear Reactor Regulation

SUBJECT: Lists safety Class I check valves for which util will invoke ASME Code Case N-181. Listed check valves made from castings refined by argon oxygen decarburization process contrary to ASME requirements.


DISTRIBUTION CODE: B001B COPIES RECEIVED: LTR J, ENCL Q SIZE: J-----  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: -----

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	05 PM H. SILVER	1 1	AD LWR	1 1
	BC LWR #4	1 0	LA LWR #4	1 0
INTERNAL:	01 REG FILE	1 1	02 NRC PDR	1 1
	06 I & E	2 2	08 OPERA LIC BR	1 1
	09 GEOSCIEN BR	4 4	10 OAB	1 1
	11 MECH ENG BR	1 1	12 STRUC ENG BR	1 1
	13 MATL ENG BR	2 2	15 REAC SYS BR	1 1
	16 ANALYSIS BR	1 1	17 CORE PERF BR	1 1
	18 AUX SYS BR	1 1	19 CONTAIN SYS	1 1
	20 I & C SYS BR	1 1	21 POWER SYS BR	1 1
	22 AD SITE TECH	1 0	26 ACCDNT ANLYS	1 0
	27 EFFL TRT SYS	1 1	28 RAD ASMT BR	1 1
	29 KIRKWOOD	1 1	AD FOR ENG	1 0
	AD PLANT SYS	1 0	AD REAC SAFETY	1 0
	AD SITE ANLYSIS	1 0	DIRECTOR NRR	1 0
	HYDRO-METEOR BR	2 2	MPA	1 0
	OELD	1 0		
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	30 ACRS	10 10		

LTR:  
 MOORE AD  
 EPB # 2  
 J. NORRIS PM  
 EPB # 2 LA

OCT 31 1979



MR4



October 25, 1979

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Denton:

Re: Nine Mile Point Unit 2  
Docket No. 50-410


For your information, Niagara Mohawk Power Corporation will invoke ASME Code Case N-181 on the Safety Class 1 check valves listed below. These check valves are made from castings which meet the applicable ASME III, Division 1, Appendix I requirements, except that they are refined by the Argon oxygen decarburization process.

<u>Quantity</u>	<u>Pressure Rating</u>	<u>Size</u>	<u>Type</u>
4	900 Pounds	12 Inches	Testable Check
1	900 Pounds	6 Inches	Testable Check

ASME Code Case N-181 is listed in Regulatory Guide 1.85, Revision 15 as being acceptable to the Nuclear Regulatory Commission for application in construction of components for water-cooled nuclear power plants.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Gerald K. Rhode  
Vice President  
System Project Management

Boo  
SE  
-10



...

...

...

(

,

...

...