

TELECOPY MESSAGE

TO: 215-337-5324 FROM: 315-343-2110 DATE/TIME 1/10/80 4:00 PM
Telephone Number Telephone Number

84-7359

TO: BOYCE H. GRIER
Director of Regulatory Operation
USNRC Region I
631 Park Avenue
King of Prussia, PA. 19406

From: Niagara Mohawk Power Corporation
Nine Mile Point Nuclear Station
Unit #1
P.O. Box #32
Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE
DOCKET NO. 50-220 LICENSE NO. DPR-63
ASSIGNED LER NO. 80-03

EVENT DATE: 1/9/80 REPORT DATE: 1/10/80

EVENT DESCRIPTION:

Discovered during review failure to sample & lab test emergency ventilation and control room charcoal filters at required interval.

COMPONENTS INVOLVED: Emergency Ventilation and Control Room Ventilation

CAUSE AND REMEDIAL ACTION: Surveillance schedule referenced operating cycle rather than 18 month sampling interval, and did not differentiate between in-place testing and lab testing. Schedule corrected to reflect Technical Specification Requirements.

FACILITY STATUS: % THERMAL MW 1820
a) Routine Startup _____ g) Shutdown _____
d) Routine Shutdown _____ h) Refueling _____
e) Steady State Oper X i) Other _____
f) Load Change _____ j) Not Applicable _____

A written follow-up report will be sent within two weeks.

TELECOPY TO: Boyce H. Grier FROM: T.J. Perkins DATE: 1/10/80
NAME R.R. Schneider NAME T.J. Perkins

T

5

