



NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

February 8, 1980

Office of Inspection and Enforcement  
Region I  
Attn: Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Dear Mr. Grier:


Re: Nine Mile Point Unit 2  
Docket No. 50-410

Your December 7, 1979 I.E. Bulletin 79-28 requested Niagara Mohawk to determine if NAMCO EA180 switches are planned for use in safety-related systems at Nine Mile Point Unit 2. In response, the NAMCO EA180 switches described in I.E. Bulletin 79-28 are not planned to be used in any safety-related systems at Unit 2.

Further, to ensure these switches will not be used, this equipment will be placed on the Excluded Equipment List.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

  
James Bartlett  
Executive Vice President

PEF:jk

xc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, D. C. 20555

8003120718  
A02



-----