

February 19, 1980

Mr. Boyce H. Grier, Director
Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406


50-220

Dear Mr. Grier:

In reference to your I.E. Bulletin 80-02, we wish to advise you that no reactor feedwater spargers or thermal sleeves manufactured by Marvin Engineering Company are at Nine Mile Point Nuclear Station. During our 1977 refueling outage original equipment supplied by General Electric was replaced with new spargers and thermal sleeves manufactured by LAMCO Industries, Inc.

We trust that this information will satisfy your concerns.

Very truly yours,


James Bartlett
Executive Vice President

jl/

AD/I
2

8003250470

