

March 31, 1980

Office of Inspection and Enforcement
Region I
Attn.: Mr. Boyce H. Grier
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Dear Mr. Grier:


Analyses have been completed for the reactor feedwater booster pump discharge for moisture separator cooling and control room chilled water system piping as stated in our letter of December 31, 1979.

These analyses indicated that restraint modifications would be required. The modifications have been completed for both systems.

Piping inspections of systems inside the drywell have been completed. A report summarizing the results of the inspection will be by April 30, 1980, in accordance with your January 4, 1980 letter.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



T. E. Lempges
Vice President - Nuclear Generation

MGM/kmb

