

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8005190554 DOC.DATE: 80/05/12 NOTARIZED: NO DOCKET #
 FACIL:50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH.NAME AUTHOR AFFILIATION
 DISE,D.P. Niagara Mohawk Power Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation

SUBJECT: Forwards addl info & clarification supplementing utll 791220
 & 31 ltrs re implementation of NUREG-0578 recommendations.
 One oversized drawing encl.

DISTRIBUTION CODE: A040S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 4
 TITLE: Resp to Lesson Learn Task Force - General Electric

NOTES:-----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	10 BC ORB #3	7	7			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	05 VERRELLI,D.	1	1	06 RIANI,L.	1	1
	07 BEARD,J.	1	1	08 SKOPEC,F.	1	1
	17 I & E	2	2	20 CORE PERF BR.	1	1
	21 ENG BR	1	1	22 REAC SFTY BR	1	1
	23 PLANT SYS BR	1	1	24 EEB	1	1
	25 EFLT TRT SYS	1	1	OELD	1	0
	TELFORD,J.T.	2	2			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	26 ACRS	16	16			

MAY 22 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 41

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second section of faint, illegible text.

Third section of faint, illegible text, containing a prominent stamp or mark on the right side.

Large section of faint, illegible text at the bottom of the page, possibly a main body or conclusion.

May 12, 1980

Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Denton:

Subject: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Find attached additional information and clarifications supplementing our letters of December 20, 1979 and December 31, 1979 regarding the implementation of NUREG 0578 Recommendations. Specifically, the areas addressed include NUREG 0578 Recommendations 2.1.3.a, 2.1.5.a, 2.1.8.b and 2.2.1.b.

Niagara Mohawk's letter of December 31, 1979 provided the conceptual design for those NUREG-0578 recommendations requiring review and approval by the Nuclear Regulatory Commission. It is our understanding that no additional information is required by your staff to determine the acceptability of the modifications proposed for Nine Mile Point Unit 1.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

Donald P. Dise

Donald P. Dise
Vice President Engineering

PEF:jk

*Accto
5/11*



2. 1

70

.

13

07

07

.

.

.....

.....

.....

0. 03 0. 29

.....

2-

NUREG 0578 RECOMMENDATION

2.1.3.a - Direct Indication of Power-Operated Relief Valve and Safety Valve Position for PWR's and BWR's

At the time of the Nuclear Regulatory staff's evaluation of Nine Mile Point Unit 1's compliance with the Category "A" items of the NUREG-0578 Recommendations, we indicated that our safety and relief valve position indication system would be seismically and environmentally qualified by January 1981. Subsequent to your staff's evaluation, Niagara Mohawk has been informed that the seismic and environmental qualification of our safety and relief valve position indication system will not be completed until July 1981.

NUREG 0578 RECOMMENDATION

2.1.5.a - Dedicated Penetrations for External Recoiners or Post-Accident Purge Systems

Our letter of December 31, 1979 proposed a modification to automatically close blocking valves 201.2-05 and 201.2-08 (see Drawing C-18014-C Sheet 1 attached) when adding nitrogen to the containment. This modification was proposed to make the purge system single failure proof for containment isolation purpose, when adding nitrogen to the containment. Further investigation of this modification has shown that when the pump in the Drywell Torus Pump back system trips (which occurs on a containment isolation signal), the blocking valves in the pump suction and discharge will automatically close. Therefore, the pathway through blocking valve 201.2-05 is already single failure proof for containment isolation purposes.

Blocking valves 201.2-135 and 201.2-136 (see Drawing C-18014-C sheet 1) downstream from blocking valve 201.2-08 have a key interlock switch such that one valve is always closed. If the interlock fails, both valves will fail closed. Thus, the pathway through blocking valve 201.2-08 is already single failure proof for containment isolation purposes.

No modification to this system is required to meet NUREG 0578 Recommendation 2.1.5.a.

NUREG 0578 RECOMMENDATION

2.1.8.b - Increased Range of Radiation Monitors

In our letter of December 31, 1979 we committed to install a high range effluent monitor to meet the requirements of NUREG 0578 Recommendation 2.1.8.b. Further investigation has revealed that the range of the two existing noble gas effluent monitors can be adjusted to monitor the entire range required, including sufficient overlap of the monitors.



NUREG 0578 RECOMMENDATION

2.2.1.b - Shift Technical Advisor

Our letter of December 20, 1979 indicated that Niagara Mohawk would augment the control room staff at Nine Mile Point Unit 1 by January 1, 1980. Since January 1, 1980, an Assistant Shift Supervisor has been added to the normal Control Room shift composition. The Assistant Shift Supervisors have bachelor's degrees in a scientific or engineering discipline. By January 1, 1981, they will have received specific training in the response and analysis of the plant for transients and accidents. Also covered will be plant design and layout, including the capabilities of instrumentation and controls in the control room.



1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025