

March 28, 1980

Mr. Eldon J. Brunner, Chief
Reactor Operations and Nuclear
Support Branch
United States Nuclear Regulatory
Commission - Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Sir:

RE: Inspection No. 50-220/80-01
Addendum 1

This letter is to clarify our response to NRC Inspection 80-01, dated March 19, 1980. The following will be implemented by the end of the 1981 refueling outage to prevent locks from being removed from secured valves:

All locks which secure valves in a position described by the Operating Procedure Valve Check Off Lists will have their cores changed to a unique key series. The new keys will be available only to shift operating personnel and certain designated management employees.

Sincerely,



Thomas E. Lempges
Vice President
Nuclear Generation

jl/

