

June 2, 1980

Office of Inspection & Enforcement  
Region I  
Attn: Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Dear Mr. Grier:

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

In our letter of April 30, 1980 we indicated that additional analyses and modifications would be complete by June 1, 1980. The information provided below supplements that response.

1. Two restraints in the containment spray raw water system were modified to be consistent with the original design.
2. Re-analysis of a 2 inch diameter section of reactor drain to the cleanup system indicated that it was in compliance with allowable code stress levels and therefore did not require any modifications.
3. Re-analysis of a drain line off the feedwater system indicates that the allowable code stress level will not be exceeded in any safety related piping.
4. Evaluation of the Reactor Containment Purge and Fill N<sub>2</sub> and the Drywell Vent and Purge Air and N<sub>2</sub> systems indicated that seven (7) additional restraints were necessary. These have been installed.
5. Re-analysis of the H<sub>2</sub>-O<sub>2</sub> monitoring system indicated that two dead weight hangers were necessary to bring the system into compliance with allowable code stress levels. These have been installed.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



T. E. Lempges  
Vice President - Nuclear Generation

MGM:jk

8006300271

