

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8007070261      DOC. DATE: 80/06/26      NOTARIZED: NO      DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe      05000220  
 AUTH. NAME      AUTHOR AFFILIATION  
 DISE, D.P.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 DENTON, H.R.      Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards addl info re util commitments to meet NUREG-0578, Recommendations 2.1.3b, 2.1.8a & RCS venting. Discusses inadequate core cooling detection instrumentation & improved post-accident sampling capability.


DISTRIBUTION CODE: A001S      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: General Distribution for after Issuance of Operating Lic


NOTES: -----

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	BCIPPOLITO, T. 05	1	1	PM POLK, P.	12	12
INTERNAL:	DIR, HUM FAC SFY	1	1	I&E	12	2
	MOORE, V. 22	1	1	NRC PDR	02	1
	OELD 14	1	0	OR ASSESS BR 19	1	0
	REG FILE 01	1	1			
EXTERNAL:	ACRS 20	16	16	LPDR	03	1
	NSIC 04	1	1			

JUL 8 1980





  
June 26, 1980

Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Denton:

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Enclosed is additional information regarding Niagara Mohawk's commitments to meet NUREG-0578 Recommendations 2.1.3b, 2.1.8a and Reactor Coolant System Venting.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Donald P. Dise  
Vice President Engineering

PEF/kmb  
Attachment

8007070261

A001  
S  
1/1



11

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

2. The second part of the document outlines the specific procedures that must be followed when recording transactions. This includes the requirement that all entries be supported by appropriate documentation, such as invoices, receipts, and contracts.

3. The third part of the document addresses the issue of internal controls. It states that the organization must implement a system of internal controls that is designed to prevent and detect errors and fraud. This system should be reviewed and updated regularly to ensure its effectiveness.

4. The fourth part of the document discusses the role of the accounting department in the organization. It notes that the accounting department is responsible for providing accurate and timely financial information to management and other stakeholders. This information is used to make informed decisions about the organization's operations and future plans.

5. The fifth part of the document concludes by reiterating the importance of maintaining accurate records and following the established procedures. It encourages all employees to take responsibility for their own actions and to report any suspected errors or fraud to the appropriate authorities.

12

13

## NUREG 0578 RECOMMENDATION

### 2.1.3b - Instrumentation for Detection of Inadequate Core Cooling

In our December 31, 1979 response to the NUREG 0578 Recommendations, Niagara Mohawk committed to installing additional reactor vessel water level instrumentation. It was indicated that this instrumentation would cover the range from the normal water level to the bottom of the core. The instrumentation will be redundant, compensated for reactor vessel pressure, and drywell and reactor building temperature and supplied with an emergency power source.

The Nuclear Regulatory Commission's NUREG 0578 clarification letter of October 30, 1979 requires this instrumentation to meet safety-grade criteria. The instrumentation will meet safety-grade criteria except for the microprocessor due to the unavailability of vendors to fabricate safety related Class 1-E microprocessors. The microprocessor is used for vessel pressure and drywell and reactor building temperature compensation.

Also in the interim from January 1, 1981 to the Spring, 1981 refueling, the drywell temperature compensation will be provided by special instructions to the operators. During the Spring, 1981 refueling outage, RTD's will be installed in the drywell and wired to the microprocessor to provide automatic drywell temperature compensation.



## NUREG 0578 RECOMMENDATION

### 2.1.8a - Improved Post-Accident Sampling Capability

In our December 31, 1979 response to the NUREG 0578 Recommendations, Niagara Mohawk committed to modifying the existing recirculation loop sample line and adding a sample sink to obtain reactor coolant samples under accident conditions by January 1, 1981. Niagara Mohawk is funding with a group of utilities the design and fabrication by General Electric of a generic sample panel. The group approach was believed to be advantageous from a schedule and manpower standpoint. Preliminary information from the sample panel vendor indicates that this equipment may not be available until after January 1, 1981. Based on this equipment delivery schedule, Niagara Mohawk will revise its installation schedule to install this equipment within 60 days after delivery to the site.





## NUREG 0578 RECOMMENDATION

### Reactor Coolant System Venting (Emergency Condenser Venting)

In our December 31, 1979 response to the NUREG 0578 Recommendations, Niagara Mohawk committed to modifying the emergency condenser tube side vents by January 1, 1981 to provide the capability to vent the emergency condensers under accident conditions. In a separate letter dated May 7, 1980 from Mr. D.G. Eisenhut, the Nuclear Regulatory Commission requested an analysis to be performed by April 1, 1981 to determine the capability of the Emergency Condenser System to depressurize the reactor coolant system with non-condensibles in the system by April 1, 1981. Therefore, Niagara Mohawk will assess the need for modifying the emergency condenser vent and will perform the analysis or modification by April 1, 1981.



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

2. The second part of the document provides a detailed overview of the current financial status of the organization. It includes a summary of the income statement, the balance sheet, and the cash flow statement. The information is presented in a clear and concise manner, allowing stakeholders to quickly understand the organization's financial performance.

3. The third part of the document outlines the organization's financial goals and objectives for the upcoming period. It discusses the strategies and initiatives that will be implemented to achieve these goals, and provides a detailed budget for the period.

4. The fourth part of the document discusses the organization's risk management strategy. It identifies the key risks that the organization faces, and describes the measures that will be taken to mitigate these risks. This includes a discussion of the organization's insurance coverage and its approach to managing operational risks.

5. The fifth part of the document provides a summary of the organization's financial performance over the past period. It includes a comparison of the organization's performance to its budget and to the performance of its peers in the industry. This information is presented in a clear and concise manner, allowing stakeholders to quickly understand the organization's financial performance.

## NUREG 0578 RECOMMENDATION

### Reactor Coolant System Venting (Reactor Head Vent System)

Our December 31, 1979 response to the NUREG 0578 recommendations committed to providing the reactor head vent valves with an emergency power supply by January 1, 1981. The modification can be performed by this date. However, a preoperational test cannot be performed until the Spring, 1981 refueling outage unless the plant undergoes an unscheduled shutdown. Therefore, rather than modify the head vent valves power supply by January 1, 1981 without proper testing, Niagara Mohawk will delay the installation of this modification until the Spring, 1981 refueling outage.

In the interim from January 1, 1981 to the Spring, 1981 refueling outage, special procedures will be in place to provide emergency power to the reactor head vent valves. If an accident did occur in conjunction with a loss of off-site power during which reactor coolant system venting would be necessary, there would be adequate time available to connect the reactor head vent valves to an emergency power supply.

