

July 28, 1980

Office of Inspection and Enforcement
Region I
Attention: Mr. Boyce H. Grier, Director
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA. 19406

RE: Nine Mile Point-Unit #1
Docket No. 50-220
DPR-63

Dear Mr. Grier:


Your June 27, 1980 Inspection and Enforcement Bulletin 80-16 requested actions regarding potential misapplication of Rosemount Inc. Transmitters at Nine Mile Point Unit #1. The following addresses Items 1 through 4 of that Bulletin.

Investigations have determined that presently there are no transmitters installed or planned to be installed with the specified output codes of "A" or "D" at this Station. Rosemount Transmitters presently installed at Nine Mile Point Unit #1 have output codes of "B" and "E" which are not the output codes in question.

Actions described herein complete response requirements for this Bulletin. Any additional information or records are readily available at your request.

The information contained in this letter demonstrates that continued operation of Nine Mile Point Unit #1 does not present an undue safety hazard to the public.

Very truly yours,



Thomas E. Lempges
Vice President -
Nuclear Generation

mtm

xc: NRC Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

8009090 668

Q

W



11

—