

Docket

REGULATORY DOCKET FILE COPY

Docket No. 50-220

SEPTEMBER 24 1980

Mr. Donald P. Dise
Vice President - Engineering
c/o Miss Catherine R. Seibert
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Dear Mr. Dise:

By our letter dated August 7, 1978, we informed you of deficiencies we identified in the design of the Hatch 2 regulator system for the motor generator (M-G) sets which supply power to the reactor protection system (RPS). In general, the problem involved the possibility of the M-G producing power which was of a quality (High/low outage, etc.) that could be outside that for which the RPS has been demonstrated to be acceptable. Specifically, the deficiencies involved:

- (1) Potential sequence of undetected single component failures which could adversely affect the operability of the RPS; and
- (2) Postulated component malfunctions initiated by a seismic event which could adversely affect the operability of the RPS.

Our letter requested that you review your RPS power supply to determine if your system was susceptible to the same adverse possibilities that the staff had identified for Hatch 2.

We have completed our review of your response to our request and have determined that the power supply RPS design at your facility is such that it could experience the same adverse conditions as described above. Accordingly, we have determined that modifications should be performed to provide fully redundant Class 1E protection at the interface of the non-Class 1E power supplies and the RPS. We believe that the use of alarms or shift surveillance is acceptable as an interim measure but is not adequate for the long-term solution of our concerns.

We have found that the conceptual design proposed by the General Electric Company and the installed modification on Hatch 1 are acceptable solutions to our concern.

OFFICE					
SURNAME	8010080	453	P		
DATE					

REGULATORY BOARD FOR THE
1993 THE 1993 THE 1993

2000 1000 1000

1000 1000 1000

Mr. Donald P. Dise

- 2 -

SEPTEMBER 24 1980

In view of the above, we believe that you should modify the power supply for the RPS at your facility. This modification should be implemented by the end of the next refueling outage. Should this scheduled outage occur within the next six months, the modifications should be accomplished by the end of the subsequent refueling outage. We will perform a post-implementation review of your modification and will require appropriate Technical Specifications for the system.

We request that you provide within 60 days of your receipt of this letter: your (1) commitment to install a Class 1E system, (2) schedule for completion of the modification and (3) schedule for submission of design information and proposed Technical Specifications.

Sincerely,

Original signed by

Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

Distribution

Docket
ORB #2
NRR Reading
Local PDR
NRC PDR
DEisenhut
RTedesco
TNovak
GLainas
TIppolito
SNorris
OELD
IE (3)
ACRS (16)
NSIC
TERA
JJRoe
RPurple
JHeltemes, AEOD
DVerrelli
PPolk

OFFICE	ORB #4	ORB #2	ORB #2			
SURNAME	DVerrelli	PPolk:mjf	TIppolito			
DATE	9/10/80	9/22/80	9/23/80			

RECEIVED



RECEIVED
FEB 10 1964
U.S. DEPARTMENT OF
HEALTH, EDUCATION
& WELFARE
OFFICE OF THE
ASSISTANT SECRETARY
FOR PUBLIC AFFAIRS
WASHINGTON, D.C.
20540

Mr. Donald P. Dise

- 3 -

cc:

Eugene B. Thomas, Jr., Esquire
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N. W.
Suite 1100
Washington, D. C. 20036

State University College at Oswego
Penfield Library - Documents
Oswego, New York 13126

Mr. Joseph J. Sunser, Manager
System Security
Niagara Mohawk Power Corporation (Security matters only)
300 Erie Boulevard West
Syracuse, New York 13202

Resident Inspector
c/o U.S. NRC
P. O. Box 126
Lycoming, New York 13093

