

STANDARD BUREAU PUBLIC COMPLAINT FORM

TELECOPY MESSAGE

TO: \_\_\_\_\_ FROM: 315/343-2110 DATE/TIME 8-27-80  
 Telephone Number Telephone Number

TO: **ROYCE H. GRIBB** From: **Niagara Mohawk Power Corporation**  
 Director of Regulatory Operation **Nine Mile Point Nuclear Station**  
 USNRC Region I **Unit #1**  
 631 Park Avenue **P.O. Box #32**  
 King of Prussia, PA 19406 **Lycoming, New York 13093**

SUBJECT: **PROMPT REPORTABLE OCCURRENCE**  
**BOOKET NO. 50-220 LICENSE NO. DPR-63**  
**ASSIGNED LER NO. 80-19**

EVENT DATE: 8/27/80 REPORT DATE: 8/28/80

EVENT DESCRIPTION: **REACTOR BUILDING TRUCK BAY OUTSIDE DOORS SEALS NOT PROPERLY INSTALLED. ON DISCOVERY, IMMEDIATELY CLOSED THE INSIDE DOOR.**

COMPONENTS INVOLVED: **REMOVABLE FLOOR SEALS ON TRUCK BAY OUTSIDE DOOR**

CAUSE AND REMEDIAL ACTION: **SEALS FOUND TO BE DAMAGED FROM USAGE. REPAIRED SEALING LOGS AND PROPERLY REINSTALLED SEALS ON THE OUTSIDE DOOR**

FACILITY STATUS: **99 % THERMAL IN 1840**

c) Routine Startup _____	g) Shutdown _____
d) Routine Shutdown _____	h) Refueling _____
e) Steady State Oper <u>X</u> _____	i) Other _____
f) Load Change _____	j) Not Applicable _____

A written follow-up report will be sent within two weeks.

TELECOPY TO: \_\_\_\_\_ FROM: \_\_\_\_\_ DATE: \_\_\_\_\_  
 NAME NAME

