

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8012300505 : DOC. DATE: 80/12/15 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME: AUTHOR AFFILIATION
 DISE, D.P.: Niagara Mohawk Power Corp.
 RECIP. NAME: RECIPIENT AFFILIATION
 IPPOLITO, T.A. Operating Reactors Branch 2

SUBJECT: Forwards addl info re crack in reactor bldg wall, per NRC
 800821 request. Photographs & oversized drawings encl.

DISTRIBUTION CODE: A0018 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 16+9
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	IPPOLITO, T. 04	13	13			
INTERNAL:	D/DIR, HUM FAC08	1	1	DIR, DIV OF LIC.	1	1
	I&E 06	2	2	NRC PDR 02	1	1
	OELD 11	1	0	OR ASSESS BR 10	1	0
	<u>REG FILE</u> 01	1	1			
EXTERNAL:	ACRS 09	16	16	LPDR 03	1	1
	NSIC 05	1	1			

DRWGS TO:
 BC
 APERTURE DIST

JAN 6 1981

10

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 37



1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

101

102

103
 104
 105
 106
 107
 108
 109
 110
 111
 112
 113
 114
 115
 116
 117
 118
 119
 120
 121
 122
 123
 124
 125
 126
 127
 128
 129
 130
 131
 132
 133
 134
 135
 136
 137
 138
 139
 140
 141
 142
 143
 144
 145
 146
 147
 148
 149
 150
 151
 152
 153
 154
 155
 156
 157
 158
 159
 160
 161
 162
 163
 164
 165
 166
 167
 168
 169
 170
 171
 172
 173
 174
 175
 176
 177
 178
 179
 180
 181
 182
 183
 184
 185
 186
 187
 188
 189
 190
 191
 192
 193
 194
 195
 196
 197
 198
 199
 200

201



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MEMORANDUM FOR: TERA CORPORATION
FROM: US NRC/TIDC/DOCUMENT MANAGEMENT BRANCH
SUBJECT: Special Document Handling Requirements


1.. Please use the following special distribution list for the attached document.

2. The attached document requires the following special considerations:

- Do not send oversize enclosures to the NRC PDR.
- Only one oversize ^{DRUGS} enclosure was received - please return for Regulatory ~~File~~ storage. ^{BC} ^{APERTURE CARD}
- Proprietary information - send only non-proprietary portions to the NRC PDR.
- Other: (specify)

cc: DMB Files

Mike
TIDC/DMB Authorized Signature



December 15, 1980

Director of Nuclear Reactor Regulation
Attn: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch #2
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Re: Nine Mile Point Unit 1
Docket 50-220
DPR-63

On August 21, 1980 members of the Nuclear Regulatory Commission staff met with Niagara Mohawk to discuss the crack in the reactor building wall at Nine Mile Point Unit 1. The attached information was requested by your staff at that meeting.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

Donald P. Dise

Donald P. Dise
Vice President Engineering

MGM:ja
Attachments

*A001
5/11 set
DRWGS TO:
BC*

*APERTURE
DIST*

8012300503

P

1944

1944

1944

1944

1944

1944

1944

1944

1944

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT UNIT 1
REACTOR BUILDING WALL CRACK

Request for Additional Information
December 1980

THE UNIVERSITY OF CHICAGO
LIBRARY

1954

Item 1

It is requested that Niagara Mohawk provide its bases for the crack mechanism philosophy.

Response

Attachments A and B provide drawings and pictures of the Nine Mile Point Unit 1 reactor building wall crack. The crack is located in the exterior north wall of the Reactor Building approximately 10.5 feet west of the east wall. The maximum width of the crack is approximately one-eighth of an inch at approximately eighteen inches below the one foot ledge at Elevation 237 feet. The crack extends down from the ledge at Elevation 237 feet approximately eight feet and extends above the ledge about the same distance. The upper and lower ends of the crack disappear in a random hairline pattern.

The design drawings for Nine Mile Point Unit 1 (attachment A) were reviewed. The North-South exterior 15 inch thick x 22 foot average height greenhouse foundation wall runs continuously for about 160 feet without a wall return or expansion joint. The wall elevation shows that the column pilasters as well as foundation wall lengths are established at the common base elevation of about 240 feet, which is also the elevation of the bedrock.

As described by ACI recommendations, the recommended maximum length for concrete foundation walls without vertical interruptions is approximately 40 to 60 feet. Therefore, for the 160 foot length wall, at least two vertical expansion joints were in order, but do not exist for the wall in question.

These walls and pilasters were constructed during approximately a one year time period. As a result, some wall elements were winter pours, and after proper curing for strength, they were exposed to the ambient temperatures. The change in ambient temperature and final operating temperature provided a thermal expansion force to each end of the wall.

The north end of the 160 foot north/south wall had a return and that portion of the thermal expansion force was dissipated by geometry.

However, the south end of the 160 foot north/south wall had a 4 foot-2 inch hard jointed vertical surface of contact with the 4 foot thick east/west secondary containment wall (@ elevation 237 feet). The balance of the common wall height was separated by one inch resilient (compressible) material. Both elevation and plan centerline location align for the two walls at the crack location.

Calculations have shown that a sufficient temperature gradient could have existed to overcome frictional forces, apply a force to the north face of the east/west secondary containment wall and crack the wall. The wall crack is vertical in nature, due to horizontal flexure of the east-west secondary wall that spans continuously between adjacent pilaster and return wall in the reactor building.



The north/south wall thermal force and corresponding horizontal displacement is considered uniform at the walls cross-section for the full height of wall. This caused the topping (only) to crack (several years ago) at floor elevation 261 feet. This is the only other area of the joint detailing that was hard jointed to the east-west secondary containment wall. No vertical displacement was observed, since the curbing at elevation 261 feet broke in a concave fashion (i.e. hard jointed to east west secondary containment wall), designating compression load primarily.

Item 2


It is requested Niagara Mohawk review the seismic design of the Reactor Building to assure interaction by the screen house wall will not precipitate unacceptable stress during a design basis seismic event.

Response

A simple beam analysis was performed to determine the effect of the combined seismic and thermal loading on the Reactor Building wall. Utilizing a simple beam model and conservative inputs, the combined seismic and thermal loads approach Reactor Building wall limits.

However, the simplistic model and conservative inputs used in the analysis result in greater than expected stresses as detailed below:

- (1) The design does not consider the localized two-way flexural action that would occur in the wall. As modeled, we have considered the wall as spanning in the horizontal direction only. In reality the wall would also span in the vertical direction. The applied load would be divided proportional to the relative stiffness between the horizontal and vertical spans. This would increase the margin to yield.
- (2) The assumption of rigid boundary conditions results in a formula which indicates loads higher than those which would be found under actual conditions. This is due to the fact that the principal of moment distribution is not applied in the calculation.
- (3) In reality reinforced concrete exhibits a creep effect which would allow the wall to undergo a plastic deformation. The deformation would provide a relaxing effect and reduce applied thermal load. This would increase the margin to yield.
- (4) Historically Grade 40 steel rebar has been found to have a yield point 10% to 15% above the specified 40 ksi. Additionally, the modeling assumes that yielding occurs only in those localized areas at a crack in the concrete. The probability of experiencing a minor flaw in this minute area is smaller than in the sample used to test F_y at the mil. Therefore, the margin to yield is likely greater than calculated.
- (5) Under combined loading, spalling of concrete free cover (about 2") on wall reinforcing may occur. It is believed that this action would not cause sufficient damage to the structural steel stairway to hinder egress.



- (6) It is also believed that "through" cracks would not occur until the ultimate failure mode is obtained, and the wall pivots about the north face. A very large applied force would be required, since the surrounding wall would attempt to retain this increment. A combination flexural and axial compression stress would have to be overcome.

Based on the conservatisms outlined above, the actual combined seismic and thermal loadings would be less than the Reactor Building wall yield.

Item 3

It is requested Niagara Mohawk develop a monitoring program to determine movement of the Reactor Building wall and above ground movement of the greenhouse wall.

Response

To monitor movement of the Reactor Building wall, Niagara Mohawk will install monitoring equipment as detailed on Figure 1.

To monitor above ground movement of the greenhouse wall, Niagara Mohawk will install monitoring equipment as detailed on Figure 2.

Data obtained since 1977, from existing monitoring equipment, indicates no increase in crack size. If movement is observed on the monitoring equipment to be installed, this information will be provided to NRC.

Item 4

It is requested Niagara Mohawk provide Reactor Building and greenhouse building drawings.

Response

Attachment A contains Reactor Building and greenhouse building drawings.

Item 5

It is requested Niagara Mohawk provide pictures of the Reactor Building wall crack.

Response

Attachment B contains pictures of the Reactor Building wall crack.

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL