

ATTACHMENT A

Niagara Mohawk Power Corporation

License No. DPR-63

Docket No. 50-220

Proposed Changes to Technical Specifications (Appendix A)

Replace page 119 with the attached revised page. This page was completely retyped with changes as marked.

8103090688



27

LIMITING CONDITION FOR OPERATION


Table 3.2.7 (Continued)

REACTOR COOLANT SYSTEM ISOLATION VALVES

<u>Line or System</u>	<u>No. of Valves (Each Line)</u>	<u>Location Relative to Primary Containment</u>	<u>Normal Position</u>	<u>Motive Power</u>	<u>Maximum Oper. Time (Sec.)</u>	<u>Action on Initiating Signal</u>	<u>Initiating Signal (All Valves Have Remote Manual Backup)</u>
<u>Reactor Head Spray (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	-
	1	Outside	Closed	R.M.P.O.	30	-	-
<u>Liquid Poison (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	-
	1	Outside	-	Self Act. Ck.	--	-	-
<u>Control Rod Drive Hydraulic (One Line)</u>	1	Inside	-	Self Act. Ck.	--	-	-
	1	Outside	-	Self Act. Ck.	--	-	-
<u>Core Spray High Point Vent (Two Lines)</u>	1	Inside	Closed	A.C. Motor	30	Closed	Reactor Water Level Low-low or High Drywell Pressure
	1	Outside	Closed	Air/D.C. Solenoid	30	Closed	

*A.I.P.O. - Automatically Initiated Power Operated

*R.M.P.O. - Remote Manual Power Operated



ATTACHMENT B

Niagara Mohawk Power Corporation

License No. DPR-63


Docket No. 50-220

Supporting Information

A modification will be made to the core spray system at Nine Mile Point Unit 1 during the spring 1981 refueling outage. The modification consists of a high point vent, a keep fill system and isolation valves as shown on Figure 1. The purpose of this modification is to eliminate the need to shutdown the reactor to perform the quarterly core spray valve operability test.

During normal operation, the high point vent system is isolated and the core spray high point vent isolation valves are normally closed. Prior to the quarterly core spray valve operability test and at other times deemed necessary, the two high point vent valves would be opened. Verification of flow to the equipment drain tank would assure the core spray system piping was filled up to the inside core spray isolation valve. The high point vent valves would then be closed and the inside core spray valves operated.

This modification will require the addition of two core spray high point vent isolation valves on each core spray line. These valves will be closed during normal operation. Automatic isolation is also provided.



CORE SPRAY HIGH POINT VENT





FIGURE 1



ATTACHMENT C

Niagara Mohawk Power Corporation

License DPR-63

Docket 50-220

Amendment Classification

The proposed amendment to the Operating License has been evaluated and determined to fall within the definition of Class II of 10CFR 170.22, thereby requiring a fee of twelve hundred dollars (\$1,200).

