

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD, WEST
SYRACUSE, N. Y. 13202

August 1, 1977

Mr. Boyce H. Grier
Director
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA. 19406

RE: Docket No. 50-220
I.E. Bulletin 76-01

Dear Mr. O'Reilly:

In accordance with I.E. Bulletin 76-01, dated March 9, 1976, and our response to that Bulletin, dated March 16, 1976, hydrostatic testing of the isolation condensers was performed on July 3, 1977 during our refueling outage and no tube failures were detected.

Very truly yours,



for T.E. Lempges -
R.R. Schneider
Vice President -
Electric Production

mtm

8103060449

A0
2

