

# LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ]

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME [1] N Y N M P [1] 8 9 14						LICENSE NUMBER [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] 15 25						LICENSE TYPE [4] [1] [1] [1] [1] 26 30				EVENT TYPE [0] [1] 31 32	
CATEGORY [1] CONT 8		REPORT TYPE [ ] [ ] 57 58		REPORT SOURCE [ ] [ ] 59 60		DOCKET NUMBER [0] [5] [0] [ ] [0] [2] [2] [0] 61 68				EVENT DATE [0] [4] [1] [7] [7] [6] 69 74				REPORT DATE [0] [5] [ ] [2] [7] [6] 75 80			

**EVENT DESCRIPTION**

[2] [ ] During routine start-up an analysis of reactor water chlorides indicated 120 ppm.  
[ ] [ ] which is higher than required .1 ppm. Reactor was immediately shutdown.  
[ ] [ ]  
[ ] [ ]  
[ ] [ ]  
[ ] [ ] RO 76-13  
[ ] [ ]

SYSTEM CODE [7] [W] [A] 8 9 10		CAUSE CODE [ ] [E] 11		COMPONENT CODE [H] [T] [E] [X] [L] [H] 12 17				PRIME COMPONENT SUPPLIER [ ] [A] 43		COMPONENT MANUFACTURER [W] [1] [2] [0] 44 47			VIOLATION [ ] [ ] 48	
--------------------------------------	--	-----------------------------	--	--	--	--	--	---	--	--	--	--	----------------------------	--

**CAUSE DESCRIPTION**

[3] [ ] An inspection was made of the south condenser water box and a tube leak was found.  
[ ] [ ] Tube was plugged.  
[ ] [ ]  
[ ] [ ]

FACILITY STATUS [ ] [C] 8 9		% POWER [0] [0] [2] 10 13		OTHER STATUS [ ] [ ] [ ] [ ] [ ] [ ] 14 19		METHOD OF DISCOVERY [ ] [a] 44 45		DISCOVERY DESCRIPTION [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] 46 80			
FORM OF ACTIVITY RELEASED [ ] [Z] 8 9		CONTENT OF RELEASE [ ] [Z] 10 11		AMOUNT OF ACTIVITY [ ] [N/A] 12 44				LOCATION OF RELEASE [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] 45 80			

**PERSONNEL EXPOSURES**

NUMBER [0] [0] [0] 8 9 11		TYPE [ ] [Z] 12 13		DESCRIPTION [ ] [N/A] 14 80			
---------------------------------	--	--------------------------	--	-----------------------------------	--	--	--

**PERSONNEL INJURIES**

NUMBER [0] [0] [0] 8 9 11		DESCRIPTION [ ] [N/A] 12 80			
---------------------------------	--	-----------------------------------	--	--	--

**OFFSITE CONSEQUENCES** Probable

[ ] [ ] NONE  
[ ] [ ]

**LOSS OR DAMAGE TO FACILITY**

TYPE [ ] [Z] 8 9		DESCRIPTION [ ] [N/A] 10 80			
------------------------	--	-----------------------------------	--	--	--

**PUBLICITY**

[ ] [ ] NONE  
[ ] [ ]

**ADDITIONAL FACTORS**

[ ] [ ]  
[ ] [ ]  
[ ] [ ]

8103090439

