

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8105220315 DOC. DATE: 81/05/08 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 LEMPGES, T.E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Management and Program Analysis

SUBJECT: Forwards monthly operating rept for Apr 1981.

DISTRIBUTION CODE: A008S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 184
 TITLE: Annual, Semi-Annual & Monthly Operating Reports (OL Stage)

NOTES:

ACTION:	RECIPIENT ID CODE/NAME:	COPIES		RECIPIENT ID CODE/NAME:	COPIES	
		LTTR	ENCL		LTTR	ENCL
	IPPOLITO, T. 04	7	7			
INTERNAL:	D/DIR, HUM FAC07	1	1	I&E	06	2
	MPA 13	2	2	NRC PDR	02	1
	DR ASSES BR 10	1	1	RAD ASMT BR		1
	<u>REG FILE</u> 01	1	1	T/A DSI		1
EXTERNAL:	ACRS 11	1	1	BROOKHAVEN	12	1
	LPDR 03	1	1	NSIC	05	1

MAY 27 1981



The following information was obtained from the records of the
 Department of the Interior, Bureau of Land Management, regarding
 the land parcels described herein. The information is being provided
 for your information and is not intended to constitute a warranty
 of any kind. The information is based on the records of the
 Department of the Interior, Bureau of Land Management, and is
 subject to change without notice. The information is provided
 as a service to the public and is not intended to constitute
 a warranty of any kind. The information is based on the records
 of the Department of the Interior, Bureau of Land Management, and
 is subject to change without notice. The information is provided
 as a service to the public and is not intended to constitute
 a warranty of any kind.

May 8, 1981

Director, Office of Management
Information and Program Control
United States Nuclear Regulatory Commission
Washington, D. C. 20555

RECEIVED
MAY 13 1981

RE: Docket No. 50-220
DPR-63

U.S.N.R.C.
NMP 3206

Gentlemen:

Submitted herewith is the Report of Operating Statistics and Shutdown Experience for April 1981 for the Nine Mile Point Nuclear Station Unit #1.

Also included is a Narrative Report of Operating Experience for the month of April 1981.

Very truly yours,

Thomas E. Lempges

Thomas E. Lempges
Vice President
Nuclear Generation

jl/

Attachments

cc: Director, Office of I&E (10 copies) ✓

RECEIVED
MAY 21 1981
U.S. NUCLEAR REGULATORY COMMISSION

NMP Document Control

INDEXED

8105220 315

R

A008
S/11

00457 0316

NIAGARA MOHAWK POWER CORPORATION

NINE MILE POINT NUCLEAR STATION UNIT #1

NARRATIVE OF OPERATING EXPERIENCE

April 1981

The Station was shutdown during the entire month for a scheduled refueling outage.

CLASS I WORK - MAINTENANCE - APRIL 1981

- 004570317
- #13394 - Tightened all bolts; found some loose.
 - #14201 - Repaired stem and placed new handle on Drain Valve 107 to #10-43 hydraulic unit
 - #13879 - Replaced upper and lower seat rings gaskets-seat ring disc-"O" rings on Scram Discharge Valve CV-127 on hydraulic unit #14-39
 - #13202 - Replaced upper and lower seat ring gaskets-seat ring disc and O ring on Scram Discharge Valve CV-127 on CR-22-39
 - #13203 - Replaced upper and lower seat ring gaskets and seat ring disc and "O" ring on Scram Valve CV-127 on CR-10-23
 - #13213 - Replaced upper and lower seat ring gaskets & seat ring disc & "O" ring on Scram valve CV-127 on CR-18-47
 - #13207 - Replaced upper and lower seat ring gaskets and seat ring disc-"O" ring on scram valve CV 127 on CR-06-23
 - #13204 - Replaced upper and lower seat ring gaskets & seat ring disc - "O" ring on scram valve V-127 on CR-10-31
 - #13205 - Replaced upper and lower seat ring gaskets & seat ring disc - "O" ring on scram valve CV-127 on CR-06-35
 - #4546 - Cleaned and polished shaft and air cylinder-placed inner and outer seals and repacked valve 80-36-112 Cont. Spray
 - #13150 - Repaired stem on 107 Accum. drain valve on CRD-18-43
 - #13299 - Relocated CLC lines on #13 RxR.P. to clear DW bellows piping
 - #5009 - Inspected snubber #51-MS-1
 - #14244 - Welded spool piece in High Pressure Seal Leak detector line

CLASS I WORK - ELECTRICAL - APRIL 1981

- Replaced #11 Battery - M.O. 2221
- M.O. #11 & #12 battery
- M.O. 1646 - Core Spray
- M.O. 1651 - Auto Isolation Valves
- M.O. 1849 - Emergency Condenser Vent

CLASS I WORK - INSTRUMENT AND CONTROL - APRIL 1981

- #14210 - C.R.D. 34-39 - Air Leak, tightened fitting
- #13396 - Spent fuel pool lev. cont. valve, air leak, replaced tubing

NIAGARA MOHAWK POWER CORPORATION

NINE MILE POINT NUCLEAR STATION UNIT #1

NARRATIVE OF OPERATING EXPERIENCE

April 1981

The Station was shutdown during the entire month for a scheduled refueling outage.

CLASS I WORK - MAINTENANCE - APRIL 1981

- #13394 - Tightened all bolts; found some loose.
- #14201 - Repaired stem and placed new handle on Drain Valve 107 to #10-43 hydraulic unit
- #13879 - Replaced upper and lower seat rings gaskets-seat ring disc-"O" rings on Scram Discharge Valve CV-127 on hydraulic unit #14-39
- #13202 - Replaced upper and lower seat ring gaskets-seat ring disc and O ring on Scram Discharge Valve CV-127 on CR-22-39
- #13203 - Replaced upper and lower seat ring gaskets and seat ring disc and "O" ring on Scram Valve CV-127 on CR-10-23
- #13213 - Replaced upper and lower seat ring gaskets & seat ring disc & "O" ring on Scram valve CV-127 on CR-18-47
- #13207 - Replaced upper and lower seat ring gaskets and seat ring disc-"O" ring on scram valve CV 127 on CR-06-23
- #13204 - Replaced upper and lower seat ring gaskets & seat ring disc - "O" ring on scram valve V-127 on CR-10-31
- #13205 - Replaced upper and lower seat ring gaskets & seat ring disc - "O" ring on scram valve CV-127 on CR-06-35
- #4536 - Cleaned and polished shaft and air cylinder-placed inner and outer seals and repacked valve 80-36-112 Cont. Spray
- #13150 - Repaired stem on 107 Accum. drain valve on CRD-18-43
- #13299 - Relocated CLC lines on #13 RxR.P. to clear DW bellows piping
- #5039 - Inspected snubber #51-MS-1
- #14244 - Welded spool piece in High Pressure Seal Leak detector line

CLASS I WORK - ELECTRICAL - APRIL 1981

- Replaced #11 Battery - M.O. 2221
- M.O. #11 & #12 battery
- M.O. 1646 - Core Spray
- M.O. 1651 - Auto Isolation Valves
- M.O. 1349 - Emergency Condenser Vent

CLASS I WORK - INSTRUMENT AND CONTROL - APRIL 1981

- #14210 - C.R.D. 34-39 - Air Leak, tightened fitting
- #13396 - Spent fuel pool lev. cont. valve, air leak, replaced tubing

00457 0317

