

May 4, 1981

Office of Inspection and Enforcement
Region I
Attention: Elden J. Brunner, Acting Director
Division of Resident and Project Inspection
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Brunner:


Niagara Mohawk's letter dated January 30, 1981 provided our response to Inspection Report 50-410/80-11. In this response, we indicated that within 30 days of our review of drawings for proper incorporation of E&DCR's/N&D's, we would notify you of the results and the corrective action taken. Although the review of drawings was completed on March 31, 1981, additional time is required to properly compile and review the information.

The review included 100% of the Quality Assurance Category I Structural (EC, ES and EY) drawings with E&DCR's/N&D's issued against them, as this was the principal area of concern. In addition, a sample of other Quality Assurance Category I drawings which had E&DCR's/N&D's issued against them: Building Services (EB), Piping (EP), Piping Supports (BZ), Instrument (EK) was reviewed. The review has revealed that other than the structural drawing there were no substantial problems of improper incorporation of E&DCR's/N&D's. The basic problem in the structural area was the incorporation of one time only E&DCR's which has little impact from an As-Built standpoint.

The details of the review and the corrective action to be taken will be submitted by May 29, 1981.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Gerald K. Rhode
Vice President

System Project Management

PEF:ja

81 06050565

