

November 30, 1981

Mr. Eldon J. Brunner, Chief
Projects Branch #1
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Re: Docket No. 50-220
Inspection Report No. 50-220/81-01

Dear Mr. Brunner:

In response to your letter of November 9, 1981, the following information is supplied.

Key cores for doors controlling access to areas where a level greater than 1000 mrem/hr. may be encountered will be changed to the XR sequence.

Keys for this series are issued by the Station Shift Supervisor or the Assistant Station Shift Supervisor to qualified people only for specific entries and are returned to the Shift Supervisor's custody. Master H-keys will be retained for control of access to areas less than 1000 mrem/hr. The key cores will be changed by January 31, 1982.

Sincerely,

31 DEC 3 1981

REGION I
02 1130

Thomas E. Lempges
Thomas E. Lempges
Vice President
Nuclear Generation

TEL/MAS/jkr

8112230346 811217
PDR ADDCK 05000220
Q PDR

'81 DEC 3 PM 1 32

U.S. NRO
REGION I

Handwritten marks