

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8205170306 DOC. DATE: 82/05/11 NOTARIZED: YES DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220  
 AUTH. NAME AUTHOR AFFILIATION  
 DISE, D.P. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 EISENHUT, D.G. Division of Licensing

SUBJECT: Submits response to NRC 820412 request for addl info re reactor decontamination, mitigation of worker radiation doses, removal & replacement of safe ends, & justification for resuming operation.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 16  
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	ORB #2	BC 01	7	7					
INTERNAL:	ELD		1	0	NRR/DHFS	DEPY08	1	1	
	NRR/DL	DIR	1	1	NRR/DL/ORAB		1	0	
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1	1	
	RGN1		1	1					
EXTERNAL:	ACRS	09	10	10	LPDR	03	1	1	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					

THE UNIVERSITY OF CHICAGO  
DIVISION OF THE PHYSICAL SCIENCES  
DEPARTMENT OF CHEMISTRY  
5708 SOUTH CAMPUS DRIVE  
CHICAGO, ILLINOIS 60637


TO THE DIRECTOR, NATIONAL BUREAU OF STANDARDS  
WASHINGTON, D.C. 20535

RE: [Illegible text]

[Illegible text]

May 11, 1982

Darrell G. Eisenhut, Director  
 Division of Licensing  
 Office of Nuclear Reactor Regulation  
 U. S. Nuclear Regulatory Commission  
 Washington, D.C. 20555



Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Dear Mr. Eisenhut:

Your letter of April 21, 1982 requested that Niagara Mohawk provide plans and schedules for 1) reactor decontamination, 2) mitigation of worker radiation doses, 3) removal and replacement of the safe ends, and 4) justification for resuming operation. This letter is in response to that request. The following is a discussion of each of these items:

1) Reactor Decontamination

Niagara Mohawk plans a two phase decontamination of the recirculation loops. The first phase (outlet nozzles to the pump discharge valves) was described in our letter of April 30, 1982. The second phase will address decontamination from the pump suction valves through the vessel inlet nozzles. In order to accomplish the phase II decontamination, an inflatable seal plug, which is being designed at this time, is planned to be utilized. The decontamination process to be used will be similar to that described in our April 30, 1982 letter. When the phase II seal plug design and all other details have been finalized, Niagara Mohawk will submit them for your review.

2) Mitigation of Worker Radiation Doses

Mitigation of radiation doses is provided by 1) effective decontamination, 2) maximum justifiable shielding and 3) overall ALARA control. The decontamination process described above, which is a prime mitigation tool, eliminates as much radiation source as is reasonably achievable. Shielding designs, both internal and external, were based upon providing at least equivalent shielding to that which was there from the water prior to cutting. All other specialty shielding (i.e., lead blankets over piping, etc.) will be reviewed to assure maximum efficiency. A team of Niagara Mohawk and contractor personnel have been assigned the responsibility of maintaining doses as low as reasonably achievable throughout the project. Sufficient workers will be trained and utilized to ensure that individual radiation doses will be minimized.

*Accol  
 5  
 1/1*

8205170306



-----

-----

3) Removal and Replacement of Safe Ends

In 1978, Niagara Mohawk realized the potential for intergranular stress corrosion cracking in the furnace sensitized safe ends. Therefore, a contingency project was developed for recirculation safe end replacement. That contingency project consisted of developing a replacement specification and draft procedures and the procurement of certain hardware. A portion of the software must now be updated to reflect new techniques, such as automatic welding. When the procedures have been finalized, they will be provided to the Nuclear Regulatory Commission for information.

The planned sequence for removal and replacement of the recirculation outlet nozzle safe ends is as follows:

- 1) Install shield curtains and nozzle shielding - Figure 1
- 2) Support the piping system
- 3) Make two cuts on the outlet elbow - Figure 2
- 4) Install internal nozzle shielding - Figure 3
- 5) Remove internal shielding
- 6) Install new elbow with safe end attached - Figure 4

Due to continued ALARA and/or technical considerations, there may be revisions to this sequence. For example, the safe end may be welded to the nozzle prior to installing the elbow, rather than welding the safe end to the elbow outside of the drywell.

The planned sequence for removal and replacement of the recirculation inlet nozzle safe ends is different than the outlet nozzle safe ends, due to geometry. Following is a list of that planned sequence.

- 1) Install external shielding - Figure 5
- 2) Cut and remove the inlet elbow - Figure 6
- 3) Install shield plug - Figure 7
- 4) Remove the spool piece - Figure 8
- 5) Install new spool piece - Figure 9
- 6) Remove the shield plug - Figure 10
- 7) Install a new elbow - Figure 11

As mentioned in the previous discussion of the outlet nozzle safe ends, this sequence is also subject to change due to ALARA and/or technical considerations.

4) Justification for Continued Operation

Furnace sensitized material cracking has been experienced throughout the industry since the early 1970's. At Nine Mile Point Unit 1, 24 of the original 34 furnace sensitized safe ends on the reactor vessel have been replaced. Unresolved safety issue A-42 has addressed intergranular stress corrosion cracking and determined that this does not create a significant safety hazard to the public. However, it is advantageous to minimize the effects on piping system and thus improve plant reliability.



[The text in this section is extremely faint and illegible due to low contrast and scan quality. It appears to be a multi-paragraph document.]

Darrell G. Eisenhut, Director  
Page 3  
May 11, 1982


All replacement recirculation material (i.e., safe end, elbows, and spool pieces) will be 316 nuclear grade stainless steel or equivalent. This material has proven to be the most resistant to intergranular stress corrosion cracking. Therefore, all five recirculation systems will be more crack resistant than originally constructed. This is consistent with NUREG 0313, Rev. 1.

In addition, the riser to elbow weld will be a heat sink weld. The procedure is currently being qualified.

Attached figure 12 shows the schedule plan for replacing these safe ends. As indicated, the first decision point is relative to decontamination, which was addressed in our letter of April 30, 1982.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



D. P. Dise  
Vice President Engineering

GJG:ja

THE UNIVERSITY OF CHICAGO  
DIVISION OF THE PHYSICAL SCIENCES  
DEPARTMENT OF CHEMISTRY  
5780 SOUTH CAMPUS DRIVE  
CHICAGO, ILLINOIS 60637  
TEL: 773-936-3700  
FAX: 773-936-3701  
WWW: WWW.CHEM.UCHICAGO.EDU



State of New York )  
County of Onondaga )

SS:

DONALD P. DISE, being duly sworn, says:

I am Vice President - Engineering of Niagara Mohawk Power Corporation. I have read the foregoing letter and the facts contained in the letter are true to the best of my knowledge, information and belief.

Donald P. Dise  
Donald P. Dise

Sworn to before me on  
this 11 day of May 1982

Cynthia A. Petta  
Notary Public

CYNTHIA A. PETTA  
Notary Public in the State of New York  
Qualified in Onondaga Co. No. 4682225  
My Commission Expires March 30, 1984



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail. The text also mentions that proper record-keeping is essential for identifying trends and anomalies in the data.

2. The second part of the document focuses on the role of internal controls in preventing fraud and errors. It highlights that a strong internal control system is necessary to ensure that all transactions are properly authorized and recorded. The text also notes that internal controls should be regularly reviewed and updated to reflect changes in the business environment.


3. The third part of the document discusses the importance of transparency and communication in financial reporting. It states that providing clear and concise information to stakeholders is essential for building trust and confidence in the organization's financial performance. The text also mentions that transparency is a key component of good corporate governance.

4. The fourth part of the document concludes by summarizing the key points discussed and reiterating the importance of these practices for the long-term success of the organization. It encourages the reader to take the necessary steps to implement these principles in their own organization.


OUTLET  
Figure 1

Install Shield Curtains & Nozzle Shielding


Water Level  
Top of Shroud



Note: If decontamination is accomplished, it will be prior to this step. The decontamination will consist of either stagnant decontamination to just below the nozzles or up through the nozzle by using a seal plug in the annulus.




OUTLET  
Figure 2  
Support Piping & Removal of Elbow




Note: Cut 1 approximately 2 inches below the elbow to riser weld. Cut 2 is to be on the safe end side of the inconel weld.



OUTLET  
Figure 3  
Remove Elbow & Install Shielding




Note: After the elbow is removed, the riser and nozzle will be weld prepared. The ID and OD of the nozzle must be etched to determine the inconnel to nozzle interface. Niagara Mohawk has specified that 3/16" of inconnel must remain so code requirements are not violated.







OUTLET  
Figure 4  
Remove Inner Shielding  
Replace Elbow & Safe End



Note: Prior to installation, a template is made to the final size of the safe end. The safe end is then welded to the elbow prior to installation. The elbow to riser weld is planned to be a heat sink weld.




INLET.  
Figure 5:  
Install Shielding.



Note: Constant flow through CRD, thus keeping the guide tubes filled. Constant drain through one CRD stub tube.




INLET  
Figure 6  
Cut Elbow




Note: Riser to elbow cut is to be approximately 2" below the weld.




INLET  
Figure 7  
Remove Elbow & Install Shield Plug







INLET  
Figure 8  
Remove Spool Piece




Note: Inlet nozzle is prepared the same as the outlet nozzle to assure code compliance.



1000


INLET  
Figure 9  
Install Spool Piece




Note: A template will be made to the final size of the safe end. The safe end will then be welded to the spool piece prior to installation on vessel.




INLET  
Figure 10  
Remove Shield Plug




Note: Plug installation tool and plug will then be removed from the general area.




INLET  
Figure 11  
Install New Elbow



Note: The elbow will be fitted prior to removal of the shield plug. The riser to elbow weld will be a heat sink weld.







NINE MILE POINT #1  
MILESTONE SCHEDULE  
SAFE-END REPLACEMENT

REV. 1 5-10-82

4-7-82

FIGURE 12  
Schedule Plan



10

[The main body of the page contains extremely faint and illegible text, appearing as scattered black specks and light gray smudges. No words or structures are discernible.]