

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8206110293 DOC. DATE: 82/06/07 NOTARIZED: NO DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220  
 AUTH. NAME AUTHOR AFFILIATION  
 LEMPGES, T. E. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 EISENHUT, D. G. Division of Licensing

SUBJECT: Submits details of cutting & welding operations for safe end replacement project, initially identified in 820511 ltr. Heat sink welding procedure currently being qualified. Replacement matl will be 316 nuclear-grade stainless steel.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR, 1 ENCL, 0 SIZE: 2  
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	ORB #2	BC 01	7	17					
INTERNAL:	ELD/HDS3		1	0	NRR/DHFS	DEPY08	1	1	
	NRR/DL	DIR	1	1	NRR/DL/ORAB		1	1	
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1	1	
	RGN1		1	1					
EXTERNAL:	ACRS	09	10	10	LPDR	03	1	1	
	NRC/PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1					



The following information was obtained from the records of the  
 Department of the Interior, Bureau of Land Management, on  
 the subject of the above-captioned land. The land is  
 situated in the County of [ ] State of [ ] and is  
 more particularly described as follows:

The land is situated in the [ ] Section, [ ] Township,  
 [ ] Range, [ ] Meridian, [ ] State of [ ]. The land is  
 bounded on the north by [ ], on the south by [ ],  
 on the east by [ ], and on the west by [ ]. The land is  
 more particularly described as follows:

[ ]

[ ]

[ ]

[ ]

June 7, 1982

Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Dear Mr. Eisenhut:

Niagara Mohawk's letter of May 11, 1982 briefly described the removal and replacement of reactor recirculation safe ends. This letter provides details of cutting and welding operations for the safe end replacement project.

Pipe cutting operations and cut geometry are described in the following two procedures. These are available at the Nine Mile Point Unit 1 plant site for your review.

1. Newport News Industrial Corporation Instruction Number 1399-K-S003, "Pipe Cutting/End Prepping Machine Operation for Niagara Mohawk Power Corporation Nine Mile Point Unit 1, Revision B."
2. Newport News Industrial Corporation Controlled Work Instruction Number CWI-1399K-1-11, "Removal and Replacement of Recirculation Nozzle Safe End and Piping for Pump #11 Suction for Niagara Mohawk Power Corporation Nine Mile Point Unit 1, Revision B". Note: There is a separate Controlled Work Instruction for each pump suction and discharge.

Welding requirements for safe end replacement, elbows and piping are outlined in Section 8.0 of MPR specification 85-21-02, "Technical Requirements for Replacement of NMP-1 Reactor Vessel Recirculation Inlet and Outlet Nozzle Safe Ends, Revision 2." The details of the weld locations, weld geometry, filler material and procedure are available at the Nine Mile Point Unit 1 plant site for your review.

A heat sink welding procedure is currently being qualified at the EPRI-NDE facility in Charlotte, North Carolina. The remaining welding procedure qualifications and welder qualifications will be performed locally. All procedures will be available at the site for your review.

8206110293 820607  
PDR ADCK 05000220  
P PDR

Aool

1942

RECEIVED  
U.S. DEPARTMENT OF THE INTERIOR  
BUREAU OF LAND MANAGEMENT  
WASHINGTON, D. C.

OFFICE OF THE ASSISTANT  
SECRETARY FOR LAND  
MANAGEMENT

WASHINGTON, D. C.

TO: ASSISTANT SECRETARY FOR LAND MANAGEMENT  
FROM: [Illegible]

DATE: [Illegible]

SUBJECT: [Illegible]

[Illegible text]

[Illegible text]

[Illegible text]

RECEIVED  
U.S. DEPARTMENT OF THE INTERIOR  
BUREAU OF LAND MANAGEMENT  
WASHINGTON, D. C.

Mr. Darrell G. Eisenhut

Page 2


June 7, 1982

Our current plans call for the use of automatic welding machines for all pipe welding inside the drywell.

All replacement material will be 316 nuclear grade stainless steel or equivalent. This material has proven to be the most resistant to intergranular stress corrosion cracking. This is consistent with NUREG 0313, Revision 1.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



Thomas E. Lemppes

Vice President Nuclear Generation

GJG:ja

[Faint, illegible text, possibly bleed-through from the reverse side of the page. The text is scattered and difficult to decipher.]