

DDO16

Docket No. 50-220

OCT 26 1982

Mr. Donald P. Dise
Vice President - Engineering
c/o Miss Catherine R. Seibert
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Dear Mr. Dise:

Subject: NUREG-0737 Item II.K.3.21, Restart of Core Spray and Low-Pressure Coolant-Injection Systems

Re: Nine Mile Point Nuclear Station, Unit No. 1

Reference: Letter D. B. Waters (BWR Owners Group) to Darrell G. Eisenhut (NRC), BWROG-80-12, December 29, 1980

We have reviewed your responses dated December 17 and 31, 1980, to NUREG-0737 Item II.K.3.21 in which you referenced the BWR Owners Group position (referenced letter) as applicable to your plant. We have completed our review of the BWR Owners Group response to Item II.K.3.21, and agree with the Owners Group position that logic modifications for LPCI and low-pressure core spray are unwarranted.

Our Safety Evaluation is enclosed. This completes our review of NUREG-0737 Item II.K.3.21 for your plant.

Sincerely,

Original signed by
D. B. Vassallo

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure: As stated

cc: See next page

Distribution:	<u>Docket File</u>	NRC PDR	LPDR	ORB#2 Rdg	D. Eisenhut	NSIC
J. Heltemes	S. Norris	P. Polk	OELD	I&E-1	ACRS-10	Gray
ORAB	V. Rooney	M. Hodges				

8211120236 821026
PDR ADQCK 05000220
P PDR

OFFICE	DL:ORB#2	DL:ORB#2	DL:ORB#2				
SURNAME	SNORRIS	PPOTK	DVassallo				
DATE	10/21/82	10/21/82	10/21/82				

Mr. Donald P. Dise
Niagara Mohawk Power Corporation

cc:

Troy B. Conner, Jr. Esq.
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Ave., NW
Washington, D.C. 20006

T. K. BeBoer, Director
Technological Development Programs
State of New York
Energy Office
Swan Street Building
CORE 1 - Second Floor
Empire State Plaza
Albany, New York 12223

Mr. Robert P. Jones, Supervisor
Town of Scriba
R. D. #4
Oswego, New York 13126

Niagara Mohawk Power Corporation
ATTN: Mr. Thomas Perkins
Plant Superintendent
Nine Mile Point Nuclear Station
P.O. Box 32
Lycoming, New York 13093

U.S. Environmental Protection Agency
Region II Office
Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

Resident Inspector
c/o U.S. NRC
P. O. Box 126
Lycoming, New York 13093

John W. Keib, Esquire
Niagara Mohawk Power Corporation
300 Erie Boulevard West
Syracuse, New York 13202

Ronald C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

