

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8304260460 DOC. DATE: 83/04/20 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 LOMPGES, T.E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 VASSALLO, D.B. Operating Reactors Branch 2

SUBJECT: Forwards revised reactor vessel pressure-temp limits, per
 830328 request. Info updates 780322 application.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	NRR	ORB2 BC 01	7	7				
INTERNAL:	ELD/HDS3		1	0	NRR/DE/MTEB		1	1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1
	<u>REG FILE</u>	04	1	1	RGN1		1	1
EXTERNAL:	ACRS	09	6	6	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 23

VASSALLO, B. OPERATING DIRECTOR BRANCH 5
 RECIPIENT NAME
 LEWIS, J. PROGRAM POWER CORP.
 AUTUMN AFFILIATION
 1411:50-50 New York Point Station, Post 12, New York 10005
 ACCESSION NO: 8504500000
 DATE: 12/15/50

SUBJECT: Formosa revised reactor vessel pressure-temp limiter
 850250 request info updated 7/28/55 application

TITLE: OR submitted: General Distribution
 DISTRIBUTION CODE: A018 COPIES RECEIVED: TR -- ENCL --
 SIZE: -----

NOTES:

INTERNAL:	RECEIVED IN CODE NAME	LTR ENCL	COPIES	RECEIVED IN CODE NAME	LTR ENCL	COPIES	LITERATURE	
							COPIES	LITERATURE
INTERNAL: ENCL 03	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1
INTERNAL: ENCL 01	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1
INTERNAL: ENCL 04	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1
INTERNAL: ENCL 02	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1
INTERNAL: ENCL 03	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1
INTERNAL: ENCL 02	NRN 0005 00 01	1	1	NRN 0005 00 01	1	1	1	1

April 20, 1983

Director of Nuclear Reactor Regulation
Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Gentlemen:

Your letter of March 28, 1983 requested information on our application of March 22, 1978. That application provided revised reactor vessel pressure-temperature limits. The attachment to this letter provides the information requested.

Very truly yours,



T. E. Lempges
Vice President Nuclear Generation

TEL/MGM:bd

8304260460 830420
PDR ADOCK 05000220
P PDR

April



0 4 22

1945

1945

1945

1945

1945

1945

1945

1945

1945

1945

1945

1945

NIAGARA MOHAWK POWER CORPORATION

NINE MILE POINT UNIT NO. 1

DOCKET 50-220
DPR-63

Revised Reactor Vessel Pressure-Temperature Limits

1. Request

Identify the limiting reactor vessel belt line component (plate or weld) for the Nine Mile Point Unit 1 (NMP-1) reactor vessel.

Response

The limiting component for the Nine Mile Point Unit 1 reactor vessel is the weld material.

2. Request

Provide the weight percent copper (Cu), phosphorus (P) and nickel (Ni) contained in the limiting component.

Response

Our letter of January 31, 1978 provided the requested information for the Nine Mile Point Unit 1 reactor vessel. The attached table from that letter summarizes the chemical analysis of the electrodes used on the Nine Mile Point Unit 1 reactor vessel welds. This indicated that the maximum copper content is less than 0.05 percent and phosphorus is less than 0.022 percent. The nickel content of the electrodes is also included in this table.

3. Request

Provide the bases for the revised curve you submitted. The bases should discuss the expected change in the RT_{NDT} , considering the projected neutron fluence for the Cu, Ni and P content of the limiting component. The data that support the bases should be from material that has been irradiated in commercial light water reactors and is similar to that in the NMP-1 limiting component.

Response

Revised Figure 3.2.2.c of our application of March 22, 1978 was derived using the formula of regulatory position C.1a of Regulatory Guide 1.99, Revision 1, April 1977 based on the maximum Cu and P concentrations as described in response to 2 above. Nickel content does not enter into the formula for calculating the Nil Ductivity Transition Temperature shift as presented in the Regulatory Guide.

Chemical Analysis
C-E Deposited All Weld Metal - Electrode Types E8018C-3 - E8018G
And Core Wire Used to Manufacture Electrodes
Time Period - 2/19/63 to 11/6/69

Size	R-No.	D-No.	Si	S	P	Mn	C	Ni	Mo	V	Cu	Lot No.
3/32	1379		.05	.018	.013	.24	.034					
		3250	.45	.016	.020	1.02	.109	1.32	.26			
		3276	.41	.015	.015	1.00	.088	1.13	.31			
3/32	1766		.05	.010	.009	.22	.029			.006		
			.27	.015	.021	.98	.088	1.00	.24			
1/8	1390		.05	.023	.008	.22	.028			.011		
		3247	.55	.016	.017	1.10	.094	1.28	.30			
		3262	.49	.018	.016	.93	.087	1.12	.32			
		3300	.39	.011	.015	1.12	.092	1.13	.27			1357
		3329	.46	.014	.020	1.10	.089	1.17	.34			
1/8	1813		.05	.018	.007	.27	.034			.001		
		4710	.26	.017	.022	.98	.086	1.01	.28			
1/8	2025		.05	.014	.007	.23	.035			.006		
		5048	.29	.014	.008	1.03	.065	1.04	.28			EBDG
		5272	.59	.011	.008	1.34	.071	1.32	.31			JOLG
5/32	1383		.05	.013	.003	.25	.039					
		3177	.36	.015	.016	.93	.056	1.10	.22			
5/32	1401		.05	.016	.005	.26	.034					
		3216	.61	.012	.015	1.24	.080	1.11	.26			
		3249	.45	.014	.014	.97	.076	1.09	.31			
		3307	.46	.014	.020	.98	.078	1.18	.29			1331
5/32	1735		.05	.011	.011	.24	.025			.005		
		4711	.33	.017	.022	.72	.075	.93	.27			
5/32	1697		.05	.012	.005	.21	.034			.004		
		4622	.24	.012	.011	.90	.072	1.04	.30			
5/32	1767		.05	.010	.010	.28	.029			.006		
		4729	.23	-	.020	1.24	.077	-	-			
		4820	.20	.014	.009	.82	.068	.96	.28			
		5118	.43	.012	.008	1.19	.058	1.49	.34			
5/32	1631		.05	.016	.005	.25	.028			.009		
		5000	.36	.017	.013	.93	.064	1.06	.31			EBFE
3/16	1391		.05	.018	.008	.22	.025			.008		
		3251	.48	.018	.012	.99	.069	1.10	.28			
3/16	1814		.05	.015	.008	.25	.038			.001		
		4728	.24	.016	.019	.97	.10	1.03	.29			
		4712	.32	.016	.020	1.08	.11	1.13	.28			



10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

Chemical Analysis

C-E Deposited All Weld Metal - Electrode Types E8018C-3 - E8018G
 And Core Wire Used to Manufacture Electrodes
 Time Period - 2/19/63 to 11/6/69

Size	R-No.	D-No.	Si	S	P	Mn	C	Ni	Mo	V	Cu	Lot No.
3/16	1742		.05	.013	.007	.23	.027			.005		
		4626	.34	.013	.010	1.01	.070	1.14	.34			
3/16	1866		.05	.017	.011	.20	.026			.005		
		5005	.17	.015	.008	.81	.064	1.04	.26			EOAG
1/4	1384		.05	.020	.005	.21	.023			.006		
		3252	.53	.018	.013	.94	.067	1.10	.36			
		3297	.50	.016	.013	1.04	.085	1.18	.30			1333
1/4	1736		.05	.012	.011	.21	.025			.005		
		4627	.49	.014	.012	1.17	.086	1.09	.34			
		4713	.20	.017	.021	.91	.090	1.02	.28			
1/4	1942		.05	.015	.001	.22	.034			.006		
		4971	.29	.011	.009	.95	.086	.92	.27			DAGG
		4972	.20	.012	.008	.84	.063	.98	.25			DAGG
5/32	2031		.05	.016	.005	.23	.003			.005		
		5158	.48	.011	.009	1.26	.062	1.46	.34			HOKG
1/4	2079		.05	.013	.006	.23	.031			.004		
		5159	.45	.010	.009	1.30	.081	1.49	.35			HAEG
3/32	2043		.06	.014	.006	.23	.032			.006		
		5181	.49	.011	.010	1.40	.074	1.75	.36			HBEG
1/4	2092		.05	.016	.008	.24	.043			.005		
		5274	.43	.010	.008	1.25	.081	1.29	.30			JBFG
3/16	2032		.05	.016	.005	.21	.034			.004		
		5508	.45	.011	.007	.99	.076	.94	.24	.004	.02	
5/32		5509	.44	.011	.007	.95	.073	.90	.22	.004	.02	
3/16	2506		.06	.008	.005	.25	.034					
5/32		7676	.37	.013	.010	.98	.077	.94	.29	.009	.04	KACI

Analysis for copper levels in the core wire and deposited weld metal was not performed by C-E during this time period. The wire supplier analyzed for copper but could not identify with the heats submitted although they did state that 99% of the wire contained less than .02% copper and very little scrap was used during this period.

Therefore, since 100% of core wire copper is transferred across the arc and none was added through the electrode coating, it is safe to assume that all the deposited welds contained .02 or less copper during this period.

0.05

10/10/10

10/10/10

10/10/10