

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8306010360 DOC. DATE: 83/05/26 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C.V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 VASSALLO, D.B. Operating Reactors Branch 2

SUBJECT: Submits alternative solutions to alleviate potential spurious operation of valves listed in 821203 suppl to 821001 App R submittal. Requirements for valves 40-30, 40-31 & 38-02 not required.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: Fire Protection

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR ORB2 BC 01	3	3			
INTERNAL:	ELD/HDS3	1	0	IE FILE 06	1	1
	IE/WHITNEY, L	1	1	NRR FIORAVANT07	2	2
	NRR WAMBACH	1	0	NRR/DE/CEB 09	2	2
	NRR/DL DIR	1	1	<u>REG FILE</u> 04	1	1
	RGN1	1	1			
EXTERNAL:	ACRS 11	3	3	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 0

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that proper record-keeping is essential for the integrity of the financial system and for the ability to detect and prevent fraud. The text notes that without reliable records, it would be difficult to track the flow of funds and identify any irregularities.

2. The second part of the document outlines the specific procedures for recording transactions. It details the steps involved in entering data into the system, including the use of standardized codes and the requirement for double-checking entries to ensure accuracy. The text also mentions the importance of keeping records up-to-date and the need for regular audits to verify the information.

3. The third part of the document addresses the issue of data security. It discusses the various risks associated with storing sensitive financial information, such as theft, loss, or unauthorized access. The text provides recommendations for implementing robust security measures, including the use of encryption, firewalls, and secure access protocols to protect the data.

4. The fourth part of the document focuses on the role of technology in modern record-keeping. It highlights the benefits of using automated systems and software solutions to streamline the recording process and reduce the risk of human error. The text also discusses the importance of staying current with technological advancements to ensure the system remains efficient and secure.

5. The fifth and final part of the document concludes by summarizing the key points discussed. It reiterates the importance of accurate record-keeping, the need for strict procedures, and the importance of data security. The text encourages all users to adhere to these guidelines to ensure the reliability and integrity of the financial records.

May 26, 1983

Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Dear Mr. Vassallo:

Your November 3, 1982 letter requested additional information regarding our October 1, 1982 Appendix R submittal. Our December 3, 1982 letter provided a response to your request. In our response to Question 7, we provided a list of valves that could be adversely affected by spurious operation and the proposed solution to alleviate the potential adverse effect. After re-examining the list of valves and solutions, we have determined alternative solutions for three of the valves provided in our response.

For core spray high point vent valves 40-30 and 40-31 (our December 3, 1982 submittal contained a typographical error; it listed these two valves as 40-31 and 40-32), we originally proposed to remove the power to these normally closed valves. This would prevent spurious operation of the valves. However, each of the lines where these valves are located has a normally locked closed manual valve (valves 40-26 and 40-27). With these manual valves locked closed, no adverse affects would result should either valve 40-30 or 40-31 spuriously open. Therefore, the requirement for removing power is not necessary.

Asok
1/0

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF CHEMISTRY
5780 SOUTH ELSTON STREET
CHICAGO, ILLINOIS 60637

FOR THE DIRECTOR

CHICAGO, ILLINOIS

RECEIVED

TO THE DIRECTOR OF THE UNIVERSITY OF CHICAGO
FROM THE DIRECTOR OF THE UNIVERSITY OF CHICAGO
SUBJECT: [Faint text, likely a report title or subject line]

[The following text is extremely faint and largely illegible, appearing to be the body of a report or letter. It contains several lines of text, some of which are partially legible, such as "The following data were obtained from the study of...", "The results of the study are...", and "These results are in agreement with...".]

For shutdown cooling isolation valve 38-02, we originally proposed to remove the power to this normally closed valve. This would prevent spurious opening of the valve. Spurious opening of the valve at reactor operating pressures and temperatures was not desirable because it was thought that the heat exchangers, pumps and piping after the external isolation valve could not withstand reactor operating temperatures. However, further analysis now indicates that the integrity of these components would be assured under reactor operating temperatures and pressures. Therefore, the requirement for removing power to valve 38-02 is not needed.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President

Nuclear Engineering & Licensing

CVM/MTG:djm



[The text in this section is extremely faint and illegible due to low contrast and scan quality. It appears to be a header or introductory section of a document.]

[The main body of the document contains several paragraphs of text that are completely illegible due to the same quality issues as the header section.]