

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8307140309 . . . DOC. DATE: 83/07/08 NOTARIZED: NO DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220  
 AUTH. NAME AUTHOR AFFILIATION  
 MANGAN, C.V. Niagara Mohawk Power Corp.  
 RECIPIENT NAME RECIPIENT AFFILIATION  
 VASSALLO, D.B. Operating Reactors Branch 2

SUBJECT: Provides addl info to suppl & clarify 770713, 1216 & 790108  
 proposed license, amends re HPCI, augmented inservice insp  
 program & continuous leak monitoring.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR ORB2 BC 01	7		
INTERNAL:	ELD/HDS3	1 0	NRR/DE/MTEB	1
	NRR/DL DIR	1 1	NRR/DL/ORAB	1
	NRR/DSI/METB	1 1	NRR/DSI/RAB	1
	<u>REG FILE</u> 04	1 1	RGN1	1
EXTERNAL:	ACRS 09	6 6	LPDR 03	1
	NRC PDR 02	1 1	NSIC 05	1
	NTIS	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 25

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

July 8, 1983

Director Nuclear Reactor Regulation  
Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Gentlemen:

This letter provides additional information to supplement and clarify proposed license amendments which are currently under review by your staff. The following is a list of the affected amendments:

1. High Pressure Coolant Injection System (July 13, 1977)
2. Augmented In-Service Inspection Program (December 16, 1977)
3. Primary Containment Continuous Leak Monitoring System (January 8, 1979)

High Pressure Coolant Injection

A proposed amendment was submitted on July 13, 1977 in which we deleted the requirement for High Pressure Coolant Injection System and Control Rod Drive hydraulic technical specifications. This was based on the fact that no credit was allowed in the ECCS calculations. We wish to withdraw this license amendment request at the present time.

Augmented Inservice Inspection Program

Niagara Mohawk wishes to withdraw the proposed amendment for the Augmented In-service Inspection Program. We are currently revising this to include plant modifications made during the past recirculation pipe replacement outage. In addition, we are revising our In-service Inspection and In-service Testing Programs in accordance with 10CFR50.55.a(g).

*Accol  
1/0*

Page 10

U.S. BUREAU OF LABOR RELATIONS  
WASHINGTON, D.C. 20540  
Case No. 1-10000-10000  
Date: 10/10/10

Case No. 1-10000-10000  
Date: 10/10/10

Page 10

The following information was obtained from the records of the Bureau of Labor Relations, U.S. Department of Labor, Washington, D.C. 20540, on October 10, 1960.

1. The Bureau of Labor Relations (B.L.R.)
2. The Bureau of Labor Relations (B.L.R.)
3. The Bureau of Labor Relations (B.L.R.)

U.S. BUREAU OF LABOR RELATIONS

The following information was obtained from the records of the Bureau of Labor Relations, U.S. Department of Labor, Washington, D.C. 20540, on October 10, 1960.

U.S. BUREAU OF LABOR RELATIONS

The following information was obtained from the records of the Bureau of Labor Relations, U.S. Department of Labor, Washington, D.C. 20540, on October 10, 1960.

Continuous Leak Monitoring

The deletion for Primary Containment continuous leak monitoring, which was submitted on January 8, 1979, should be changed such that Surveillance Requirement 4.3.3.g(1) remains. Operating Procedure N1-OP-9, "Nitrogen Inerting and H<sub>2</sub>-O<sub>2</sub> Monitoring System for Primary Containment and Pressure Suppression System" provides for monitoring gross leakage. However, Specification 4.3.3.g(2) is still to be deleted since it is not required by the utilization of this method.

Very truly yours,

*C. V. Mangan*

C. V. Mangan  
Vice President

Nuclear Engineering and Licensing

CVM/MGM:bd

1

.....

.....

.....

.....