

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8405230193    DOC. DATE: 84/05/15    NOTARIZED: NO    DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe    05000220  
 AUTH. NAME    AUTHOR AFFILIATION  
 MANGAN, C.V.    Niagara Mohawk Power Corp.  
 RECIP. NAME    RECIPIENT AFFILIATION  
 VASSALLO, D.B.    Operating Reactors Branch 2

SUBJECT: Advises that field measurements of normal operating voltages at reactor protection sys components scheduled during startup from current refueling & maint outage, per util 831215 ltr.

DISTRIBUTION CODE: A001S    COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB2 BC	01	7				
INTERNAL:	ELD/HDS3		1		NRR/DE/MTEB		1
	NRR/DL DIR		1		NRR/DL/ORAB		1
	NRR/DSI/METB		1		NRR/DSI/RAB		1
	<u>REG FILE</u>	04	1		RGN1		1
EXTERNAL:	ACRS	09	6		LPDR	03	1
	NRC PDR	02	1		NSIC	05	1
	NTIS		1				

TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL 0



May 15, 1984

Director of Nuclear Reactor Regulation  
Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63

Dear Mr. Vassallo:

Our letter of December 15, 1983 indicated that we would obtain field measurements of normal operating voltages at the reactor protection system components. These measurements will be used to determine if circuit modifications, or motor generator set normal operating voltage changes are required. These modifications, if necessary, will ensure that the recommended General Electric normal operating voltage of  $115 + 2$  volts at the components is met. Measurements are currently scheduled to be taken during startup from the current refueling and maintenance outage. However, if circuit modifications are necessary, they will be completed during the currently planned 1986 refueling and maintenance outage. However, our preliminary review indicates that the motor generator set normal operating voltage will not need to be changed.


Sincerely,

NIAGARA MOHAWK POWER CORPORATION

*C. V. Mangan*

C. V. Mangan  
Vice President  
Nuclear Engineering and Licensing

CVM/MGM:bd



Acc 1  
1/0



Handwritten marks or scribbles in the top right corner.

Main body of extremely faint, illegible text, possibly bleed-through from the reverse side of the page.

Faint text at the bottom of the page, possibly a footer or page number.