REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8407030439 DOC.DATE: 84/06/29 NOTARIZED: YES DOCKET # FACIL:50-220 Nine Mile:Point Nuclear Station, Unit 1, Niagara Powe 05000220

AUTH.NAME AUTHOR AFFILIATION

BEMPGES, T.E. Niagara Mohawk Power Corp.

RECIP.NAME. RECIPIENT AFFILIATION

VASSALLO, D.B. Operating Reactors Branch 2

SUBJECT: Forwards response to Generic Ltr. 84-11 retinsps of BWR stainless steel piping, Submittal of previous results, associated w/IE Bulletins 82-03 & 82-02 inapplicable.

DISTRIBUTION CODE: A0478 COPIES RECEIVED:LTR L ENCL SIZE: L'ACTIFLE: OR: Submittal: Inservice Inspection/Testing

NOTES:

08/22/60

05000220

OL:08/22/69

b	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		
v	NRR ORB2 BC	014	1 ⊧7	· 7					
INTERNAL:	ELD/HDS3		1.	0	NRR/DE/MEB	15	1	1	
	NRR/DE/MTEB	14	1 i.	1	NRR/DL/TAPMG		1	1.	
	REG FILE	04	ı 1	1	RGN1		1	1	
EXTERNAL:	ACRS	16.	10	10	LPDR	03	1	1	
	NRC PDR NTIS	021	, 1 r	1	NSIC	05°	1	, 1,	

B Taring CAY : CAN TO THE STANK C STANK COME OF THE STANK AND COME OF THE STANK included the contract the following the form the station, and it is east to the following the follow HULLIA I IX TIA THE WINDER 3 (A -) 1 . Tyr. 441 4 3 x 15 you of the concr (orp. and ', 91')

RECIPIES A AFFILLATIONS separating keactors franch ?

as att: Forwards resource to seneric Ltr Ed-11 re inspending standings steel projection of previous results absorbated will suffering Menus anapplicable.

al relevabled comes and supplies the collection of the collection Mills: Fix but mittel: Incorvice Inspection/lesting

> 2 31.1 CA122/101:10

A REPORT OF THE

05500020

COPTES LITE ENGL		RECIPIELT I. (COD) Amal E		LOPIES		7 4 3 8 6 8 3 1 m			
			,,,,	4	1	-	all Sully mind		
1	į,	c3 g +4	1"# \ 40\ \$\\#1"#	*)	8		8 6"XHX\\H_1 x	: 1,	3.4
K	1	c N 14 16	/	ľ	1	9 J	18 37" \ Jux\xa51		
Î	1		£17-351	1	K	gu kiji	ally one		
i	1	Σij	;સ€હ*્ય.⊒	0.1	10	σį	en \n	: 1	(14 X *
1.	1	۲., د	11 6 lm	1	1	an	MAY JAM		
				t	à.		alta		

NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

June 29, 1984

Director of Nuclear Reactor Regulation Attention: Mr. Domenic B. Vassallo, Chief Operating Reactors Branch No. 2 Division of Licensing U. S. Nuclear Regulatory Commission Washington, D.C. 20555

> Re: Nine Mile Point Unit 1 Docket No. 50-220 DPR-63

Dear Mr. Vassallo:

Attached is Niagara Mohawk's response to Generic Letter 84-11 dated April 19, 1984, regarding inspections of boiling water reactor stainless steel piping. In general, Niagara Mohawk's response follows the staff recommendations in Generic Letter 84-11. It should be noted Nine Mile Point Unit 1 was excluded from earlier Inspection and Enforcement Bulletins 82-03 and 83-02. Therefore, submittal of previous results associated with those bulletins are not applicable.

Very truly yours,

T. E. Lempges Vice President Nuclear Generation

TEL/AJP:bd Attachment

8407030439 840629 PDR ADDCK 05000220 Q PDR ROAT.

1

The second section is the second seco

* 7

UNITED STATES

NUCLEAR REGULATORY COMMISSION

In the Matter of

NIAGARA MOHAWK POWER CORPORATION
(Nine Mile Point Nuclear Station
Unit No. 1)

Docket No. 50-220

AFFIRMATION

I, Thomas E. Lempges, Vice President, Nuclear Generation, a duly authorized officer of Niagara Mohawk Power Corporation, licensee in the captioned proceeding, certify that the information presented herein, indicates Niagara Mohawk's current plans for Nine Mile Point Unit 1 in response to Generic Letter 84-11.

NIAGARA MOHAWK POWER CORPORATION

Inomas_E. Lempges Vice President

Nuclear Generation

Subscribed and sworn to before me on this $29^{\pm 0}$ day of June, 1984

NOTARY PUBLIC

CHRISTINE AUSTIN

Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687

My Commission Expires March 30, 1925

7

> CHRESTAL AUSTM Natur Pleit is in Jeen of Kier York Desinct in Dickley On No. Albielt Lif Commuses Engbes Kinch 30, 19...

_ - - +## II

RESPONSE TO NUCLEAR REGULATORY-COMMISSION GENERIC LETTER 84-11 DATED APRIL 19, 1984 REGARDING INSPECTIONS OF BWR STAINLESS STEEL PIPING

In response to Generic Letter 84-11, Niagara Mohawk currently plans to do the following*:

- 1. Piping susceptible to intergranular stress corrosion cracking will be inspected (as indicated below in item 2) once each refueling cycle commencing with Niagara Mohawk's next scheduled refueling outage.
- 2. Stainless steel welds susceptible to intergranular stress corrosion cracking will be inspected in piping equal or greater than four inches in diameter, in systems operating over 200°F, that are part of or connected to the reactor coolant pressure boundary, out to the second isolation valve as follows.
 - Inspection of 20 percent of the welds in each pipe size of intergranular stress corrosion cracking sensitive welds not inspected previously (but no less than four welds) and reinspection of 20 percent of the welds in each pipe size inspected previously (but not less than two welds) and found not to be cracked. This sample will be selected primarily from weld locations shown by experience to have the highest propensity for cracking.
 - Unrepaired cracked welds. b.
 - c. Inspection of weld overlays on welds where circumferential cracks longer than ten percent of circumference will be measured. Disposition of any findings will be reviewed on a case-by-case basis.
 - d. Inspection of any weld treated by induction heating stress improvement which has not had post treatment ultrasonic test acceptance.
 - In the event new cracks or significant growth of old cracks are e. found, inspection scope shall be expanded in accordance with Inspection and Enforcement Bulletin 83-02.
- 3. Inspections shall be performed in accordance with the Nine Mile Point Unit 1 Technical Specifications. Inspections shall be performed by individuals qualified to A) the ASME Boiler and Pressure Vessel Code, Section XI and B) the (40-hr) Ultrasonic Testing Operator Training Course for intergranular stress corrosion cracking developed by the Electric Power Research Institute and the Nondestructive Examination Center, or an equivalent Nuclear Regulatory Commission approved course.

The state of the s

" Salva a commence of the salva salv

الم المكاويات المتعافلية والمعاولية المحاربية الأراث المحاولية أن المحاولة وولايات المعطور المحاربين المحاربين

BY BY NEW COSTS S HE M D

the second of

The first the second of the se

A CONTRACT OF THE CONTRACT OF

The state of the s

BORNON DE LES REPRESENTANTES DE LA PROPERTIE D

THE CONTRACT OF BUILDING STATE OF THE CONTRACT OF THE CONTRACT

THE RESERVE TO STATE OF THE RESERVE THE STATE OF THE STAT

TOTAL TO THE TOTAL TO THE TOTAL TOTAL TO THE TOTAL TO THE TOTAL TOTAL TO THE TOTAL TOTAL TO THE TOTAL TOTAL TO THE TOTAL TO THE TOTAL TOTAL TOTAL TO THE TOTAL TOTAL TOTAL TO THE TOTAL TOTAL

- 4. Leak detection and leakage limits will be addressed separately in a Technical Specifications amendment as requested by your letter of June 6, 1984.
- 5. Crack evaluation and repairs will meet the intent of Attachment 2 to Generic Letter 84-11.
- * This program applies to service sensitive materials. However, material which has been demonstrated to be corrosion-resistant material as discussed in NUREG 0313 Rev. 1 and which has been installed at Nine Mile Point Unit 1, will not be subject to this type of inspection program.

.

•