

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8407100570 DOC. DATE: 84/06/29 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara-Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 LEMPGES, T. E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 VASSALLO, D. B. Operating Reactors Branch 2

SUBJECT: Forwards application for amend to License DPR-63, providing
 Tech Spec re NUREG-0737, Items II.B.1, II.F.1.3, II.F.1.4,
 II.F.1.5 & II.F.1.6. Tech Specs requested per Generic Ltr
 83-36 not included for reasons discussed. Fee encl.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+13
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES: 05000220
 OL: 08/22/69

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
	NRR ORB2 BC	01	7	7			
INTERNAL:	ELD/HDS3		1	0	IE/DEPER DIR	33	1 1
	IE/DEPER/EPB		3	3	IE/DEPER/IRB		1 1
	NRR ERICKSON, P		1	1	NRR PAULSON, W.		1 1
	NRR/DHFS DEPY29		1	1	NRR/DL DIR	14	1 1
	NRR/DL/ORAB	18	3	3	NRR/DSI/ADRS	27	1 1
	NRR/DSI/AEB		1	1	NRR/DSI/ASB		1 1
	NRR/DSI/RAB		1	1	NRR/DST DIR	30	1 1
	<u>REG FILE</u>	04	1	1	RGN1		1 1
EXTERNAL:	ACRS	34	10	10	LPDR	03	1 1
	NRC PDR	02	1	1	NSIC	05	1 1
	NTIS		1	1			

w/ check
\$ 150
076199

Very faint header text at the top of the page, possibly including a title or reference number.

Several lines of very faint text, possibly a short paragraph or a list of items.

Column 1	Column 2	Column 3	Column 4	Column 5	Column 6
A	P	A	...
B	P	A	...
C	P	A	...
D	P	A	...
E	P	A	...
F	P	A	...
G	P	A	...
H	P	A	...
I	P	A	...
J	P	A	...
K	P	A	...
L	P	A	...
M	P	A	...
N	P	A	...
O	P	A	...
P	P	A	...
Q	P	A	...
R	P	A	...
S	P	A	...
T	P	A	...
U	P	A	...
V	P	A	...
W	P	A	...
X	P	A	...
Y	P	A	...
Z	P	A	...

June 29, 1984

Director of Nuclear Reactor Regulation
 Attention: Mr. Domenic B. Vassallo, Chief
 Operating Reactors Branch No. 2.
 Division of Licensing
 U. S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Dear Mr. Vassallo:

Generic Letter 83-36 dated November 1, 1983 requested information regarding the implementation of Technical Specifications for certain NUREG 0737 items. The attachment to this letter provides proposed Technical Specifications regarding the NUREG items listed below:

Reactor Coolant System Vents	(II.B.1)
Containment High Range Radiation Monitor	(II.F.1.3)
Containment (Drywell) Pressure Monitor	(II.F.1.4)
Containment (Suppression Chamber) Water Level	(II.F.1.5)
Containment Hydrogen Monitor	(II.F.1.6)

Proposed Technical Specifications regarding Post Accident Sampling System (II.B.3), Noble Gas Effluent Monitor (II.F.1.1), Sampling and Analysis of Plant Effluents (II.F.1.2), and Control Room Habitability (III.D.3.4) have not been included for reasons discussed herein.

Generic Letter 83-36 requested that the administrative control section of the Technical Specifications be revised to reference a post accident sampling system administrative program covering personnel training, sampling and analysis procedures, and equipment maintenance (II.B.3). Niagara Mohawk does not believe implementation of Technical Specifications is necessary to ensure the establishment and maintenance of such an administrative program. Pending further revisions, in accordance with our March 8, 1984 letter, site Process Survey Procedure N1-PSP-13 will address the three facets of the administrative program requested in Generic Letter 83-36. Implementation of site Process Survey Procedure N1-PSP-13 is, therefore, considered sufficient to ensure the capability of the plant to obtain and analyze reactor coolant and containment atmosphere samples under normal and accident conditions.

8407100570 840629
 PDR ADDCK 05000220
 PDR

4046
 w/check
 # 150
 # 076199

SECRET

U. S. DEPARTMENT OF THE ARMY
HEADQUARTERS, ARMY
WASHINGTON, D. C. 20315
OFFICE OF THE ADJUTANT GENERAL
ATTENTION: THE ADJUTANT GENERAL

ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL

1000000-000-0000

ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL
ATTENTION: THE ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL

ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL
ATTENTION: THE ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL

ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL
ATTENTION: THE ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL

ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL
ATTENTION: THE ADJUTANT GENERAL
OFFICE OF THE ADJUTANT GENERAL

Generic Letter 83-36 also requested Technical Specifications regarding operability of Noble Gas Effluent Monitors (II.F.1.1) and the Sampling and Analysis of Plant Effluents (II.F.1.2). Niagara Mohawk believes that the intent of the Nuclear Regulatory Commission suggested Technical Specifications is covered within the scope of the Radiological Effluent Technical Specification submittal of February 1, 1984. Specifically, reporting the inoperability of the noble gas effluent monitor is addressed in Section 3.6.14b of that submittal. Additionally, implementation of our proposed Radiological Effluent Technical Specifications is sufficient to ensure that the capability exists to collect and analyze or measure representative samples of radioactive iodine and particulates in plant gaseous effluents during and following an accident.

Technical Specifications regarding Control Room Habitability (III.D.3.4) will be submitted under separate cover by September 30, 1984.

Accordingly, Niagara Mohawk Power Corporation hereby transmits three (3) originals and nineteen (19) copies of an application for amendment to Nine Mile Point Unit 1's Operating License DPR-63. Also enclosed are forty (40) copies of the proposed change to the Technical Specifications in Appendix A of the above mentioned license. Pursuant to 10CFR170.12 a one hundred fifty dollar (\$150.00) application fee is enclosed.

Pursuant to 10CFR50.91(b)(1) a copy of the attached license amendment application and the associated analysis regarding no significant hazards consideration is being provided to the appropriate state representative.

Sincerely,

NIAGARA MOHAWK POWER CORPORATION



T. E. Lemppes
Vice President
Nuclear Generation

TEL/BDW:bd
Attachment

cc: Mr. Jay Dunkleberger
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223

