

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8410100396 DOC. DATE: 84/10/03 NOTARIZED: YES DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410  
 AUTH. NAME AUTHOR AFFILIATION  
 LEMPGES, T.E. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards response to NRC 830329 ltr re SER Open Item 54 concerning performance testing of relief & safety valves. Encl info will be included in next FSAR amend.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 16  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: PNL 1cy FSAR'S & AMDTS ONLY. 05000410

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	HAUGHEY, M	01	1	1	
INTERNAL:	ADM/LFMB		1	0	ELD/HDS3		1	0	
	IE FILE		1	1	IE/DEPER/EPB	36	3	3	
	IE/DEPER/IRB	35	1	1	IE/DQASIP/QAB21		1	1	
	NRR ROE, M.L		1	1	NRR/DE/AEAB		1	0	
	NRR/DE/CEB	11	1	1	NRR/DE/EHEB		1	1	
	NRR/DE/EQB	13	2	2	NRR/DE/GB	28	2	2	
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1	
	NRR/DE/SAB	24	1	1	NRR/DE/SGEB	25	1	1	
	NRR/DHFS/HFEB	40	1	1	NRR/DHFS/LQB	32	1	1	
	NRR/DHFS/PSRB		1	1	NRR/DL/SSPB		1	0	
	NRR/DSI/AEB	26	1	1	NRR/DSI/ASB		1	1	
	NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1	
	NRR/DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	1	
	NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1	
	NRR/DSI/RSB	23	1	1	REG FILE	04	1	1	
	RGN1		3	3	RM/DDAMI/MIB		1	0	
EXTERNAL:	ACRS	41	6	6	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	1	1	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 56 ENCL 48

Faint header text at the top of the page, possibly including a title or reference number.

Second line of faint text, appearing to be a subtitle or a specific section header.

Third line of faint text, possibly a date or a location indicator.

Fourth line of faint text, likely a recipient or sender address.

Column 1	Column 2	Column 3	Column 4	Column 5	Column 6
1	2	3	4	5	6
7	8	9	10	11	12
13	14	15	16	17	18
19	20	21	22	23	24
25	26	27	28	29	30
31	32	33	34	35	36
37	38	39	40	41	42
43	44	45	46	47	48
49	50	51	52	53	54
55	56	57	58	59	60
61	62	63	64	65	66
67	68	69	70	71	72
73	74	75	76	77	78
79	80	81	82	83	84
85	86	87	88	89	90
91	92	93	94	95	96
97	98	99	100	101	102
103	104	105	106	107	108
109	110	111	112	113	114
115	116	117	118	119	120
121	122	123	124	125	126
127	128	129	130	131	132
133	134	135	136	137	138
139	140	141	142	143	144
145	146	147	148	149	150
151	152	153	154	155	156
157	158	159	160	161	162
163	164	165	166	167	168
169	170	171	172	173	174
175	176	177	178	179	180
181	182	183	184	185	186
187	188	189	190	191	192
193	194	195	196	197	198
199	200	201	202	203	204
205	206	207	208	209	210
211	212	213	214	215	216
217	218	219	220	221	222
223	224	225	226	227	228
229	230	231	232	233	234
235	236	237	238	239	240
241	242	243	244	245	246
247	248	249	250	251	252
253	254	255	256	257	258
259	260	261	262	263	264
265	266	267	268	269	270
271	272	273	274	275	276
277	278	279	280	281	282
283	284	285	286	287	288
289	290	291	292	293	294
295	296	297	298	299	300
301	302	303	304	305	306
307	308	309	310	311	312
313	314	315	316	317	318
319	320	321	322	323	324
325	326	327	328	329	330
331	332	333	334	335	336
337	338	339	340	341	342
343	344	345	346	347	348
349	350	351	352	353	354
355	356	357	358	359	360
361	362	363	364	365	366
367	368	369	370	371	372
373	374	375	376	377	378
379	380	381	382	383	384
385	386	387	388	389	390
391	392	393	394	395	396
397	398	399	400	401	402
403	404	405	406	407	408
409	410	411	412	413	414
415	416	417	418	419	420
421	422	423	424	425	426
427	428	429	430	431	432
433	434	435	436	437	438
439	440	441	442	443	444
445	446	447	448	449	450
451	452	453	454	455	456
457	458	459	460	461	462
463	464	465	466	467	468
469	470	471	472	473	474
475	476	477	478	479	480
481	482	483	484	485	486
487	488	489	490	491	492
493	494	495	496	497	498
499	500	501	502	503	504
505	506	507	508	509	510
511	512	513	514	515	516
517	518	519	520	521	522
523	524	525	526	527	528
529	530	531	532	533	534
535	536	537	538	539	540
541	542	543	544	545	546
547	548	549	550	551	552
553	554	555	556	557	558
559	560	561	562	563	564
565	566	567	568	569	570
571	572	573	574	575	576
577	578	579	580	581	582
583	584	585	586	587	588
589	590	591	592	593	594
595	596	597	598	599	600
601	602	603	604	605	606
607	608	609	610	611	612
613	614	615	616	617	618
619	620	621	622	623	624
625	626	627	628	629	630
631	632	633	634	635	636
637	638	639	640	641	642
643	644	645	646	647	648
649	650	651	652	653	654
655	656	657	658	659	660
661	662	663	664	665	666
667	668	669	670	671	672
673	674	675	676	677	678
679	680	681	682	683	684
685	686	687	688	689	690
691	692	693	694	695	696
697	698	699	700	701	702
703	704	705	706	707	708
709	710	711	712	713	714
715	716	717	718	719	720
721	722	723	724	725	726
727	728	729	730	731	732
733	734	735	736	737	738
739	740	741	742	743	744
745	746	747	748	749	750
751	752	753	754	755	756
757	758	759	760	761	762
763	764	765	766	767	768
769	770	771	772	773	774
775	776	777	778	779	780
781	782	783	784	785	786
787	788	789	790	791	792
793	794	795	796	797	798
799	800	801	802	803	804
805	806	807	808	809	810
811	812	813	814	815	816
817	818	819	820	821	822
823	824	825	826	827	828
829	830	831	832	833	834
835	836	837	838	839	840
841	842	843	844	845	846
847	848	849	850	851	852
853	854	855	856	857	858
859	860	861	862	863	864
865	866	867	868	869	870
871	872	873	874	875	876
877	878	879	880	881	882
883	884	885	886	887	888
889	890	891	892	893	894
895	896	897	898	899	900
901	902	903	904	905	906
907	908	909	910	911	912
913	914	915	916	917	918
919	920	921	922	923	924
925	926	927	928	929	930
931	932	933	934	935	936
937	938	939	940	941	942
943	944	945	946	947	948
949	950	951	952	953	954
955	956	957	958	959	960
961	962	963	964	965	966
967	968	969	970	971	972
973	974	975	976	977	978
979	980	981	982	983	984
985	986	987	988	989	990
991	992	993	994	995	996
997	998	999	1000	1001	1002

October 3, 1984  
(NMP2L 0185)

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Schwencer:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

Enclosed is information relating to Enclosure 12 to the Nuclear Regulatory Commission letter dated March 29, 1983. This is Safety Evaluation Report open item 54. This information was requested by your staff for use in evaluating the performance testing of relief and safety valves.

The enclosed information will be included in the next Final Safety Analysis Report Amendment.

Very truly yours,



T. E. Lempges  
Vice President  
Nuclear Generation

TEL/DS:ja  
Enclosure

cc: R. Gramm, NRC Resident Inspector

Project File (2)

8410100396 841003  
PDR ADOCK 05000410  
E PDR

Boal  
1/1



Small, illegible marks or characters in the top right corner.

Main body of the document containing several paragraphs of extremely faint and illegible text.

Faint text or markings at the bottom right of the page.

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Niagara Mohawk Power Corporation )  
(Nine Mile Point Unit 2) )

Docket No. 50-410

AFFIDAVIT

T. E. Lempges, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

T. E. Lempges

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 3 day of October, 1984.

Janis M. Macro  
Notary Public in and for  
Onondaga County, New York

My Commission expires:

JANIS M. MACRO

Notary Public in the State of New York  
Qualified in Onondaga County No. 4784555  
My Commission Expires March 30, 1985



## Nine Mile Point Unit 2 ESAR

## RESPONSE TO NRC ENCLOSURE 12

## QUESTION 1


The test program utilized a rams head discharge pipe configuration. Most plants utilize a tee quencher configuration at the end of the discharge line. Describe the discharge pipe configuration used at your plant and compare the anticipated loads on valve internals in the plant configuration to the measured loads in the test program. Discuss the impact of any differences in loads on valve operability.

## RESPONSE

Unit 2 utilizes a tee quencher at the end of the main steam SRV discharge line (SRVDL). The test program described in NEDE-24988-P used a rams head discharge device with test conditions simulating the shutdown cooling mode. The impact of the difference on valve operability is accounted for as follows:

Valve operability is affected by dynamic loads on valve internals. The dynamic loads are governed by (a) back pressure of the SRV and (b) flow through the SRV. Higher back pressures and flow will produce higher dynamic loads.

- (a) In the test program, the SRV inlet pressure was equal to 250 psig. The Unit 2 reactor pressure during shutdown cooling mode is approximately 135 psig. The maximum back pressure of the SRV is approximately 35 percent of the SRV inlet pressure; thus, the test program has qualified the SRV to work with back pressure of about two times that of Unit 2. This provides adequate margin to offset the difference in using a tee quencher.
- (b) The test program has qualified the SRV with a rams head discharge device. The tee quencher allowed less flow (257 lbm/sec) than the rams head (263 lbm/sec) because it has higher flow resistance. Thus, operability of the SRV for Unit 2 SRVDL with a tee quencher will also be qualified.





RESPONSE TO NRC ENCLOSURE 12


QUESTION 2

The test configuration utilized no spring hangers as pipe supports. Plant specific configurations do use spring hangers in conjunction with snubber and rigid supports. Describe the safety relief valve supports used at your plant and compare the anticipated loads on valve internals for the plant pipe supports to the measured loads in the test program. Describe the impact of any differences in loads on valve operability.

RESPONSE

Fourteen of 18 SRV discharge lines use no spring hangers between the SRV and first full anchor. The remaining four lines use spring hangers solely as deadweight supports and to limit deadweight stresses to less than 1,500 psi. Due to their low stiffness, spring hangers have an insignificant impact on the dynamic properties of the piping system and do not affect the operability of the valves. An adequate number of snubbers and rigid supports are provided to support piping for dynamic loads.

Measured stresses in the SRV discharge piping near the SRV outlet, from NEDE-24988-P, are given in Table 1. Computed stresses in Unit 2 SRV discharge piping near the SRV discharge outlet are given in Table 2. The computed stresses are consistently lower than the measured stresses, which are low. Therefore, it is expected that loads on Unit 2 SRVs will be lower than test loads. Hence, there is no impact on valve operability.



Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12


TABLE 1

MEASURED STRESSES FOR STEAM BLOWDOWN IN  
SRV DISCHARGE PIPING NEAR SRV OUTLET  
DIKKERS 8R10 SRV

<u>Strain Gage*</u>	<u>Stress (psi)**</u>
SG21	200
SG22	1,400
SG23	200
SG24	1,400

---

NOTES: \*Strain gages SG21 through SG24 are at the same location, but differ in orientation.  
\*\*Based on 10-in Sch. 80 (0.593 in-thick) pipe.



Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12


TABLE 2

COMPUTED STRESSES FOR STEAM BLOWDOWN  
IN SRV DISCHARGE PIPING NEAR SRV OUTLET

<u>Valve No.</u> <u>2MSS*PSV-</u>	<u>Calc. No.</u> <u>AX-</u>	<u>Node</u>	<u>Computed Stress</u> <u>(psi)**</u>
120	2A	205	564
121	2A	310	410
122	2A	410	397
123	2A	510	355
124	2B	204	340
125	2B	304	332
126	2B	404	386
127	2B	504	302
128	2B	604	303
129	2C	204	420
130	2C	304	491
131	2C	404	550
132	2C	504	308
133	2C	604	284
134	2D	212	699
135	2D	330	904
136	2D	577	952***
137	2D	721	903

---

NOTES: \*SRSS (SRV discharge fluid transient, SRV inertia (max)).  
 \*\*Based on 10-in Sch. 60 (0.5 in-thick) pipe.  
 \*\*\*Maximum computed stress of 952 psi is much lower than the measured stress of 1,400 psi shown in Table 1.



Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12

QUESTION 3

Report NEDE-24988-P did not identify any valve functional deficiencies or anomalies encountered during the test program. Describe the impact on valve safety function of any valve functional deficiencies or anomalies encountered during the program.

RESPONSE


No functional deficiencies or anomalies of the safety relief valves were experienced during the testing at Wyle Laboratories in compliance with the alternate shutdown cooling mode requirement. All of the valves subjected to test runs opened and closed without loss of pressure integrity or damage. Anomalies encountered during the test program were all due to failures of test facility instrumentation, equipment, data acquisition system, or deviation from the approved test procedure.

The test specification for each valve required six runs. Under the test procedure, any anomaly caused the test run to be judged invalid. All anomalies were reported in the test report. The Wyle Laboratories test log sheet for the Dijkers valve test is in Table 3.

Each Wyle test report for the respective valves identifies each test run performed, documents whether or not the test run is valid, and states the reason for considering the run invalid. No anomaly encountered during the required test program affects any valve's safety or operability function.

All valid test runs are identified in Table 2.2-1 or NEDE-24988-P. The data presented in Table 4.2-1 for each valve were obtained from the Table 2.2-1 test runs and were based on the following selection criteria:

1. Presenting the maximum representative loading information obtained from the steam run data.
2. Presenting the maximum representative water loading information obtained from the 15°F subcooled water test data.
3. Presenting the data on the only test run performed for the 50°F subcooled water test condition.






Nine Mile Point Unit 2 ESAR

RESPONSE TO NRC ENCLOSURE 12

TABLE 3

OPERABILITY TEST LOG - SRV DK-1

<u>Test No.</u>	<u>Media</u>	<u>Load Line Configuration</u>	<u>Date</u>	<u>Test Remarks</u>
101	Steam	1	03/03/81	Acceptable
102	Water	1	03/03/81	Acceptable
103	Steam	1	03/03/81	Acceptable
104	Water	1	03/04/81	Acceptable
105	Steam	1	03/04/81	Acceptable
106	Water	1	03/04/81	Acceptable



Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12

QUESTION 4


The purpose of the test program was to determine valve performance under conditions anticipated to be encountered in the plants. Describe the events and anticipated conditions at the plant for which the valves are required to operate and compare these plant conditions to the conditions in the test program. Describe the plant features assumed in the event evaluations used to scope the test program and compare them to plant features at your plant. For example, describe high level trips to prevent water from entering the steam lines under high pressure operating conditions as assumed in the test event and compare them to trips used at your plant.

RESPONSE

The purpose of the test program was to demonstrate that the safety relief valve (SRV) will open and reclose under all expected flow conditions. The expected valve operating conditions were determined from accidents and anticipated transients referenced in Regulatory Guide 1.70, Revision 2. Additional single failures were considered so that dynamic forces on SRVs would be maximized. By this approach, the BWR Owners' Group, in the enclosure to the September 17, 1980, letter from D. B. Waters to R. H. Vollmer, identified 13 events which may result in liquid or two-phase SRV inlet flow that would maximize the dynamic forces on the SRV. Among the 13 events, the alternate shutdown cooling mode was found to be the only expected event which will result in liquid flow at the valve inlet. Consequently, this event was simulated in the SRV test program. The conclusion and test results applicable to Unit 2 are discussed subsequently.

The SRV inlet conditions in the test program, as documented in NEDE-24988-P, are 15°F to 50°F subcooled liquid at 20 psig to 250 psig. For Unit 2, the inlet condition during shutdown cooling (Event 7) is approximately 35°F subcooling at a pressure of approximately 135 psig.


The 13 events and the plant-specific features that mitigate these events are summarized in Table 4. Of these 13 events, only 11 are applicable to the Unit 2 design. Two events, namely 3 and 11, are not applicable because Unit 2 does not have an HPCI system. For the 11 remaining events, the Unit 2 specific features, such as trip logic, power supplies, instrument line configuration, alarms, and



## Nine Mile Point Unit 2 FSAR

operator actions, have been compared to the base plant analysis presented in the BWR Owners' Group submittal dated September 17, 1980. For these events, Table 4 demonstrates that the Unit 2 specific features are included in the base plant analyses. Furthermore, the time available for operator action is expected to be longer in the Unit 2 plant than in the base plant analysis for each event where operator action is required.

As discussed previously, the BWR Owners' Group evaluated transients, including single active failures, that would maximize the dynamic forces on the SRVs. As a result of this evaluation, the alternate shutdown cooling mode is the only expected event involving liquid or two-phase flow. Consequently, this event was tested in the BWR SRV test program. The fluid and flow conditions tested in the BWR Owners' Group test program conservatively envelope the Unit 2 plant-specific fluid conditions expected for the alternate shutdown cooling mode of operation.




Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12

TABLE 4

EVENTS EVALUATED

Plant Features	No. 1 -	No. 2 -	No. 3 -	No. 4 -	No. 5 -	No. 6 -	No. 7 -	No. 8 -	No. 9 -	No. 10 -	No. 11 -	No. 12 -	No. 13 -
	FW Cont. Fail, L8 Trip Failure	Press. Reg. Fail.	HPCI, HPCI L8 Trip Failure	Tran- sient HPCI, RCIC L8 Trip Failure	Tran- sient RCIC, RCIC L8 Trip Failure	Tran- sient HPCS, HPCS L8 Trip Failure	Tran- sient ECIC, ECIC Hd. Spr.	Alt. - Shut- down Cooling, Shut- down Suction Un- avail- able	MSL Brk OSC	SBA, RCIC, RCIC L8 Trip Failure	SBA, HPCS, HPCS L8 Trip Failure	SBA, HPCI, HPCI L8 Trip Failure	SBA, Depress. & ECCS Over., Operator Error
High water Level 7 alarm	I/S		I/NA	I/S	I/S				I/S	I/S	I/NA	I/S	I/S
High drywell pressure alarm													
FW Level 8 trip	I/S	I/S											
RCIC Level 8 trip			I/NA	I/S	I/S				I/S	I/S	I/NA		I/S
HPCS Level 8 trip				I/S	I/S				I/S	I/S			I/S
HPCI Level 8 trip			I/NA	I/NA					I/NA		I/NA		I/NA
HPCI/S and RCIC initiation on low water level	I/S	I/S	I/NA	I/S	I/S	I/S		I/S	I/S				I/S
HPCI/S initiation on high drywell pressure			I/NA	I/NA					I/S	I/S	I/NA	I/S	I/S
RCIC initiation on high drywell pressure													I/NA
Low-pressure ECCS initiation on high drywell pressure									(2)	(2)	(2)	I/S	I/S
Low-pressure initiation on low water level													I/S






Nine Mile Point Unit 2 FSAR

TABLE 4  
EVENTS EVALUATED

Plant Features	No. 1 -	No. 2 -	No. 3 -	No. 4 -	No. 5 -	No. 6 -	No. 7 -	No. 8 -	No. 9 -	No. 10 -	No. 11 -	No. 12 -	No. 13 -
	FW Cont. Fail, PW L8 Trip Failure	Press. Reg. Fail.	HPCI, HPCI L8 Trip Failure	Tran- sient BCIC, RCIC L8 Trip Failure	Tran- sient HPCS, HPCS L8 Trip Failure	Tran- sient RCIC Hd. Spr.	Alt. Shut- down Cooling, Shut- down Suction Un- avail- able	MSL Brk OSC	RCIC L8 Trip Failure	SBA, HPCS, HPCS L8 Trip Failure	SBA, HPCI, HPCI L8 Trip Failure	SBA, Depress. & ECCS Over., Operator Error	LBA, ECCS Overf Brk Isol
FW pumps trip on low suction pressure or high vibration	I/S												
HPCS trip on high backpressure			X/NA								X/NA		
RCIC trip on high backpressure				I/S					I/S				
Turbine trip on vessel high level	I/S	I/S											
MSIV closure on low turbine inlet pressure	I/S	I/S						I/S					
MSIV closure on high steam flow		I/S						I/S					
MSIV closure on high steam tunnel temperature								I/S					
MSIV closure on high radiation								I/S					
Reactor scram on turbine trip	I/S	I/NA	(3)										
Reactor scram on neutron flux monitor		I/NA	(3)										
Reactor scram on MSIV closure		I/S											
Reactor scram on high radiation								I/S	(1)				
Reactor scram on high drywell pressure								I/S	I/S	I/NA	I/S	I/S	




Nine Mile Point Unit 2 PSAR

TABLE 4  
EVENTS EVALUATED

	No. 1 - FW Cont. Fail, PW L8 Trip Failure	No. 2 - Press. Reg. Fail.	No. 3 - HPCI, HPCI L8 Trip Failure	No. 4 - RCIC, RCIC L8 Trip Failure	No. 5 - HPCS, HPCS L8 Trip Failure	No. 6 - Tran- sient RCIC Hd. Spr.	No. 7 - Alt. Shut- down Cooling, Shut- down Suction Un- avail- able	No. 8 - MSL Brk OSC	No. 9 - SBA, RCIC L8 Trip Failure	No. 10 - SBA, HPCS L8 Trip Failure	No. 11 - SBA, HPCI, HPCI L8 Trip Failure	No. 12 - SBA, Depress. & ECCS Over., Operator Error	No. 13 - LBA, ECCS Overf Brk Isol
Plant Features													
Reactor scram on low water level													X/S
Reactor isolation on low water level													X/S

KEY: X - Feature considered in base case analysis.  
S - Feature in plant-specific design.  
NA - Not applicable.

NOTES: (1)As a consequence of MSIV closure.  
(2)High vessel pressure prevents initiation.  
(3)Scram bypassed below 30 percent power.



Nine Mile Point Unit 2 FSAR

RESPONSE TO NRC ENCLOSURE 12

QUESTION 5

The valves are likely to be extensively cycled in a controlled depressurization mode in a plant-specific application. Was this mode simulated in the test program? What is the effect of this valve cycling on valve performance and probability of the valve to fail open or to fail closed?

RESPONSE

The BWR safety relief valve (SRV) operability test program was designed to simulate the alternate shutdown cooling mode, which is the only expected liquid discharge event for Unit 2. The sequence of events leading to the alternate shutdown cooling mode follows.

Following normal reactor shutdown, the reactor operator depressurizes the reactor vessel by opening the turbine bypass valves and removing heat through the main condenser. If the main condenser is unavailable, the operator could depressurize the reactor vessel by using the SRVs to discharge steam to the suppression pool. If SRV operation is required, the operator cycles the valves in order to ensure that the cooldown rate is maintained within the technical specification limit of 100°F per hr. When the vessel is depressurized, the operator initiates normal shutdown cooling by use of the RHR system. If that system is unavailable because the valve on the RHR shutdown cooling suction line fails to open, the operator initiates the alternate shutdown cooling mode.

For alternate shutdown cooling, the operator opens the SRVs and initiates an RHR pump utilizing the suppression pool as the suction source. The reactor vessel is filled such that water is allowed to flow into the main steam lines, out of the SRV, and back to the suppression pool. Cooling of the system is provided by use of an RHR heat exchanger.


In order to ensure continuous long-term heat removal, the SRV is kept open and no cycling of the valve is performed. To control the reactor vessel cooldown rate, the operator is instructed to control the flow rate into the vessel. Consequently, no cycling of the SRV is required in the alternate shutdown cooling mode, and no cycling of the SRV was performed in the generic BWR SRV operability test program.



100

Nine Mile Point Unit 2 FSAR

The ability of the Unit 2 SRV to withstand extensive cycling for steam discharge conditions has been confirmed during steam discharge qualification testing of the valve by the valve vendor. Based on the SRV qualification testing, cycling of the valves in a controlled depressurization mode for steam discharge conditions will not affect valve performance adversely. Furthermore, the probability of the valve to fail open or closed is extremely low.





RESPONSE TO NRC ENCLOSURE 12

QUESTION 6.

Describe how the values of the valve  $C_v$ 's in report NEDE-24988-P will be used at your plant. Show that the methodology used in the test program to determine the valve C will be consistent with the application at your plant.

RESPONSE

The flow coefficient,  $C_v$ , for the Dikkers safety relief valve (SRV) was determined in the generic SRV test program (NEDE-24988-P). The average flow coefficient calculated from test results for the Dikkers valve is reported in Table 5.2-1 of NEDE-24988-P. This test value has been used by NMPC to confirm that the liquid discharge flow capacity of the SRVs will be sufficient to remove core decay heat in the alternate shutdown cooling mode. The  $C_v$  value determined in the SRV test demonstrates that the SRVs are capable of returning flow to the suppression pool.

If the alternate shutdown cooling mode is required, the operator is to ensure that adequate core cooling is provided by monitoring the following parameters: RHR flow rate and reactor vessel pressure and temperature.

The flow coefficient for the Dikkers valve reported in NEDE-24988-P was determined from the SRV flow rate when the valve inlet was pressurized to approximately 250 psig. The valve flow rate was measured with the supply line flow venturi upstream of the steam chest. The  $C_v$  for the valve was calculated using the nominal measured pressure differential between the valve inlet (steam chest) and 3 ft downstream of the valve and the corresponding measured flowrate. Furthermore, test conditions and configurations were representative of Unit 2 conditions for the alternate shutdown cooling mode, e.g., pressure upstream of the valve, fluid temperature, friction losses, and liquid flowrate. Therefore, the reported  $C_v$  values are appropriate for application to Unit 2.

