

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8410110020 DOC. DATE: 84/10/05 NOTARIZED: YES DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410
 AUTH. NAME: AUTHORITY AFFILIATION
 LEMPGES, T.E. Niagara Mohawk Power Corp.
 RECIPIENT NAME: RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards revised response re 100% volumetric inservice exam
 of all pipe welds in break exclusion areas, per D. Turrell
 840921 telcon request. Subj addressed in FSAR Question
 210.19.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: PNL 1cy FSAR'S & AMDTS ONLY.

05000410

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME:		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	HAUGHEY, M	01	1	1	
INTERNAL:	ADM/LFMB		1	0	ELD/HDS3		1	0	
	IE FILE.		1	1	IE/DEPER/EPB	36	3	3	
	IE/DEPER/IRB	35	1	1	IE/DQASIP/QAB21		1	1	
	NRR ROE, M.L		1	1	NRR/DE/AEAB		1	0	
	NRR/DE/CEB	11	1	1	NRR/DE/EHEB		1	1	
	NRR/DE/eqb	13	2	2	NRR/DE/GB	28	2	2	
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1	
	NRR/DE/SAB	24	1	1	NRR/DE/Sgeb	25	1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1	
	NRR/DHFS/PSRB		1	1	NRR/DL/SSPB		1	0	
	NRR/DSI/AEB	26	1	1	NRR/DSI/ASB		1	1	
	NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1	
	NRR/DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	1	
	NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1	
	NRR/DSI/RSB	23	1	1	REG FILE	04	1	1	
	RGN1		3	3	RM/DDAMI/MIB		1	0	
EXTERNAL:	ACRS	41	6	6	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	1	1	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	
NOTES:			1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 56 ENCL 48

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for the proper management of the organization's finances and for ensuring compliance with applicable laws and regulations.

2. The second part of the document outlines the specific procedures that must be followed when recording transactions. This includes the requirement to use the correct accounting entries and to ensure that all supporting documentation is properly maintained and filed.

3. The third part of the document discusses the role of the accounting department in providing accurate and timely financial information to management. It highlights the importance of regular reporting and the need to identify and address any discrepancies or errors as soon as they are discovered.

4. The fourth part of the document addresses the issue of internal controls and the need to implement effective measures to prevent fraud and other types of financial misstatements. It stresses the importance of a strong internal control system and the role of the accounting department in monitoring and evaluating its effectiveness.

5. The fifth part of the document discusses the importance of maintaining accurate records of all assets and liabilities. It emphasizes the need for regular physical counts and reconciliations to ensure that the recorded values accurately reflect the actual values of the organization's resources.

6. The sixth part of the document addresses the issue of budgeting and the need to establish realistic and achievable financial goals. It highlights the importance of regular budget reviews and the need to adjust the budget as necessary to reflect changes in the organization's operations and market conditions.

7. The seventh part of the document discusses the importance of maintaining accurate records of all income and expenses. It emphasizes the need for proper documentation and the importance of ensuring that all income is properly reported and all expenses are properly deducted for tax purposes.

8. The eighth part of the document addresses the issue of financial reporting and the need to provide clear and concise information to stakeholders. It highlights the importance of following established reporting standards and the need to ensure that all information is accurate and reliable.

9. The ninth part of the document discusses the importance of maintaining accurate records of all financial transactions. It emphasizes the need for proper documentation and the importance of ensuring that all transactions are properly recorded and classified.

10. The tenth part of the document addresses the issue of financial management and the need to ensure that the organization's resources are used efficiently and effectively. It highlights the importance of regular financial reviews and the need to identify and address any areas of inefficiency or waste.

October 5, 1984
(NMP2L 0187)

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Schwencer:


Re: Nine Mile Point Unit 2
Docket No. 50-410

Enclosed is a revised response requested by Mr. D. Turrell on the 100 percent volumetric in-service examination of all pipe welds in break exclusion areas. This subject is addressed in Final Safety Analysis Report question 210.19.

This information was requested as a result of a conference call on September 21, 1984 between D. Hill, Niagara Mohawk and D. Turrell and M. Haughey, of the Nuclear Regulatory Commission and Stone & Webster representatives.

This enclosed information will be included in the next Final Safety Analysis Report Amendment.

Very truly yours,



T. E. Lempges
Vice President
Nuclear Generation

TEL/DS:ja
Enclosure
xc: Project File (2)

R. Gramm, NRC Resident Inspector

8410110020 841005
PDR ADDCK 05000410
Q PDR

13001
/11

THE STATE OF TEXAS,
COUNTY OF DALLAS.

Know all men by these presents, that _____ of the County of _____ State of _____ do hereby certify that _____ of the County of _____ State of _____ is the true and correct owner of the _____ described in the _____ of _____ of _____ County, State of _____ and that the same is subject to a mortgage in favor of _____ of the County of _____ State of _____ in the amount of _____ Dollars (\$ _____) and that the same is being sold by _____ of the County of _____ State of _____ in accordance with the terms of the said mortgage.

Witness my hand and seal of office this _____ day of _____ 19____.

County Clerk

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

T. E. Lempges, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

T. E. Lempges

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 5th day of October, 1984.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires March 30, 1985

My Commission Expires March 30, 1967
Printed in Ontario, Canada
Hotel Prince in the State of New York
CHRISTINE JUSTIN


Nine Mile Point Unit 2 FSAR

QUESTION F210.19 (3.6.2)

Provide assurance that 100% volumetric inservice examination of all pipe welds in the break exclusion area will be conducted during each inspection interval as defined in IWA-2400, ASME Code, Section XI.


RESPONSE,

A 100 percent volumetric preservice and inservice inspection of high-energy fluid system piping welds within the break exclusion area, will be conducted during each inspection interval as defined in IWA 2400, ASME Code Section XI.



Nine Mile Point Unit 2 FSAR

- b. The following design stress limits are not exceeded for Safety Class 2 piping:
- (1) The maximum stress ranges do not exceed $0.8 (1.2 S_h + S_a)$, as calculated by Equations (9) and (10) in Paragraph NC-3652, ASME Code Section III, considering normal and upset plant conditions (i.e., sustained loads, occasional loads, and thermal expansion) and an OBE event.
 - (2) The maximum stresses do not exceed $1.8 S$, as calculated by Equation (9) in Paragraph NC-3652 under the loadings resulting from a postulated piping failure of fluid system piping beyond these portions of piping.
- c. Welded attachments for pipe supports or other purposes, to these portions of piping are avoided, except where detailed stress analysis demonstrates compliance with the limits discussed in Items 2a and 2b.
- d. The number of circumferential and longitudinal piping welds and branch connections is minimized.
- e. The length of these portions of piping is reduced to the minimum length practicable.
- f. The design of pipe anchors or restraints (e.g., connections to containment penetrations and pipe whip restraints) does not require welding directly to the outer surface of the piping (e.g., flued integrally forged pipe fittings are used), except where such welds are capable of 100-percent volumetric inservice inspection. This criterion is also applicable to the portion of piping between the containment and the inside containment isolation valves.
- g. For these portions of high energy fluid system piping, preservice and subsequent inservice examinations are performed in accordance with the requirements specified in ASME Section XI. 100-Percent volumetric examination of circumferential and longitudinal pipe welds is required on the portions of high energy fluid system piping in the break exclusion region. Details of containment penetration, identification of pipe welds, and access for inservice inspection points of fixity and discontinuity are provided in Section 3.8.2.



Nine Mile Point Unit 2 FSAR

- h. Regardless of the fact that all conditions above have been met, a crack is postulated in the main steam or feedwater piping in the main steam tunnel. The crack in the pipe, equal in area to a single-ended pipe rupture, is considered a singular event. Pipe whip and jet impingement are not considered, and a single active failure is not taken as a concurrent event.
3. Balance of Piping Outside the Containment
- a. Breaks in ASME Section III, Safety Class 2 and 3 piping and in nonnuclear class piping that is seismically analyzed and supported are postulated at the following locations in each piping and branch run (except those portions of fluid system piping identified in Items 1 and 2):

 - (1) At terminal ends of the pressurized portions of the runs.
 - (2) At intermediate locations selected by either of the following criteria:

 - (a) At each pipe fitting (e.g., elbow, tee, cross, and nonstandard fitting), welded attachment, and valve, or, if the run contains no fittings, at one location at each extreme of the run within the protective structure (a terminal end, if located within a protective structure, may substitute for one intermediate break).

