

October 19, 1984  
(NMP2L 0207)

Mr. R. W. Starostecki, Director  
U. S. Nuclear Regulatory Commission  
Region I  
Division of Project and Resident Programs  
631 Park Avenue  
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2  
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim report, in accordance with 10CFR50.55(e), for the problem concerning the qualification of containment purge system valves for seismic and hydrodynamic loadings. This problem was reported via tel-con to S. Collins of your staff on September 19, 1984.

Very truly yours,

*C. V. Mangar*  
C. V. Mangar  
Vice President  
Nuclear Engineering and Licensing


CVM/GG/pbd

xc: Director of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

R. A. Gramm, NRC Resident Inspector

Project File (2)

8411190073 841019  
PDR ADDCK 05000410  
S PDR



NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT - UNIT 2  
DOCKET NO. 50-410

Interim Report for a Problem  
Concerning CPS Isolation Valve Qualification  
(55(e)-84-40)

Description of the Problem

The problem pertains to containment purge system safety related valves. An analysis of this system indicates that the calculated accelerations which these valves may encounter when subjected to dynamic loads could exceed those specified in the purchase specifications. These valves are being purchased from Posi-Seal International, Incorporated. The matter is still under investigation and a final report will be submitted by August 1, 1985.

