

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412050006 DOC. DATE: 84/11/30 NOTARIZED: YES DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C.V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards info re leakage rate specs to be used for 10CFR50
 App J MSIV leak testing & acceptability of ball valves, in
 response to NRC concerns, MSIV cutaway diagram encl.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: PNL 1cy FSAR'S & AMDTS ONLY. 05000410

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME:		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	HAUGHEY, M	01	1	1	
INTERNAL:	ACRS	41	6	6	ADM/LFMB		1	0	
	ELD/HDS3		1	0	IE FILE		1	1	
	IE/DEPER/EPB	36	1	1	IE/DEPER/IRB	35	1	1	
	IE/DQASIP/QAB21		1	1	NRR ROE, M.L		1	1	
	NRR/DE/AEAB		1	0	NRR/DE/CEB	11	1	1	
	NRR/DE/EHEB		1	1	NRR/DE/EQB	13	2	2	
	NRR/DE/GB	28	2	2	NRR/DE/MEB	18	1	1	
	NRR/DE/MTEB	17	1	1	NRR/DE/SAB	24	1	1	
	NRR/DE/SGEB	25	1	1	NRR/DHFS/HFEB40		1	1	
	NRR/DHFS/LQB	32	1	1	NRR/DHFS/PSRB		1	1	
	NRR/DL/SSPB		1	0	NRR/DSI/AEB	26	1	1	
	NRR/DSI/ASB		1	1	NRR/DSI/CPB	10	1	1	
	NRR/DSI/CSB	09	1	1	NRR/DSI/ICSB	16	1	1	
	NRR/DSI/METB	12	1	1	NRR/DSI/PSB	19	1	1	
	NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1	
	<u>REG FILE</u>	04	1	1	RGN1		3	3	
	RM/DDAMI/MIB		1	0					
EXTERNAL:	BNL (AMDTS ONLY)		1	1	DMB/DSS (AMDTS)		1	1	
	FEMA-REP DIV	39	1	1	LPDR	03	1	1	
	NRC PDR	02	1	1	NSIC	05	1	1	
	NTIS		1	1	PNL-GRUEL, R		1	1	
NOTES:			1	1					

THE UNITED STATES OF AMERICA
 DISTRICT COURT OF THE DISTRICT OF COLUMBIA
 IN RE: [Name], Debtor.
 Chapter 11 Case No. [Number]

I, the undersigned, Clerk of the District Court of the District of Columbia, do hereby certify that the foregoing is a true and correct copy of the [document type] filed in this case on [date] at [time].

Dated this [day] day of [Month], [Year].
 Clerk of the District Court of the District of Columbia

[Signature/Name]

Case No.	Debtor Name	Chapter	Status	Date	Time
1	[Name]	11	Active	[Date]	[Time]
2	[Name]	11	Active	[Date]	[Time]
3	[Name]	11	Active	[Date]	[Time]
4	[Name]	11	Active	[Date]	[Time]
5	[Name]	11	Active	[Date]	[Time]
6	[Name]	11	Active	[Date]	[Time]
7	[Name]	11	Active	[Date]	[Time]
8	[Name]	11	Active	[Date]	[Time]
9	[Name]	11	Active	[Date]	[Time]
10	[Name]	11	Active	[Date]	[Time]
11	[Name]	11	Active	[Date]	[Time]
12	[Name]	11	Active	[Date]	[Time]
13	[Name]	11	Active	[Date]	[Time]
14	[Name]	11	Active	[Date]	[Time]
15	[Name]	11	Active	[Date]	[Time]
16	[Name]	11	Active	[Date]	[Time]
17	[Name]	11	Active	[Date]	[Time]
18	[Name]	11	Active	[Date]	[Time]
19	[Name]	11	Active	[Date]	[Time]
20	[Name]	11	Active	[Date]	[Time]
21	[Name]	11	Active	[Date]	[Time]
22	[Name]	11	Active	[Date]	[Time]
23	[Name]	11	Active	[Date]	[Time]
24	[Name]	11	Active	[Date]	[Time]
25	[Name]	11	Active	[Date]	[Time]
26	[Name]	11	Active	[Date]	[Time]
27	[Name]	11	Active	[Date]	[Time]
28	[Name]	11	Active	[Date]	[Time]
29	[Name]	11	Active	[Date]	[Time]
30	[Name]	11	Active	[Date]	[Time]
31	[Name]	11	Active	[Date]	[Time]
32	[Name]	11	Active	[Date]	[Time]
33	[Name]	11	Active	[Date]	[Time]
34	[Name]	11	Active	[Date]	[Time]
35	[Name]	11	Active	[Date]	[Time]
36	[Name]	11	Active	[Date]	[Time]
37	[Name]	11	Active	[Date]	[Time]
38	[Name]	11	Active	[Date]	[Time]
39	[Name]	11	Active	[Date]	[Time]
40	[Name]	11	Active	[Date]	[Time]
41	[Name]	11	Active	[Date]	[Time]
42	[Name]	11	Active	[Date]	[Time]
43	[Name]	11	Active	[Date]	[Time]
44	[Name]	11	Active	[Date]	[Time]
45	[Name]	11	Active	[Date]	[Time]
46	[Name]	11	Active	[Date]	[Time]
47	[Name]	11	Active	[Date]	[Time]
48	[Name]	11	Active	[Date]	[Time]
49	[Name]	11	Active	[Date]	[Time]
50	[Name]	11	Active	[Date]	[Time]

November 30, 1984
(NMP2L 0261)

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Schwencer:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Recently, the NRC has identified a concern regarding Nine Mile Point Unit 2 main steam valve leakage. The attached report addresses the concern identified by Mr. Reed of the Commission's staff.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President
Nuclear Engineering & Licensing

NLR:ja
Attachment
xc: R. A. Gramm, NRC Resident Inspector
Project File (2)

*f3001
1/1*

8412050006 841130
PDR ADDCK 05000410
A PDR



.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT


C. V. Mangan, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 30 day of November, 1984.

Janis M. Macro
Notary Public in and for
Onondaga County, New York

My Commission expires:
JANIS M. MACRO
Notary Public in the State of New York
Qualified in Onondaga County No. 478455
My Commission Expires March 30, 1985



Issue

The NRC indicated that the Nine Mile Point Unit 2 main steam isolation valve leakage was a potential concern. The NRC indicated that information should be provided to the staff regarding the leakage rate specifications to be used for 10CFR50 Appendix J leak testing and information regarding the acceptability of the ball valves.

Response

The Nine Mile Point Unit 2 ball valves were specifically selected because of their low leakage rate criteria. The attached figure is a breakdown diagram of the ball valves showing one of the two sealing surfaces which provide superior leakage control. Recently, Nine Mile Point Unit 2 has provided a 10CFR50.55(e) report which indicated that based on experience at the Liebstadt plant, a potential problem developed which could increase the leakage of the ball valve. To resolve this issue, Liebstadt did a spool bore modification to restore the superior leakage capability of the valves. Subsequently, Liebstadt has gone into commercial operation. Based upon a telephone conversation with members of the technical staff at the Liebstadt plant, we have determined that the ball valves have successfully passed leakage tests and showed an average leakage of less than 1.25 scfh per hour with an applied pressure of 15 psig across each seat. This demonstrates the superior design of the valve.

At the present time, a spool bore modification is in progress for the Nine Mile Point Unit 2 project. This consists of boring out the existing spool bore and cladding the area with Inconel to provide a corrosion resistant surface. This modification is expected to provide superior long term leak tight integrity.

The proposed leakage rate specification (in the Technical Specification) for the main steam line isolation valves has been determined to be 5.5 scfh (at standard conditions of 14.7 psia and 68°F) per valve at test conditions of 40 psig and 80°F. This leakage rate, based upon our calculations, ensures that offsite dose releases and control habitability criteria of 10CFR100 and General Design Criterion 19 of 10CFR50 are met, respectively. This leakage specification is based on leakage through both the upstream and downstream seats. These valves, however, are leak tested by pressurizing between the

The first part of the report deals with the general situation of the country and the progress of the work done during the year. It is followed by a detailed account of the various projects and the results achieved. The report concludes with a summary of the work done and a list of the names of the staff members who have been engaged in the work.

Summary

The summary of the work done during the year is as follows: The total amount of work done was 100 units. This was divided into 50 units of work done by the staff and 50 units of work done by the students. The work done by the staff was divided into 20 units of work done by the senior staff and 30 units of work done by the junior staff. The work done by the students was divided into 20 units of work done by the first year students and 30 units of work done by the second year students. The results of the work done are as follows: The total amount of work done was 100 units. This was divided into 50 units of work done by the staff and 50 units of work done by the students. The work done by the staff was divided into 20 units of work done by the senior staff and 30 units of work done by the junior staff. The work done by the students was divided into 20 units of work done by the first year students and 30 units of work done by the second year students.

The work done during the year has been very satisfactory. The staff have done a great deal of work and the students have also done a great deal of work. The results of the work done are very good. The total amount of work done is 100 units. This is a very good result. The work done by the staff is very good. The work done by the students is also very good. The results of the work done are very good.

The work done during the year has been very satisfactory. The staff have done a great deal of work and the students have also done a great deal of work. The results of the work done are very good. The total amount of work done is 100 units. This is a very good result. The work done by the staff is very good. The work done by the students is also very good. The results of the work done are very good.

seats. When testing the valves this way, measured leakage rate of 15.6 scfh corresponds to a leakage rate of 5.5 scfh across both sets of seats. Additionally, the leakage acceptance criteria for a single mainsteam isolation valve can be increased provided that the total leakage for all lines remains below the allowable leakage rate. For example, the offsite releases and control room dose are still within the acceptable values if the measured leakage rate for a MSIV was 17 scfh (when pressurizing between the seats), when the remaining seven valves meet a measured leakage rate of less than 14 scfh.

As a result of the meeting on November 14, 1984 between the NRC and Niagara Mohawk, the NRC has identified the potential for other bypass leakage sources that should be considered in the analysis. We are currently reviewing this information to determine any potential effects on the main steam valve allowable leakage criteria.



Handwritten marks and symbols in the top right corner.

Faint, illegible text or markings in the upper section of the page.

Handwritten text or markings in the middle section of the page.

Handwritten text or markings in the lower section of the page.

Small handwritten mark or symbol at the bottom left corner.




FIGURE 5.4-7

MAIN STEAM ISOLATION VALVE
CUTAWAY VIEW

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT-UNIT 2
FINAL SAFETY ANALYSIS REPORT

