

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412110099      DOC. DATE: 84/12/05      NOTARIZED: NO      DOCKET #  
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe      05000220  
 AUTH. NAME      AUTHOR AFFILIATION  
 MANGAN, C.V.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 VASSALLO, D.B.      Operating Reactors Branch 2

SUBJECT: Responds to 841026 Generic Ltr 84-23 requesting plans for implementing two improvements to water level instrumentation at facility. Vertical leg drop & analog level trip units discussed.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: OR Submittal: General Distribution

NOTES: 05000220  
 OL: 08/22/69

	RECIPIENT			COPIES			RECIPIENT			COPIES		
	ID	CODE/NAME		LTTR	ENCL		ID	CODE/NAME		LTTR	ENCL	
	NRR	ORB2 BC	01	7	7							
INTERNAL:	ACRS		09	6	6	ADM/LFMB			1	0		
	ELD/HDS3			1	0	NRR/DE/MTEB			1	1		
	NRR/DL DIR			1	1	NRR/DL/ORAB			1	0		
	NRR/DSI/METB			1	1	NRR/DSI/RAB			1	1		
	<u>REG FILE</u>		04	1	1	RGN1			1	1		
EXTERNAL:	LPDR		03	1	1	NRC PDR	02		1	1		
	NSIC		05	1	1	NTIS			1	1		

The first part of the report deals with the general situation in the country. It is noted that the economy is showing signs of recovery, but there are still many problems to be solved. The government is working hard to improve the situation and to provide for the needs of the people.

In the second part, the report discusses the progress of the various departments. It is noted that the Ministry of Education has made great progress in improving the quality of the schools. The Ministry of Health has also done a great deal of work to improve the health of the people.

The third part of the report deals with the financial situation. It is noted that the government has managed to keep the budget in balance and to reduce the national debt. This is a great achievement and shows that the government is committed to sound financial management.

Finally, the report discusses the future prospects of the country. It is noted that there are many challenges ahead, but if the government continues to work hard and to provide for the needs of the people, a bright future is ahead.

CONCLUSION

In conclusion, the report shows that the country has made significant progress in many areas. The economy is recovering, the government is working hard to improve the situation, and the people are showing signs of hope. There are still many challenges ahead, but if the government continues to work hard and to provide for the needs of the people, a bright future is ahead.

The report also notes that there are many areas where more work needs to be done. The government should continue to focus on improving the quality of education, the health of the people, and the financial situation. It should also continue to work on reducing the national debt and improving the overall standard of living.

Finally, the report emphasizes the importance of the people's support. The government can only succeed if the people are united behind it. It is the duty of every citizen to support the government and to work together to build a better future for the country.

December 5, 1984

Director of Nuclear Reactor Regulation  
Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
.....DPR-63.....

Dear Mr. Vassallo:

Your Generic Letter 84-23, dated October 26, 1984, requested our plans for implementing two improvements to the water level instrumentation for Nine Mile Point Unit 1. It also described a third improvement to protect against reference leg breaks, which your letter indicated was being evaluated for possible future action. Our responses for the two requested items are attached.

Sincerely,

NIAGARA MOHAWK POWER CORPORATION

*for C. V. Mangan*  
C. V. Mangan  
Vice President  
Nuclear Engineering and Licensing

JLB/bd  
Attachment

8412110099 841205  
PDR ADOCK 05000220  
P PDR

*Hool*  
*1/1*

Page 2 of 2

Director of the Bureau of  
Education, U.S. Department of  
Education, Washington, D.C.  
20540-0001

To: The Honorable  
[Name]  
[Address]  
[City, State, ZIP]

Date: [Date]

The enclosed letterhead is for your information. It contains information regarding the status of your application for a position in the Bureau of Education. The enclosed letterhead is for your information. It contains information regarding the status of your application for a position in the Bureau of Education. The enclosed letterhead is for your information. It contains information regarding the status of your application for a position in the Bureau of Education.

Sincerely,  
[Signature]

Enclosure

[Name]

[Title]

U.S. Department of Education

100-100000000

## 1. Vertical Leg Drop

### a. NRC Description:

Improvements to plant(s) that will reduce level indication errors caused by high drywell temperature. These improvements include prevention of reference leg overheating or reduction of the vertical drops in the drywell. (Vertical drop should be measured from the condensation pot to the drywell exit point. Maximum drop would allow an indicated level at the bottom of the normal operating range when actual level is just above lower tap for worst flashing condition.) Those plants for which the vertical drop in the drywell has already been minimized will not have to make additional changes for the drywell heating effect.

### b. Niagara Mohawk Response:

Niagara Mohawk has implemented several improvements to reduce potential reactor water level indication errors caused by high drywell temperature conditions. These include 1) adjustment of the triple low reactor water level setpoint for automatic initiation of the Automatic Depressurization System and 2) installation of a fuel-zone reactor water level monitoring system with temperature correction for the vessel level reference leg.

#### ° Adjustment of Reactor Water Level Setpoints:

General Electric identified potential reactor water level indication errors resulting from high drywell temperature in their Service Information Letter 299. It further contained recommendations for evaluating the effect on level as a result of elevated temperatures based on vertical lengths of piping in the drywell. Our evaluation, done in accordance with the guidance provided in the Service Information Letter, concluded that there was a potential error associated with the reactor triple low water level setpoint. At that time, this setpoint was adjusted in a conservative direction reflecting the maximum potential error, and a proposed Technical Specification incorporating the new setpoint was submitted to the Nuclear Regulatory Commission. This amendment request was subsequently approved.

MEMORANDUM

TO: [Illegible] FROM: [Illegible] SUBJECT: [Illegible]

DISCUSSION

[Illegible text]

CONCLUSIONS

[Illegible text]

A more detailed description of the analysis that provided the basis for this change in reactor triple low water level setpoint and the reasons why the reactor low and low low water level setpoints need not be changed, was also submitted in our letter of November 26, 1984.

◦ Fuel Zone Water Level Instrumentation:

The lowest point at which the reactor water level is normally monitored is the vessel tap for the triple low water level instrumentation discussed above. This tap location corresponds to approximately 4 feet 8 inches above the top of active fuel. In order to monitor reactor water to lower levels an additional monitoring system was installed. This system is described in our letter of February 9, 1981. Under appropriate conditions, this system enables reactor water level to be monitored over a range from below the reactor core to the reactor vessel main steam line penetrations. The design of the system incorporates temperature sensing elements of the vessel level reference legs in the drywell for accurate determinations of indicated reactor water level. The modifications and compensating actions are being incorporated into our Emergency Operating Procedures, which are currently being prepared. Thus, the effects of potential errors in the reactor water level indication from elevated drywell temperatures will be minimized.

◦ Additional Improvement Program:

Nevertheless, Niagara Mohawk will initiate a program to determine the need to further improve the reactor water level instrumentation in a more fundamental manner based on the information reported in S. Levy, Inc. report, SLI-8211. The first phase of the program will consider worst case flashing conditions, its effects during upset and emergency conditions of concern, and the possible need for equipment changes. The second phase of the program will be carried out with a walkdown of the existing equipment arrangements and an in-situ review of possible needed changes inside the containment, including containment penetrations. This second phase will be done during the next planned refueling outage in the spring of 1986. This is important since any such potential changes would need to be physically verified. After completing these phases, any necessary changes will be the subject of a modification project. Such a modification project, if required, would be included in our forthcoming Integrated Safety Assessment Program for prioritization and scheduling.

The first part of the document discusses the importance of maintaining accurate records and the role of the auditor in this process. It emphasizes that the auditor's primary responsibility is to provide an independent and objective assessment of the financial statements.

THE AUDITOR'S RESPONSIBILITIES

The auditor's responsibilities are defined by the auditing standards and the terms of the engagement. These responsibilities include the identification and assessment of risks of material misstatement, the design and implementation of audit procedures, and the collection of sufficient and appropriate audit evidence. The auditor must also maintain professional skepticism throughout the audit process and communicate the results of the audit to the appropriate parties.

THE AUDITOR'S REPORT

The auditor's report is the final product of the audit process and provides the users of the financial statements with information about the auditor's findings. The report typically includes the auditor's opinion on the financial statements, the scope of the audit, and any limitations or qualifications. The auditor must ensure that the report is clear, concise, and free from bias or ambiguity.



## 2. Analog-Level-Trip-Units

### a. NRC-Description:

Review of plant experience relating to mechanical level indication equipment. Plant experience shows mechanical level equipment is more vulnerable to failure or malfunction than analog equipment. A number of plants have already connected analog trip units to their level transmitters to improve reliability and accuracy. Those plants that use mechanical level indication should replace the mechanical level indication equipment with analog level transmitters unless operating experience confirms high reliability.

### b. Niagara-Mohawk-Response:

The mechanical trip units for Nine Mile Point Unit 1 were replaced with analog units during the spring 1979 refueling outage. This project was described in our letter of March 27, 1979.

THE UNIVERSITY OF CHICAGO  
DIVISION OF THE PHYSICAL SCIENCES  
DEPARTMENT OF CHEMISTRY  
5800 S. DICKINSON DRIVE  
CHICAGO, ILLINOIS 60637  
TEL: 773-936-3700  
FAX: 773-936-3701  
WWW: WWW.CHEM.UCHICAGO.EDU