

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8412180290 DOC.DATE: 84/12/14 NOTARIZED: YES DOCKET #
 FACIL:50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha. 05000410
 AUTH.NAME AUTHOR AFFILIATION
 MANGAN,C.V. Niagara Mohawk Power Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 SCHWENCER,A. Licensing Branch 2

SUBJECT: Forwards info requested in 841212 telcon re design basis for roof snow loading. Info will be included in FSAR Amend 17.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DL/ADL	1 0	NRR LB2 BC	1 0
	NRR LB2 LA	1 0	HAUGHEY,M 01	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DEPER/IRB 35	1 1
	IE/DQASIP/QAB21	1 1	NRR ROE,M,L	1 1
	NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
	NRR/DE/EHEB	1 1	NRR/DE/eqB 13	2 2
	NRR/DE/GB 28	2 2	NRR/DE/MEB 18	1 1
	NRR/DE/MTEB 17	1 1	NRR/DE/SAB 24	1 1
	NRR/DE/SGEB 25	1 1	NRR/DHFS/HFEB40	1 1
	NRR/DHFS/LQB 32	1 1	NRR/DHFS/PSRB	1 1
	NRR/DL/SSPB	1 0	NRR/DSI/AEB 26	1 1
	NRR/DSI/ASB	1 1	NRR/DSI/CPB 10	1 1
	NRR/DSI/CSB 09	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/METB 12	1 1	NRR/DSI/PSB 19	1 1
	NRR/DSI/RAB 22	1 1	NRR/DSI/RSB 23	1 1
	REG FILE 04	1 1	RGN1	3 3
	RM/DDAMI/MIB	1 0		
EXTERNAL:	BNL (AMDTs ONLY)	1 1	DMB/DSS (AMDTs)	1 1
	FEMA-REP DIV 39	1 1	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1
	NTIS	1 1	PNL GRUEL,R	1 1



11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

December 14, 1984
(NMP2L 0296)

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Schwencer:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Attached is the information requested by your staff during a telephone conference on December 12, 1984. This material provides the design basis for the roof snow loading and will be included in Final Safety Analysis Report Amendment 17.

Very truly yours,

C. V. Mangar
C. V. Mangar
Vice President
Nuclear Engineering & Licensing

DS:ja
Attachment
xc: R. A. Gramm, NRC Resident Inspector
Project File (2)

8412180290 841214
PDR ADDCK 05000410
A PDR

Bool
11



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial data and for facilitating audits.

2. The second part of the document outlines the various methods used to collect and analyze data. It includes a detailed description of the sampling techniques employed and the statistical models used to interpret the results.

3. The third part of the document provides a comprehensive overview of the findings. It highlights the key trends observed in the data and discusses the implications of these findings for the organization's operations and strategic planning.

4. The fourth part of the document concludes with a summary of the main points and offers recommendations for future research. It suggests that further studies should be conducted to explore the long-term effects of the interventions discussed in the report.

5. The fifth part of the document contains a list of references and a list of figures. The references cite the key sources used in the research, and the figures provide a visual representation of the data presented in the text.

6. The sixth part of the document includes a list of appendices and a list of tables. The appendices provide additional information that supports the main text, and the tables present the data in a structured and easy-to-read format.

7.

8.

9.

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 14 day of December, 1984.

DOMINICK T. SCAFIDI
NOTARY PUBLIC STATE OF NEW YORK
RESIDING IN Onondaga COUNTY
COMMISSION EXPIRES MARCH 30, 1986.
Dominick T. Scafidi
Notary Public in and for
Onondaga County, New York

My Commission expires:

MARCH 30, 1986



1. The first part of the document is a list of names and addresses, which appears to be a directory or a list of contacts. The names are written in a cursive or handwritten style, and the addresses are listed below them.



2. The second part of the document is a list of names and addresses, similar to the first part. It also appears to be a directory or a list of contacts.

3. The third part of the document is a list of names and addresses, continuing the directory or list of contacts.

4. The fourth part of the document is a list of names and addresses, continuing the directory or list of contacts.

Hail

Hail storms are a relatively rare phenomenon in the region. Pautz reports that there were 49 occurrences of hail with diameters greater than or equal to 1.91 cm (0.75 in) in New York State in the 13-yr period from 1955 through 1967⁽¹⁷⁾. This converts to approximately four severe hail storms per year. However, hail frequency is not uniform throughout the state. Baldwin and Changnon, both report an annual frequency of one to two hail storms per year in north central New York^(18, 19). Changnon indicates that these storms are most likely to occur in the late spring. A review of the Monthly Climatological Data for Syracuse shows four occurrences of hail during the period 1976 through 1980⁽²⁰⁾.

Ice Storms

A survey by Bennett for 1928 through 1937 indicates that ice or freezing rain may occur up to one to three times per year in the site region⁽²¹⁾. These occurrences are most frequent during the winter. However, glaze accumulations greater than 0.64 cm (0.25 in) could be expected only once per year. A more recent summary of glaze statistics in Baldwin indicates that during the 20-yr period (1950 through 1969), 8 to 12 days of glaze annually occur over the region⁽¹⁸⁾. Glaze has occurred on 49 days during 1976 through 1980 at the Syracuse NWS Station⁽²⁰⁾. The longest duration of freezing rain at the Syracuse NWS Station during this period occurred for 30 hours between March 2nd and 3rd of 1976⁽²⁰⁾.

High Air Pollution Potential

Episodes of limited atmospheric dispersion in the U.S. have been studied by Holzworth in terms of urban and area pollutant source problems⁽²²⁾. Holzworth has estimated approximately 10 forecast days of high potential for air pollution in a 5-yr period in the vicinity of the site. Using a pressure gradient technique to define stagnating conditions, Korshover found between 75 to 125 stagnation days in the region during the 40-yr period from 1936 through 1975⁽²³⁾. This converts to 2 to 3 stagnation days per year, which agrees with Holzworth's estimate. The summer and fall experience the highest potential for stagnation days.

2.3.1.3.2 Maximum Snow Load

A conservative estimate of the 100-year recurrence interval ground-level snow load is estimated to be 45 psf. (61) Based upon this data, a roof snow load of 45 psf (62) is conservatively used in



[Faint, illegible text spanning the width of the page, possibly bleed-through from the reverse side.]

Nine Mile Point Unit 2 FSAR

designing the Category I structures. Additional snow loads due to drifting of snow on the building roofs due to channeling or blowing-up effects against the taller structure walls, is also considered in designing the Category I structures. The criteria used in determining additional snow loads meets or exceeds the requirements of ANSI A58.1 (61).



[Faint, illegible text spanning the width of the page]

Nine Mile Point Unit 2 FSAR

56. U.S. Department of Commerce. Local Climatological Data-Annual Summary With Comparative Data - Rochester, New York. Environmental Data Service, NOAA. 1982.
57. Changery, M.J. Historical Extreme Winds for the United States - Great Lakes and Adjacent Regions. National Climatic Center, NOAA, Prepared for U.S. NRC, NUREG/CR-2890, August 1982, pp. 187.
58. ANSI A58.1, pp. 100, March 1982.
59. Kramer, M.L. and Halitsky, J. Accident X/Q Values at Category I Fresh Air Intakes and Vital Area Access Zones for Releases from the Main Steam Tunnel, the Combined Radwaste/Reactor Building Vent and the Main Stack at Nine Mile Point Unit 2. Prepared for Niagara Mohawk Power Corporation, January 6, 1984.
60. Kramer, M.L. and Halitsky, J. Addendum - Accident X/Q Values at Category I Fresh Air Intakes and Vital Area Access Zones for Releases from the Main Steam Tunnel, the Combined Radwaste/Reactor Building Vent and the Main Stack at Nine Mile Point Unit 2. Prepared for Niagara Mohawk Power Corporation, May 7, 1984.
61. ANSI A58.1, American National Standard, Building Code Requirements for minimum design loads in Buildings and other structures, 1972.
62. New York State Building construction code applicable to General Building construction, State of New York, November 30, 1979.

