

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8501100349 DOC.DATE: 85/01/08 NOTARIZED: YES DOCKET #  
 FACIL:50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410  
 AUTH.NAME AUTHOR AFFILIATION  
 MANGAN,C.V. Niagara Mohawk Power Corp.  
 RECIP.NAME RECIPIENT AFFILIATION  
 SCHWENCER,A. Licensing Branch 2

SUBJECT: Forwards changes to re turbine lubrication & control oil storage & use areas & diesel generator areas,Info will be incorporated into Amend 17 to FSAR.

DISTRIBUTION CODE: B001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 4  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR/DL/ADL	1 0	NRR LB2 BC	1 0
	NRR LB2 LA	1 0	HAUGHEY,M 01	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DQASIP/QAB21	1 1
	NRR ROE,M,L	1 1	NRR/DE/AEAB	1 0
	NRR/DE/CEB 11	1 1	NRR/DE/EHEB	1 1
	NRR/DE/EQB 13	2 2	NRR/DE/GB 28	2 2
	NRR/DE/MEB 18	1 1	NRR/DE/MTEB 17	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SGEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/PSRB	1 1	NRR/DL/SSPB	1 0
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ICSB 16	1 1	NRR/DSI/METB 12	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	<u>REG FILE</u> 04	1 1
	RGN1	3 3	RM/DDAMI/MIB	1 0
EXTERNAL:	BNL(AMDTs ONLY)	1 1	DMB/DSS (AMDTs)	1 1
	FEMA-REP DIV 39	1 1	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1
	NTIS	1 1	PNL GRUEL,R	1 1

[Faint, illegible text at the top of the page]

[Faint, illegible text in the upper middle section]

[Faint, illegible text in the middle section]

[Faint, illegible text in the lower middle section]

[Faint, illegible text in the lower section]

[Faint, illegible text in the lower section]

[Faint, illegible text at the bottom of the page]

[Faint, illegible text at the very bottom of the page]

January 8, 1985  
(NMP2L 0319)

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Schwencer:

Re: Nine Mile Point Unit 2  
..Docket No. 50-410...

Enclosed please find ten copies of changes to the Final Safety Analysis Report text which were reviewed with members of your staff on June 28 and 29, 1984.

This information will be included in Amendment 17 of the Final Safety Analysis Report.

Very truly yours,

*C. V. Mangano*  
C. V. Mangano  
Vice President

Nuclear Engineering & Licensing

NLR:ja  
Enclosure  
xc: R. A. Gramm, NRC Resident Inspector  
Project File (2)

8501100349 850108  
PDR ADOCK 05000410  
A PDR

*Boo1  
11*

Faint, illegible text in the upper left quadrant of the page.

Faint, illegible text in the upper right quadrant of the page.

Faint, illegible section header or title.

Large block of faint, illegible text in the middle of the page.

Faint, illegible section header.

Faint, illegible text in the lower middle section of the page.

Faint, illegible text in the lower right quadrant of the page.

Faint, illegible text in the bottom left corner of the page.

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Niagara Mohawk Power Corporation )  
(Nine Mile Point Unit 2) )

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 8<sup>th</sup> day of January, 1985.

Christine Austin  
Notary Public in and for  
Onondaga County, New York

My Commission expires:

**CHRISTINE AUSTIN**  
Notary Public in the State of New York  
Qualified in Onondaga Co. No. 6787537  
My Commission Expires March 30, 1985

CHRISTINE AUSTIN  
Notary Public in the State of New York  
(Qualified in Onondaga Co. No. 4731201)  
My Commission Expires March 30, 19...

Early warning smoke detection is provided in all battery rooms. Manual water hose reels and portable extinguishers are located near all battery rooms.

#### 9A.3.7.8 Turbine Lubrication and Control Oil Storage and Use Areas

All oil hazards connected with the turbine oil systems are located in the turbine building. There is no mechanical safety-related equipment located in the turbine building. Extensive fire suppression systems have been designed for the turbine oil hazards as discussed in the fire hazards analysis. Turbine oil does not pose a hazard to any safety-related system.

#### 9A.3.7.9 Diesel Generator Areas

Diesel generators are separated from each other and from other areas of the plant by 3-hr walls. Automatic preaction sprinkler systems have been provided for all three diesels. Division I and II diesel generators have been modified to allow spraying water on them without harmful effects. The Division III (HPCS) diesel generator will be modified.

All three diesel generator rooms have smoke detection systems that alarm in the control room and manual CO<sub>2</sub> and water hose reels and portable extinguishers for backup. Drainage is provided for firefighting water. Day tanks contain less than 1,100 gal and are located in separate rooms with 3-hr walls. Curbs are provided to contain the entire contents of the tank in the event of a tank leak and postulated sprinkler discharge. Room ventilation and automatic sprinkler protection have been provided.

The combustion air for each diesel generator comes through a separate air intake which is located at the south end of the diesel generator building. The exhaust air outlets for the diesel generator building ventilation systems are located on the roof at the north end of the diesel generator building, approximately 80 ft away.

Each diesel generator room is provided with three hour rated fire dampers in the ventilation systems. If a fire occurs in a diesel generator room it would be isolated from the other diesel generator rooms by the fire dampers and three hour fire walls. This would prevent a fire in one diesel generator from effecting the other diesel generators.

No credible fire and single failure of the fire protection system in the diesel generator building can degrade or destroy more than one combustion air intake.

#### 9A.3.7.10 Diesel Fuel Oil Storage Tanks

Diesel fuel oil storage tanks are buried. They are approximately 60 ft long and 12 ft in diameter. Half of each tank extends under the diesel generator building. The



77  
2000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000

1000  
1000  
1000



treatment routine is used with a fresh tank. Overtreatment will not adversely affect the storage, flow, or burning properties of the fuel oil. NUCHEM FC-101 contains various multipurpose agents. Its preservative additive prevents formation and settling out of organic sludge and, also, acts as a rust preventive agent protecting the storage tanks in the water bottom layer as well as in the air layer above the diesel fuel oil. NUCHEM FC-101 contains metal deactivators and metal suppressing agents which retard oxidation and polymerization of the fuel which can result because trace amounts of copper may be present in the fuel. A water absorptive agent in NUCHEM FC-101 keeps trace amounts of water dispersed in the diesel fuel oil and prevents burner flameout. NUCHEM FC-101 contains a bactericide agent which prevents bacteria and slime formation and destroys any existing organisms. NUCHEM FC-101, with its rigidly formulated multipurpose agents, ensures the startup of the standby diesel generators. Bell System telephone companies, utilities, and both small and large consumers of No. 2 diesel fuel oil are recognized users of NUCHEM FC-101 and related NUCHEM fuel conditioners. The external surfaces of the fuel oil storage tanks require no special coating but are free from oil, grease, loose rust, and loose paint. The tanks are buried in concrete below the diesel generator building. The fill, vent, and sounding line connections at the storage tanks are also buried in concrete to prevent corrosion. Since galvanic reactions are unlikely to occur in such an environment, cathodic protection of the fuel oil storage tanks is not required. After the interior and exterior surfaces are cleaned, tested, and dried, they are inspected in accordance with Subsection 3.1 of ANSI N45.2.1. The fill of each tank extends below the diesel generator mat beyond the exterior wall line, thereby positioning the tank fill line, sounding line, and vent line outside the building. Each storage tank is filled from its own tank truck fill station located in the yard. The storage tanks are constructed with baffles, 10 reinforcement stiffeners, 4 reinforcement rings, and 15-degree off-center drains to minimize turbulence within the tanks during filling. The 4-in. fill lines for the three divisional fuel oil storage tanks are located 51 ft 3 in. and 55 ft 3 in. from the first and second pump suction, respectively. Seven 3/4 in. x 8 in. stiffener rings are evenly spaced between the fill line and the first pump suction in



Main body of the document containing faint, illegible text and markings.