

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO MARK I CONTAINMENT LONG-TERM PROGRAM

POOL DYNAMIC LOADS REVIEW

NIAGARA MOHAWK POWER CORPORATION

DOCKET NO. 50-220

1.0 INTRODUCTION

In July 1980, the staff issued a report, NUREG-0661, "Safety Evaluation Report, Mark I Containment Long-Term Program," to address the NRC acceptance criteria for the Mark I containment Long-Term Program, which are intended to establish design basis loads that are appropriate for the anticipated life of each Mark I⁻BWR facility, and to restore the originally intended design safety margins for each Mark I containment system.

Since the issuance of NUREG-0661, the Mark I owners submitted additional reports in which they provided additional justification for the adequacy of: (1) the data base for specifying torus wall pressure during condensation oscillations; (2) the consideration given to asymmetric torus loading during condensation oscillations; and (3) the effect of fluid compressibility in the vent system on pool-swell loads. As a result of the staff's and its consultant's (Brookhaven National Laboratory) evaluation of these reports, Supplement 1 to NUREG-0661, dated August 1982, has been issued.

2.0 EVALUATION

Niagara Mohawk Power Corporation (NMPC) submitted a Plant Unique Analysis Report (PUAR) on the pool dynamic loads for the Nine Mile Point, Unit 1 Mark I containment. This report provides a description of the specific application of the generic Mark I pool dynamic loads and methods for Nine Mile Point, Unit 1 and the plant unique loads used in assessing the capability of the containment and components to accomodate the pool dynamic loading phenomena. The Brookhaven National Laboratory (BNL) was contracted to review the PUAR for compliance with the staff's acceptance criteria and to evaluate the acceptability of any proposed alternative load specification.

A summary of the BNL review and status for each of the pool dynamic loads is presented in the attached report titled "Technical Evaluation of the Nine Mile Point, Unit 1 Plant Unique Analysis Report." As indicated in the report, NMPC has adopted all but a few of the generic criteria. For those few exceptions alternative criteria were proposed. The BNL evaluation of these criteria is included in the attached report. Based on its review, the staff endorses the BNL evaluation and conclusion.



r . . .

μ . •

۰ ۲

متو...

.

3.0 CONCLUSIONS

The staff has completed an assessment of Nine Mile Point, Unit 1 against generic acceptance criteria contained in NUREG-0661 and its supplement, and has also reviewed those few areas where alternative criteria have been proposed. In addition, the staff has completed its review of those areas where additional information was relegated to the plant unique review. In each of these areas the staff has concluded that the pool dynamic loads utilized by NMPC are conservative and, therefore, acceptable.

Principal Contributor: F. Eltawila

Date: January 22, 1985

Attached: Technical Evaluation, dated September 1984, prepared by BNL ι

10-4