

B0058

APPENDIX A

LUBRICATION DATA FORM LC8

MAINTENANCE FORM LC9


|  |   |
|--|---|
| Stone & Webster Engineering<br>J.O. No. 12177<br>Spec. No. _____   |   |
| RELEASED FOR:<br>RETURN TO SUPPLIER <input type="checkbox"/><br>ENG & DESIGN <input type="checkbox"/><br>FABRICATION <input type="checkbox"/>  | DIRECTIONS TO SITE:<br>FOR CONSTRUCTION <input type="checkbox"/><br>NOT FOR CONSTRUCTION <input type="checkbox"/> |
| <input type="checkbox"/> APP Approved, Acceptable For Use<br><input type="checkbox"/> AAR Approved As Revised<br><input type="checkbox"/> UNA Unacceptable<br><input type="checkbox"/> BLT As-Built<br><input type="checkbox"/> FIO For Information Only |   |
| Date _____<br>By _____   |   |

8503260504 850305  
PDR ADDCK 05000410  
A PDR

1. The first part of the document is a list of names and addresses of the members of the committee. The names are listed in alphabetical order, and the addresses are given in full. The list is as follows:

| Name         | Address                              |
|--------------|--------------------------------------|
| Mr. A. B. C. | 123 Main St., New York, N. Y.        |
| Mr. D. E. F. | 456 Broadway, New York, N. Y.        |
| Mr. G. H. I. | 789 Fifth Ave., New York, N. Y.      |
| Mr. J. K. L. | 1010 Third Ave., New York, N. Y.     |
| Mr. M. N. O. | 1111 Second Ave., New York, N. Y.    |
| Mr. P. Q. R. | 1212 First Ave., New York, N. Y.     |
| Mr. S. T. U. | 1313 West 125th St., New York, N. Y. |
| Mr. V. W. X. | 1414 East 125th St., New York, N. Y. |
| Mr. Y. Z. A. | 1515 Central Ave., New York, N. Y.   |
| Mr. B. C. D. | 1616 Union Ave., New York, N. Y.     |
| Mr. E. F. G. | 1717 Madison Ave., New York, N. Y.   |
| Mr. H. I. J. | 1818 Park Ave., New York, N. Y.      |
| Mr. K. L. M. | 1919 Lexington Ave., New York, N. Y. |
| Mr. N. O. P. | 2020 Fifth Ave., New York, N. Y.     |
| Mr. Q. R. S. | 2121 Third Ave., New York, N. Y.     |
| Mr. T. U. V. | 2222 Second Ave., New York, N. Y.    |
| Mr. W. X. Y. | 2323 First Ave., New York, N. Y.     |
| Mr. Z. A. B. | 2424 West 125th St., New York, N. Y. |
| Mr. C. D. E. | 2525 East 125th St., New York, N. Y. |
| Mr. F. G. H. | 2626 Central Ave., New York, N. Y.   |
| Mr. I. J. K. | 2727 Union Ave., New York, N. Y.     |
| Mr. L. M. N. | 2828 Madison Ave., New York, N. Y.   |
| Mr. O. P. Q. | 2929 Park Ave., New York, N. Y.      |
| Mr. R. S. T. | 3030 Lexington Ave., New York, N. Y. |
| Mr. U. V. W. | 3131 Fifth Ave., New York, N. Y.     |
| Mr. X. Y. Z. | 3232 Third Ave., New York, N. Y.     |
| Mr. A. B. C. | 3333 Second Ave., New York, N. Y.    |
| Mr. D. E. F. | 3434 First Ave., New York, N. Y.     |
| Mr. G. H. I. | 3535 West 125th St., New York, N. Y. |
| Mr. J. K. L. | 3636 East 125th St., New York, N. Y. |
| Mr. M. N. O. | 3737 Central Ave., New York, N. Y.   |
| Mr. P. Q. R. | 3838 Union Ave., New York, N. Y.     |
| Mr. S. T. U. | 3939 Madison Ave., New York, N. Y.   |
| Mr. V. W. X. | 4040 Park Ave., New York, N. Y.      |
| Mr. Y. Z. A. | 4141 Lexington Ave., New York, N. Y. |
| Mr. B. C. D. | 4242 Fifth Ave., New York, N. Y.     |
| Mr. E. F. G. | 4343 Third Ave., New York, N. Y.     |
| Mr. H. I. J. | 4444 Second Ave., New York, N. Y.    |
| Mr. K. L. M. | 4545 First Ave., New York, N. Y.     |
| Mr. N. O. P. | 4646 West 125th St., New York, N. Y. |
| Mr. Q. R. S. | 4747 East 125th St., New York, N. Y. |
| Mr. T. U. V. | 4848 Central Ave., New York, N. Y.   |
| Mr. W. X. Y. | 4949 Union Ave., New York, N. Y.     |
| Mr. Z. A. B. | 5050 Madison Ave., New York, N. Y.   |
| Mr. C. D. E. | 5151 Park Ave., New York, N. Y.      |
| Mr. F. G. H. | 5252 Lexington Ave., New York, N. Y. |
| Mr. I. J. K. | 5353 Fifth Ave., New York, N. Y.     |
| Mr. L. M. N. | 5454 Third Ave., New York, N. Y.     |
| Mr. O. P. Q. | 5555 Second Ave., New York, N. Y.    |
| Mr. R. S. T. | 5656 First Ave., New York, N. Y.     |
| Mr. U. V. W. | 5757 West 125th St., New York, N. Y. |
| Mr. X. Y. Z. | 5858 East 125th St., New York, N. Y. |
| Mr. A. B. C. | 5959 Central Ave., New York, N. Y.   |
| Mr. D. E. F. | 6060 Union Ave., New York, N. Y.     |
| Mr. G. H. I. | 6161 Madison Ave., New York, N. Y.   |
| Mr. J. K. L. | 6262 Park Ave., New York, N. Y.      |
| Mr. M. N. O. | 6363 Lexington Ave., New York, N. Y. |
| Mr. P. Q. R. | 6464 Fifth Ave., New York, N. Y.     |
| Mr. S. T. U. | 6565 Third Ave., New York, N. Y.     |
| Mr. V. W. X. | 6666 Second Ave., New York, N. Y.    |
| Mr. Y. Z. A. | 6767 First Ave., New York, N. Y.     |
| Mr. B. C. D. | 6868 West 125th St., New York, N. Y. |
| Mr. E. F. G. | 6969 East 125th St., New York, N. Y. |
| Mr. H. I. J. | 7070 Central Ave., New York, N. Y.   |
| Mr. K. L. M. | 7171 Union Ave., New York, N. Y.     |
| Mr. N. O. P. | 7272 Madison Ave., New York, N. Y.   |
| Mr. Q. R. S. | 7373 Park Ave., New York, N. Y.      |
| Mr. T. U. V. | 7474 Lexington Ave., New York, N. Y. |
| Mr. W. X. Y. | 7575 Fifth Ave., New York, N. Y.     |
| Mr. Z. A. B. | 7676 Third Ave., New York, N. Y.     |
| Mr. C. D. E. | 7777 Second Ave., New York, N. Y.    |
| Mr. F. G. H. | 7878 First Ave., New York, N. Y.     |
| Mr. I. J. K. | 7979 West 125th St., New York, N. Y. |
| Mr. L. M. N. | 8080 East 125th St., New York, N. Y. |
| Mr. O. P. Q. | 8181 Central Ave., New York, N. Y.   |
| Mr. R. S. T. | 8282 Union Ave., New York, N. Y.     |
| Mr. U. V. W. | 8383 Madison Ave., New York, N. Y.   |
| Mr. X. Y. Z. | 8484 Park Ave., New York, N. Y.      |
| Mr. A. B. C. | 8585 Lexington Ave., New York, N. Y. |
| Mr. D. E. F. | 8686 Fifth Ave., New York, N. Y.     |
| Mr. G. H. I. | 8787 Third Ave., New York, N. Y.     |
| Mr. J. K. L. | 8888 Second Ave., New York, N. Y.    |
| Mr. M. N. O. | 8989 First Ave., New York, N. Y.     |
| Mr. P. Q. R. | 9090 West 125th St., New York, N. Y. |
| Mr. S. T. U. | 9191 East 125th St., New York, N. Y. |
| Mr. V. W. X. | 9292 Central Ave., New York, N. Y.   |
| Mr. Y. Z. A. | 9393 Union Ave., New York, N. Y.     |
| Mr. B. C. D. | 9494 Madison Ave., New York, N. Y.   |
| Mr. E. F. G. | 9595 Park Ave., New York, N. Y.      |
| Mr. H. I. J. | 9696 Lexington Ave., New York, N. Y. |
| Mr. K. L. M. | 9797 Fifth Ave., New York, N. Y.     |
| Mr. N. O. P. | 9898 Third Ave., New York, N. Y.     |
| Mr. Q. R. S. | 9999 Second Ave., New York, N. Y.    |
| Mr. T. U. V. | 10000 First Ave., New York, N. Y.    |

# LIMITORQUE CORPORATION



## LUBRICATION INSPECTION PROCEDURE & DATA

### GENERAL

Proper lubrication is an absolute essential in achieving the design life of all types of power transmission products and Limitorque valve controls are no exception.

The design of the actuator has been specially tailored to absolutely minimize the maintenance and re-lubrication requirements; however, periodic inspection is the only way to guarantee trouble-free service.

Limitorque utilizes a totally sealed gear case factory-packed with grease. The gear case can be mounted in any position (as all penetrations into it are sealed); however, those mounting positions which would cause vulnerable areas of the operator (e.g., motor and limit switch compartment) to be saturated with lubricant should a seal failure occur, should be avoided if possible and are not recommended. Grease is used in normal service instead of oil to minimize the impact of a seal failure (should one occur).

No seal can remain absolutely tight at all times; therefore, it is not unusual to find a very small amount of weeping around shaft seals—especially during long periods of idleness such as storage. The use of grease minimizes this condition as much as possible. Should a small amount of weeping be found in the limit switch compartment on start-up, it should be removed with a clean rag. Once the equipment has begun operating, this phenomenon should disappear.

### LUBRICATION INSPECTION

It is recommended that all Limitorque operators be inspected for proper lubrication prior to operating—especially if they had been stored for a long period of time.

### FREQUENCY

The frequency of lubrication inspections should be based upon historical data on the installed equipment. Every operator application has its own effect on lubricants and each facility should pattern its inspections around its particular needs. The following schedule of lubrication inspection should be followed until operating experience indicates otherwise.

**Main Gear Case:** Inspect lubrication on approximate intervals of 18 months or 500 cycles—whichever occurs first. Lubricate the Zerk fitting in the housing cover at the same interval.

**Geared Limit Switch:** Inspect lubrication on approximate intervals of 36 months or 1000 cycles—whichever occurs first.





The three primary considerations in a lubrication inspection are: (1) Quantity; (2) Quality; (3) Consistency.

**Quantity** - Limitorque operators are built to operate on the partial immersion principle. The primary concern in the amount of lubricant is whether the "worm" is totally immersed in grease. This can be verified by the use of one or more of the many "fill" and "drain" plugs provided on the operator housing.

**Quality** - When removing a "fill" or "drain" plug to inspect the lube level, remove a small amount and insure that it is clean and free of any contaminant including water. Should dirt, water, or other foreign matter be found, the units should be flushed with a commercial degreaser/cleaner like Exxon VARSOL #1 or #3 which is non-corrosive and does not affect seal materials such as Buna N or Viton. Repack unit with fresh lubricant.

**Consistency** - The main gear box lubricant should be slightly fluid approximating a standard NLGI-1 grade consistency or less. Thinners such as Amoco WAYTAC #31 oil may be added provided the volume of thinner does not exceed 20% of the total lubricant.

The geared limit switch lube should be soft to the touch approximating an NLGI-2 consistency or less.

Standard Lubricants  
\*(-20°F to 150°F)

| United Size               | Type               | Manufacturer | Color    | Base            |
|---------------------------|--------------------|--------------|----------|-----------------|
| SMC-04 & 03               | Nebula EPO (Rev.1) | Exxon        | Dark Tan | Calcium Complex |
| **SMB/SB/SBD<br>000,00    | Nebula EPO (Rev.1) | Exxon        | Dark Tan | Calcium Complex |
| **SMB/SB/SBD/WB<br>0 to 4 | Nebula EPO (Rev.1) | Exxon        | Dark Tan | Calcium Complex |
| SMB/WB-5                  | 50 EP (XC-421-39)  | Sun Oil Co.  | Black    | Lithium Lead    |
| **All HBC Sizes           | Nebula EPO (Rev.1) | Exxon        | Dark Tan | Calcium Complex |

\*Temperature rating based on continuous ambient vs. the time interval for inspection.

\*\*For nuclear containment safety related active units, Nebula EPOs used.

SMB/SB/SBD-000 & 00 lube was changed from Sun 50 EP (XC-421-39) to Nebula EPO on all unit serial numbers 295810 and higher.

SMB/SB/SBD/WB 0 through 4 lube was changed from Nebula EPI to Nebula EPO on all serial numbers 302262 and higher.

All HBC sizes lube was changed from Nebula EPI to Nebula EPO on all serial numbers 302262 and higher.

## GEARED LIMIT SWITCH:

Humble Oil Company - Beacon 325—Light Gray - acceptable substitute Mobil 28.

## MOTOR BEARINGS:

Motors furnished with Limitorque valve controls are lubricated for life.

## LUBRICANT SUBSTITUTES:

Typical commercially available lubricants other than those used by Limitorque for which manufacturers data indicates compatibility with Limitorque operators are shown below with the temperature range recommended by the manufacturer.



| <u>Manufacturer</u> | <u>Type</u>          | <u>Temperature Range</u> | <u>Base</u>                |
|---------------------|----------------------|--------------------------|----------------------------|
| Exxon               | **Humble P290        | - 40°F to 120°F          | Lithium Line               |
| Arco                | Litholine HEP1       | - 10°F to 220°F          | Lithium                    |
| Gulf Oil            | Gulfcrown EPO        | - 20°F to 220°F          | Lithium                    |
| Cities Service      | City AP              | - 0°F to 220°F           | Lithium                    |
| Mobil Oil Co.       | Mobilux EPO          | - 10°F to 220°F          | Lithium 12                 |
| Shell Oil           | Darina 0             | - 10°F to 250°F          | Hydroxystearate<br>No Soap |
| Fiske               | Lubriplate Low Temp. | - 40°F to 150°F          | Lithium                    |
| Texaco              | Marfak 0             | + 20°F to 200°F          | Sodium                     |
|                     | Low Temp. EP         | - 40°F to 200°F          | Lithium                    |
| Tidewater Oil       | Veedol Alitho 10     | - 10°F to 150°F          | Lithium                    |

\*\* Tested and used by Limitorque for applications at low temperatures (-50°F to -70°F). Consult Limitorque if the temperature range is beyond the limitations shown above.

The standard lubricants used by Limitorque have been proven extremely reliable over many years of service. There are, however, many other lubricants available which may be used *in place of* the standard.

*Do not add a different lubricant to a Limitorque operator unless it is of the same soap base as the existing lubricant unless you have received the approval of the lubricant manufacturer.*

The minimum lubricant qualities required by Limitorque are:

1. Should contain an "EP" additive.
2. Must be suitable for the temperature range intended.
3. Must be water and heat resistant and non-separating.
4. Must not create more than 8% swell in Buna N or Viton.
5. Must not contain any grit, abrasive, or fillers.
6. Must slump — prefer NLGI grade 0 to 1.
7. Must not be corrosive to steel gears, ball or roller bearings.
8. Dropping point must be above 316°F for temperature ranges of - 20°F to 150°F.

8/15/76  
Rev. 1 - 12/21/76  
Rev. 2 - 9/1/78  
Rev. 3 - 6/12/79  
Rev. 4 - 10/16/79




## LUBRICANT REQUIREMENTS

| UNIT SIZE       | Amount of Lubricant       |                          |
|-----------------|---------------------------|--------------------------|
|                 | Approx. Volume<br>Gallons | Approx. Weight<br>Pounds |
| SMC04           | .15                       | 1.0                      |
| SMB/SB-000      | .50                       | 3.5                      |
| SMB/SB/SBD-00   | .50                       | 4.0                      |
| SMB/SB/SBD/WB-0 | 1.00                      | 9.5                      |
| SMB/SB/SBD/WB-1 | 1.50                      | 15.0                     |
| SMB/SB/SBD/WB-2 | 1.75                      | 14.5                     |
| SMB/SB/SBD/WB-3 | 5.50                      | 50.0                     |
| SMB/SB/SBD/WB-4 | 8.50                      | 75.0                     |
| SMB/WB-4T       | 8.00                      | 71.0                     |
| SMB/WB-5T       | 7.50*                     | 65.0*                    |

\*Add 1 gallon/7 lbs. for thrust bearing assembly in SMB5 thrust-type unit.

|       |       |       |
|-------|-------|-------|
| H0BC  | .20   | 1.5   |
| H1BC  | .35   | 3.0   |
| H2BC  | .50   | 4.0   |
| H3BC  | 1.40  | 12.0  |
| H4BC  | 3.50  | 30.0  |
| H5BC  | 5.20  | 45.0  |
| H6BC  | 9.25  | 80.0  |
| H7BC  | 14.50 | 125.0 |
| H10BC | 26.00 | 225.0 |



## LIMITORQUE MAINTENANCE PROCEDURE

### MAJOR MAINTENANCE:

The need for major maintenance on Limitorque equipment occurs when some operational deficiency is evident. Care should be taken to evaluate the deficiency in order to determine the extent to which the major maintenance should proceed. Major maintenance should always include the routine maintenance requirements but in addition should proceed as follows:

1. \*Disassembly of deficient portion of equipment.
2. Replacement of any damaged or excessively worn component with new factory parts. It is recommended that worm and worm gears be replaced as a set to ensure the greatest benefit from the replacement.
3. Replacement of lubricant if main gear box was involved in the major maintenance.
4. Replacement of all torn gaskets and seals.
5. Inspect stem and stem nut thread carefully for wear and/or damage.
6. Check operability of all electrical control components before reinstallation.

\*Complete disassembly and reassembly instructions are available for all equipment.





## LIMITORQUE MAINTENANCE PROCEDURE

### ROUTINE MAINTENANCE:

A schedule should be made to periodically inspect all Limitorque equipment. The time interval of this inspection should depend upon the frequency of operation and the ambient environmental conditions in which the equipment is stored or installed. A minimum inspection period of eighteen months should be used as a base until experience indicates otherwise. This routine maintenance should include -

1. Remove limit switch compartment and/or control cabinet cover. Should moisture be evident, dry the compartment and components.
2. Inspect and clean all electrical controls and contacts in the limit switch compartment and/or control cabinet. This cleaning should consist of wiping clean of all electrical contacts with electrical type solvent cleaner similar to CRC Lectra Clean and removal of foreign residue.
3. Check all terminal connections for tightness.
4. Clean gasketed surfaces on limit switch compartment and/or control cabinet cover. Replace all damaged gaskets or seals for weatherproof or submersible units. Wipe a coating (approximately 2 mils) of lightweight bearing grease on surfaces of explosion-proof cover flanges for protection.
5. Inspect lubricant per Lubrication Procedure. Visually check shaft penetrations for indications of seal leakage. If abnormal leakage is found, the seal should be replaced. (Slight oil weepage is not cause for seal replacement.) SEE MAJOR MAINTENANCE.
6. Megger the motor. (One MEG-OHM or better is considered normal.)
7. Clean and lubricate the valve stem (obtain valve manufacturer's recommendation for lubricant) for rising stem applications.



APPENDIX B

BWR Containment Qualification

Report 600376A



NUCLEAR POWER STATION  
QUALIFICATION TYPE TEST REPORT  
LIMITORQUE VALVE ACTUATORS  
FOR BWR SERVICE

PROJECT #600376A

Test per IEEE Standard 382-72

Test performed 4/26/72 to 8/30/72

Prepared by Limitorque Corporation

APPROVED: \_\_\_\_\_

*W. J. Denkowski*  
W. J. Denkowski  
Vice President Engineering

DATE: \_\_\_\_\_

*5/13/76*

ACCEPTED: \_\_\_\_\_

*C. D. Formica*  
C. D. Formica  
Quality Assurance Administr.

REISSUED 5/13/76

DATE: \_\_\_\_\_

*5/13/76*



TABLE OF CONTENTS

|  | <u>Page No.</u> |
|--|-----------------|
| 1.0 Introduction.....                              | 1               |
| 2.0 Identification of Sample Valve Actuator.:..... | 1               |
| 3.0 Type-Test Procedure & Results.....             | 2               |
| 3.1 Aging Simulation.....                          | 3               |
| 3.1.1 Thermal Aging.....                           |                 |
| 3.1.2 Mechanical Aging.....                        |                 |
| 3.1.3 Radiation Aging.....                         |                 |
| 3.2 Seismic Qualification.....                     | 4               |
| 3.3 Accident Simulation.....                       | 5               |

FRANKLIN INSTITUTE RESEARCH LABORATORIES REPORT

|  |      |
|--|------|
| 1. Introduction.....                             | 1-1  |
| 2. Identification of Valve Operators.....        | 2-1  |
| 3. Steam Environment Test.....                   | 3-1  |
| 4. Conclusion.....                               | 4-1  |
| Figure 3 - Steam Exposure Profile.....           | 3-5  |
| Table 1(a) - Actuator Cycling Data - Unit 1..... | 3-7  |
| Table 1(b) - Actuator Cycling Data - Unit 2..... | 3-8  |
| Table 2(a) - Insulation Resistance - Unit 1..... | 3-10 |
| Table 2(b) - Insulation Resistance - Unit 2..... | 3-11 |
| 4.0 Conclusion.....                              | 6    |





APPENDICES .

- Appendix A - Test Data Log Sheets
- Appendix B - Instrument List
- Appendix C - Certificate of Compliance - Motor Heat Age
- Appendix D - Certificate of Compliance - Radiation Exposure
- Appendix E - Test Report - Seismic Qualification



## BWR Qualifications

### 1.0 Introduction

A typical Limitorque Valve Actuator, SMB-0 with a 25 ft lb motor was submitted for generic qualification to the type-test specified by IEEE Standard 382-72 for service in a Boiling Water Reactor (BWR) containment chamber in nuclear power station application. The operator is considered acceptable on provision it proves capable of satisfactorily operating against a load simulating a normal valve operating load in both opening and closing directions within a 30-day period following the start of environmental exposure.

### 2.0 Identification of Sample Valve Actuator

#### TEST UNIT

A Limitorque SMB-0 Valve Actuator with a 25 ft lb nuclear containment motor (RH insulation) was constructed per standard nuclear bills of material and standard nuclear motor specifications. The following information was taken from the equipment nameplates.

#### Valve Actuator

Type/Size.....SMB-0  
Manufacturer.....Limitorque Corporation  
Order Number.....360943A  
Serial Number.....144068



### Electric Motor Information

Size.....25 ft lb stall  
5 ft lb run

Manufacturer.....Reliance Electric Co.

Identification Number.....601962-P

Speed.....1700 RPM

Voltage.....230/460

Frequency.....60 Hz

Duty.....15 minute

Insulation Class .....RH

Type.....P

- 2.1 The SMB-0-25 Valve Actuator S/N 144068 had originally been subjected to a short term environmental test with motor identification number 601960P. At the conclusion of the test, the valve actuator was refitted with motor identification number 60192-P which had also been subjected to gamma radiation of 204 megarads and to seismic test (Ogden Technology Laboratories, Inc. Report 7192-9).

### 3.0 Type-Test Procedure and Results

The type-test plan as described in IEEE Standard 382-72, paragraph 4, consists of three basic parts.

1. Aging Simulation
2. Seismic Qualification
3. Accident Environmental Simulation



### 3.1 Aging Simulation

#### 3.1.1 Thermal Aging

Thermal aging was performed on the motor stators by the motor manufacturer (Reliance Electric Co.).

The motor stator was heat-aged for 100 hours at 180°C. Refer to Appendix C for Certificate of Compliance confirming this aging simulation. Regarding the nuclear valve actuator switches and seals, the aging temperature would not exceed 200°F for 200 hours. The switch and seal materials are rated by the manufacturers for use at 300°F and 450°F respectively. Since Limitorque Corporation has successfully used valve actuators with these materials at continuous temperatures of 300°F, heat-aging these components at lower temperatures was not considered necessary.

#### 3.1.2 Mechanical Aging

Mechanical aging was performed on the test unit by Limitorque Test Laboratory starting 3/13/72 and completing on 3/27/72. The SMB-0-25 Limitorque valve actuator was installed on a test stand with an Acme stem thrusting against a load cell to simulate seating thrust. After calibrating the torque switch to obtain an average thrust of 20,740 lbs (average of ten readings obtained at a torque switch setting of 1-7/8). The unit remained on the test stand and was cycled at room ambient conditions for a total of 500 cycles, each consisting of one opening and one closing stroke.





### 3.1.2 Mechanical Aging (continued)

At the conclusion of the mechanical aging, the thrust was checked showing an average thrust of 21,058 lbs in a total of ten readings.

### 3.1.3 Radiation Aging

The test unit was exposed to a cobalt 60 gamma field of one megarad/hour at an air equivalent dosage for a period of four hours by Radiation International, Inc. and then shipped to the test lab for seismic qualification.

After seismic testing, the unit was additionally exposed to the one megarad/hour gamma field for an additional 200 hours.

A copy of Radiation International, Inc. certification of this radiation exposure is included in Appendix D.

## 3.2 Seismic Qualification

The seismic qualification was performed April 26, 1972 by Ogden Technology Laboratories, Inc. on an Electro-Hydraulic Vibration machine. The test unit with motor was scanned in each of the three major axes over a frequency range of 1 to 35 Hz with a maximum acceleration of 1.0g's to search for resonance. Since no resonance was found, the test sample was then vibrated for a period of ten seconds at each even integer of frequency from 4 to 34 Hz in each axis at an excitation of 3 g's. The unit was operated during each dwell through one cycle from open limit



to torque switch seated position and back to original point. The test sample was then vibrated for a minimum of ten seconds at 35 Hz in each axis at an excitation level of 5 g's with the unit being operated as indicated above.

A report on the seismic qualification was prepared by Ogden Technology Laboratories, Inc. (Report No. 7192-9), a copy being included in Appendix E.

### 3.3 Accident Simulation

The test was performed at the Franklin Institute Research Laboratory Environmental Facility starting July 31, 1972 and ending August 30, 1972. With the exception of using two temperature transients and limiting the test to thirty days per the combined test profile, the valve actuator was exposed to the profiles indicated on Table 2, page 12 of IEEE382-72.

Due to limitations in the environmental chamber used, the time required to cool the chamber far exceeds that suggested by the combined profile. The temperature transients, however, closely approximated that stipulated by table 2 of IEEE382-72. Since the cooling rate between transients is not specified in table 2, and furthermore, since the second transient is intended to approach a conservative position for further assurance of actuator performance during the LOCA, the cooling rate is not part of the environmental test and is of no consequence.

The Franklin Institute Research Laboratories Test Report F-C3441 attached describes the test detail.



PROPRIETARY INFORMATION

Technical

Final Report  
F-C3441

Report

QUALIFICATION TEST OF LIMITORQUE VALVE  
OPERATORS IN A SIMULATED REACTOR  
CONTAINMENT POST-ACCIDENT STEAM ENVIRONMENT

September 1972

*Prepared for*

Limatorque Corporation  
(Affiliated with Philadelphia Gear Corporation)  
King of Prussia, Pennsylvania

Under Limatorque Shop Order No. 600376-A

PROPRIETARY INFORMATION



THE FRANKLIN INSTITUTE RESEARCH LABORATORIES  
BENJAMIN FRANKLIN PARKWAY • PHILADELPHIA, PENNA 19103



## 1. INTRODUCTION

Two Limitorque SMB-0-25 valve operators were subjected to a qualification test to determine their acceptability for service in a nuclear power plant. The test consisted of a 30-day exposure to a steam environment at temperatures going as high as 340°F during the first day. The performance of the valve operators was monitored by periodic cycling (under simulated valve-seating load) and measurement of insulation resistance on all power and control leads. The test was started on July 31, 1972, and ran through August 30, 1972.





## 2. IDENTIFICATION OF VALVE OPERATORS

The valve operators were identified by the following information on the name plates.

## UNIT NO. 1

LIMITORQUE VALVE OPERATOR

TYPE: SMB  
SIZE: 0  
ORDER: 360943A  
SERIAL: 144068

## UNIT NO. 2

LIMITORQUE VALVE OPERATOR

TYPE: SMB  
SIZE: 0  
ORDER: 355696A  
SERIAL: 135809A

MOTOR

MANUFACTURER: Reliance Electric Co.  
IDENTIFICATION NO: 601962-P  
START: 25 lb-ft  
RUN: 5 lb-ft  
  
TYPE: P  
FRAME: R56  
PHASE: 3  
RPM: 1700  
HZ: 60  
VOLTS: 230/460  
AMP: 8.0/4.0  
RISE AT RUN TORQUE: 75°C  
DUTY: 15 min  
INSULATION: Class HR

MOTOR

IDENTIFICATION: 463489-DX  
START: 25 lb-ft  
RUN: 5 lb-ft  
TYPE: P  
FRAME: R56  
PHASE: 3  
RPM: 1700  
HZ: 60  
VOLTS: 230-460  
AMPS: 8.0/4.0  
AMBIENT: 75°C  
INSULATION: Class HR  
DUTY: 15 min



The valve operator on Unit No. 1 had previously been exposed by FIRL to gamma radiation (200 megarads) and a steam/chemical environment (for twelve days), and had been refitted by Limitorque with a motor which had been subjected to a gamma radiation dose of 200 megarads (by FIRL) and a seismic test (by Limitorque). The valve operator had also been subjected to a seismic test by Limitorque. The prior tests conducted by FIRL are documented in Final Report F-C3327.\* Unit No. 2 had not been subjected to any prior testing.

During the installation of the units in the test chamber, the melamine switch base of Unit No. 1 was accidentally broken. It was replaced by a new base which was first exposed to 200 megarads of gamma radiation, the same radiation exposure which Unit 1 had received.

---

\* *Qualification Test of Limitorque Valve Operator, Motor Brake, and Other Units in a Simulated Reactor Containment Post-Accident Environment,* Final Report F-C3327, Franklin Institute Research Laboratories, July 1972.



### 3. STEAM ENVIRONMENT TEST

#### 3.1 Test Arrangement

The test was conducted in FIRL's Qualification Test facilities, shown in Figure 1. Unit No. 1 was mounted in the rear, and Unit No. 2 in the front, of the test chamber. Control and power lead connections were made by running teflon insulated wires through sealed (Conax) fittings on the switch compartments of the units and the test chamber wall. A control panel provided with switches and position indicating lights (wired to the geared limit switches) was used to cycle the units during the test. Provision was made for measuring the pressure and temperature inside the test chamber and in the switch compartments of the two units as well as the temperature inside the motor housing of Unit No. 1 and in the steam condensate that collected in the bottom of the test chamber (below the drain level). Instrumentation was provided for measuring electrical parameters when the valve operators were cycled.

To subject the valve operators to a load during cycling, each of them was fitted with a closed-end thrust tube over the screw. At the end of each *close* stroke, seating of the screw against the closed end of the tube simulated the mechanical loading of valve seating.

#### 3.2 Test Procedure

The valve operators were exposed to steam in accordance with the pressure/temperature profile recommended in the proposed IEEE guide for type tests of Class I electric valve operators.\* This profile is illus-

---

\*Proposed Guide for Type Test of Class I Electric Valve Operators for Nuclear Power Generating Stations, Draft 13, IEEE Project No. 382, JCNPS/SC2.3, June 1972.



trated in Figure 2, which also shows the schedule for cycling the valve operators and measuring the insulation resistance of the power and control leads. During the first four days of the test, the specified temperatures and pressures were maintained by the controlled injection of steam into the test chamber. To achieve the specified temperature drops, the natural cooling of the test chamber (after the steam pressure and flow rate were decreased) was enhanced by blowing air over the exterior of the chamber and circulating water through a coil inside the chamber. During the remainder of the test, the 200°F/10-psig state was maintained by filling the test chamber with air and using external electrical heaters. The atmosphere within the chamber was kept saturated with water vapor by daily injections of steam and by maintaining the steam condensate in the bottom of the chamber at a temperature equal to, or slightly greater than that of the air/vapor mixture.

### 3.3 Test Results

#### 3.3.1 Pressure/Temperature Profile

Copies of the data log sheets are given in Appendix A.

The actual pressure/temperature profile achieved during the critical first four days is illustrated in Figure 3. During the last twenty-six days of the test, the temperature was maintained within approximately 5% of the specified 200°F. The main difference between the specified and actual temperature profiles is that more than the specified time was required to cool the test chamber after the first dwell at 340°F. (As a consequence of there being two valve operators within the test chamber, the amount of heat that had to be dissipated in two hours exceeded our cooling capacity.) Another difference is that the pressure rises to 105 psig required 19 seconds and 23 seconds at the beginning of the first and second pressure transients, respectively, instead of the specified









Figure 2. Specified Steam Exposure Profile





F-C3441

Figure 3. Actual Steam Exposure Profile



TABLE 2(b)

INSULATION RESISTANCE OF POWER AND CONTROL LEADS - UNIT NO.2  
All Resistances are in Megohms Except Where a K Indicates Kilo-ohms

| Time After<br>Start of<br>Test (hr) | Stator Winding<br>Leads |      |      | Control Circuit Leads |      |      |      |      |      |      |      |
|-------------------------------------|-------------------------|------|------|-----------------------|------|------|------|------|------|------|------|
|                                     | 2T-1                    | 2T-2 | 2T-3 | 2CL1                  | 241  | 245  | 251  | 255  | 261  | 270  | 271  |
| -238.9*                             | ∞                       | ∞    | ∞    | ∞                     | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    |
| - 65.9*                             | 500                     | 500  | 500  | 200                   | 200  | 200  | 200  | 200  | 200  | 200  | 200  |
| - 0.66*                             | -                       | -    | -    | -                     | -    | -    | -    | -    | -    | -    | -    |
| 0.08                                | 90K                     | 80K  | 80K  | 60K                   | 60K  | 60K  | 60K  | 60K  | 60K  | 60K  | 60K  |
| 1.97                                | 0.13                    | 0.13 | 0.14 | 39K                   | 40K  | 43K  | 0.24 | 43K  | 48K  | 48K  | 46K  |
| 11.3                                | 0.16                    | 0.15 | 0.14 | 0.50                  | 0.50 | 0.50 | 1.9  | 0.50 | 0.50 | 0.51 | 0.51 |
| 95.8                                | 1.0K                    | 1.5K | 1.5K | 1.0K                  | 1.0K | 1.0K | 4.0K | 1.0K | 5.0K | 5.0K | 1.0K |
| 99.3                                | 8.0K                    | 8.0K | 8.0K | 1.0K                  | 1.0K | 1.0K | 4.0K | 1.0K | 5.0K | 6.0K | 2.0K |
| 99.9                                | -                       | -    | -    | -                     | -    | -    | -    | -    | -    | -    | -    |
| 101.9                               | 25K                     | 25K  | 25K  | 40K                   | 40K  | 40K  | 90K  | 40K  | 40K  | 50K  | 50K  |
| 167.1                               | 90                      | 90   | 90   | >100                  | >100 | >100 | >100 | >100 | >100 | >100 | >100 |
| 191.0                               | 90                      | 90   | 90   | >100                  | >100 | >100 | ∞    | >100 | >100 | >100 | >100 |
| 359.8                               | 8.5                     | 8.5  | 8.5  | 50                    | 50   | 50   | 100  | 50   | 50   | 50   | 50   |
| 575.2                               | 7.0                     | 7.0  | 7.0  | 40                    | 40   | 40   | 90   | 40   | 40   | 40   | 40   |
| 724.7                               | 6.5                     | 6.5  | 6.5  | 25                    | 25   | 25   | 80   | 25   | 25   | 25   | 25   |
| 726.5                               | <∞                      | <∞   | <∞   | <∞                    | <∞   | <∞   | <∞   | <∞   | <∞   | <∞   | <∞   |

\*Checkout readings taken before start of test.

F-C3441



### 3.3.5 Final Inspections

A visual inspection of the valve operators and test chamber was conducted at the conclusion of the test. Photographs of the units at this point are shown in Figures 4, 5 and 6. In Figure 4, the grease marks inside the test chamber, at the left, clearly show that the condensate level rose well above the top of the valve operators during the flooding discussed in Section 3.3.2. This means that the motors were completely submerged during the flooding.

The paint had deteriorated over the entire exterior of the units, particularly on Unit No. 1 (which had gone through a steam/chemical exposure prior to the steam exposure reported herein); and corrosion and pitting of the metal surfaces had begun. No damage was apparent inside the switch compartments. On Unit No. 2, a white powdery material that seemed to be a foreign substance covered part of the melamine plate in the limit switch. The lower portions of both switch compartments were covered with a thin layer of grease that had become partially baked and was flaking in some areas. The interior of each switch compartment cover exhibited what seemed to be a water line about 3 to 4 inches from the top; evidently, air trapped inside the covers prevented the water from completely filling the compartments during flooding. However, the height of the water line was such as to indicate that all but the uppermost parts of the switch mechanism had been under water.

After the valve operators were returned to Limitorque, they were disassembled for more detailed inspection. An FIRL engineer viewed the disassembly of Unit No. 1 and participated in inspecting it as well as No. 2.

On Unit No. 1, the gasket between the motor casing and valve-operator housing was in good condition. There was grease mixed with water on the pinion; there also was moisture on the inside of the motor end-caps, mixed with grease at the front end. However, the shaft and bearings turned freely, and lubrication seemed to be unimpaired. The





10 seconds. However, the temperature rose to about 330°F within 15 seconds at the start of the first transient and in 10 seconds at the start of the second transient. This was observed by viewing a thermometer at the top of the test chamber. The further rise to 340°F occurred more gradually.

### 3.3.2 Flooding of Test Chamber

During the fifth day of the test, when the conditions were being changed from 250°F/15 psig to 200°F/10 psig, it was discovered that the test chamber had become flooded with steam condensate. Investigation revealed that the condensate trap had become clogged with grease that had evidently come out of the pressure relief valve of the valve operators.

Judging by the amount of water which was removed from the chamber (about 225 gal) it was clear that the valve operators had been completely submerged by the condensate. This was confirmed at the conclusion of the test when the water line left inside the test chamber was found to be higher than the top of the valve operators under test. To help clear the interior of the valve operators of water which had entered them as a result of the flooding, air and nitrogen were flushed through the operator switch compartments (by use of the lines running between them and pressure gages outside the test chamber). Aside from this corrective action, the test was carried on without interruption; the test chamber was not opened at any time. The units performed normally when cycled after the period of flooding.

### 3.3.3 Operator Cycling Data

The electrical parameters (current, potential, and power) and the stroke times are listed in Tables 1(a) and 1(b) for Units 1 and 2; respectively.

The operators functioned normally throughout the test, with the following exception. Beginning with the third cycle, Unit 2 began to require two pushes of the start button to initiate the open cycle, after



Table 1(a) VALVE ACTUATOR CYCLING DATA — UNIT NO. 1

| Cycle No. | Time After Start of Test (hr) | OPEN            |                 |                 |                 |              |              |           |                   | CLOSE           |              |              |                  |             |          |                   |
|-----------|-------------------------------|-----------------|-----------------|-----------------|-----------------|--------------|--------------|-----------|-------------------|-----------------|--------------|--------------|------------------|-------------|----------|-------------------|
|           |                               | Potential       |                 |                 | Running Current |              |              | Power (W) | Stroke Time (sec) | Running Current |              |              | Peak Current (A) | Power       |          | Stroke Time (sec) |
|           |                               | $\phi_{ab}$ (V) | $\phi_{ac}$ (V) | $\phi_{bc}$ (V) | $\phi_a$ (A)    | $\phi_b$ (A) | $\phi_c$ (A) |           |                   | $\phi_a$ (A)    | $\phi_b$ (A) | $\phi_c$ (A) |                  | Running (W) | Peak (W) |                   |
| 1*        | -0.58                         | 480             | 480             | 480             | 3.6             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.5          | 3.4          | 3.6              | 250         | 2000     | 74.0              |
| 2         | 0.27                          | 475             | 475             | 475             | 3.5             | 3.3          | 3.6          | 250       | 74.0              | 3.5             | 3.4          | 3.3          | 3.6              | 250         | 1000     | 75.0              |
| 3         | 2.0                           | 475             | 475             | 475             | 3.4             | 3.3          | 3.5          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 1000     | 74.5              |
| 4         | 6.1                           | 475             | 475             | 475             | 3.5             | 3.4          | 3.5          | 250       | 74.0              | 3.6             | 3.5          | 3.4          | 4.0              | 250         | 1000     | 74.5              |
| 5         | 8.1                           | 475             | 475             | 475             | 3.6             | 3.5          | 3.6          | 250       | 74.0              | 3.7             | 3.6          | 3.5          | 4.0              | 250         | 1000     | 74.5              |
| 6         | 11.6                          | 484             | 484             | 484             | 3.6             | 3.5          | 3.7          | 250       | 74.0              | 3.7             | 3.6          | 3.5          | 4.0              | 250         | 1000     | 75.0              |
| 7         | 101.9                         | 478             | 478             | 478             | 3.5             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 1000     | 75.0              |
| 8         | 167.6                         | 478             | 476             | 477             | 3.5             | 3.3          | 3.6          | 250       | 74.2              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 500      | 75.0              |
| 9         | 191.3                         | 481             | 481             | 481             | 3.5             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.5          | 3.4          | 4.0              | 250         | 750      | 75.0              |
| 10        | 360.0                         | 480             | 480             | 480             | 3.5             | 3.3          | 3.5          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 1250     | 75.0              |
| 11        | 575.6                         | 478             | 478             | 478             | 3.5             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.9              | 250         | 1250     | 75.0              |
| 12        | 724.8                         | 478             | 478             | 478             | 3.5             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 1250     | 75.0              |
| 13        | 726.7                         | 480             | 479             | 480             | 3.6             | 3.3          | 3.6          | 250       | 74.0              | 3.6             | 3.4          | 3.3          | 3.8              | 250         | 1250     | 75.0              |

\*Checkout cycle run before start of test.



Table 1(b) VALVE ACTUATOR CYCLING DATA - UNIT NO. 2

| Cycle No. | Time After Start of Test (hr) | OPEN            |                 |                 |                 |              |              |           |                   | CLOSE           |              |              |                           |             |          |                   |
|-----------|-------------------------------|-----------------|-----------------|-----------------|-----------------|--------------|--------------|-----------|-------------------|-----------------|--------------|--------------|---------------------------|-------------|----------|-------------------|
|           |                               | Potential       |                 |                 | Running Current |              |              | Power (W) | Stroke Time (sec) | Running Current |              |              | Peak Current $\phi_c$ (A) | Power       |          | Stroke Time (sec) |
|           |                               | $\phi_{ab}$ (V) | $\phi_{ac}$ (V) | $\phi_{bc}$ (V) | $\phi_a$ (A)    | $\phi_b$ (A) | $\phi_c$ (A) |           |                   | $\phi_a$ (A)    | $\phi_b$ (A) | $\phi_c$ (A) |                           | Running (W) | Peak (W) |                   |
| 1*        | -0.35                         | 480             | 480             | 480             | 3.2             | 3.4          | 3.5          | 250       | 75.5              | 3.4             | 3.6          | 3.3          | 3.8                       | 250         | 1500     | 76.0              |
| 2         | 0.35                          | 475             | 475             | 475             | 3.2             | 3.3          | 3.5          | 250       | 76.0              | 3.3             | 3.5          | 3.3          | 3.5                       | 250         | 1250     | 76.5              |
| 3         | 2.2                           | 475             | 475             | 475             | 3.3             | 3.4          | 3.5          | 250       | -                 | 3.3             | 3.5          | 3.2          | 3.7                       | 250         | 1250     | 77.0              |
| 4         | 6.3                           | 475             | 475             | 475             | 3.3             | 3.5          | 3.5          | 250       | 79.5              | 3.4             | 3.5          | 3.4          | 3.9                       | 250         | 1000     | 76.5              |
| 5         | 8.2                           | 475             | 475             | 475             | 3.4             | 3.5          | 3.6          | 250       | 76.5              | 3.5             | 3.6          | 3.4          | 3.8                       | 250         | 1000     | 77.0              |
| 6         | 11.7                          | 484             | 484             | 484             | 3.4             | 3.5          | 3.6          | 250       | 77.0              | 3.5             | 3.7          | 3.4          | 3.9                       | 250         | 1250     | 77.0              |
| 7         | 101.0                         | 473             | 473             | 473             | 3.2             | 3.4          | 3.4          | 250       | 76.5              | 3.4             | 3.6          | 3.3          | 3.8                       | 250         | -        | 76.0              |
| 8         | 167.8                         | 475             | 475             | 475             | 3.2             | 3.4          | 3.4          | 250       | 75.5              | 3.4             | 3.5          | 3.2          | 3.6                       | 250         | 750      | 76.5              |
| 9         | 191.2                         | 481             | 481             | 481             | 3.3             | 3.5          | 3.6          | 250       | 75.5              | 3.4             | 3.6          | 3.3          | 3.9                       | 250         | 1000     | 76.5              |
| 10        | 360.2                         | 479             | 479             | 479             | 3.2             | 3.4          | 3.5          | 250       | 76.5              | 3.4             | 3.5          | 3.3          | 3.9                       | 250         | 1250     | 76.5              |
| 11        | 575.5                         | 478             | 478             | 478             | 3.2             | 3.4          | 3.4          | 250       | 76.0              | 3.3             | 3.5          | 3.2          | 3.8                       | 250         | 1500     | 77.0              |
| 12        | 724.9                         | 478             | 478             | 478             | 3.3             | 3.4          | 3.4          | 250       | 76.0              | 3.4             | 3.6          | 3.2          | 3.7                       | 250         | 1250     | 77.0              |
| 13        | 726.6                         | 480             | 481             | 480             | 3.3             | 3.4          | 3.5          | 250       | 76.0              | 3.4             | 3.6          | 3.2          | 3.8                       | 250         | 1250     | 76.0              |

\*Checkout cycle run before start of test.



which the cycle was executed normally. An analysis of this effect and checks made after the valve operator was disassembled led to the following explanation.

At the start of the open cycle, the bypass functions to prevent the opening of the torque switch by the torque spring, which is released and bounces back when the open pushbutton is actuated. Evidently, although it functioned satisfactorily at room temperature, the bypass was not remaining active long enough to fulfill its function after the valve operator was heated to 340°F. This may have been due to a change in bypass setting resulting from the fact that the grease lubricating the spring became lighter when heated, and had less dampening effect on the spring bounce than it did at room temperature. Thus, it appears that two pushes of the start button were needed because of an improper initial setting of the gear limit bypass. It must be emphasized that, aside from the need for a second push of the start button, the open cycle was always executed normally.

#### 3.3.4 Insulation Resistance Measurements

The measurements of insulation resistance made periodically on the power and control leads are listed for the two units in Tables 2(a) and 2(b). These measurements were made between each lead and ground (the test chamber), at 500 Vdc. The low values obtained on some of the control leads of Unit No. 1 during the first set of measurements (see first row of Table 2(a) were believed to be caused by chemical deposits left on the switch components by prior testing. In the process of cleaning and reconnecting the affected parts, a switch plate was accidentally broken; and, as mentioned in Section 2, the new part with which it was replaced was first exposed to the same dose of nuclear radiation that Unit No. 1 had received in prior testing.

During the time that the units were flooded with steam condensate. (see Section 3.3.2), the insulation resistances decreased significantly on both units; however, there was a recovery to high resistance values when the flooding was corrected.





TABLE 2(a)

INSULATION RESISTANCE OF POWER AND CONTROL LEADS - UNIT NO. 1  
All Resistances are in Megohms Except Where a K Indicates Kilo-ohms

| Time After<br>Start of<br>Test (hr) | Stator Winding<br>Leads |      |      | Control Circuit Leads |      |      |      |      |      |      |      |
|-------------------------------------|-------------------------|------|------|-----------------------|------|------|------|------|------|------|------|
|                                     | T-1                     | T-2  | T-3  | CL1                   | 41   | 45   | 51   | 55   | 61   | 70   | 71   |
| -238.9*                             | >100                    | >100 | >100 | ∞                     | 0.6  | 0.6  | 0.7  | 0.7  | ∞    | ∞    | ∞    |
| - 65.9*                             | ∞                       | ∞    | ∞    | ∞                     | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    |
| - 0.66*                             | 500                     | 500  | 500  | 200                   | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    | ∞    |
| 0.08                                | 15K                     | 15K  | 15K  | 50K                   | 60K  | 70K  | 75K  | 75K  | 75K  | 75K  | 70K  |
| 1.97                                | 70K                     | 65K  | 65K  | 35K                   | 35K  | 38K  | 40K  | 45K  | 42K  | 45K  | 42K  |
| 11.3                                | 0.13                    | 0.13 | 0.13 | 0.48                  | 0.48 | 0.48 | 0.49 | 2.9  | 0.50 | 0.51 | 0.51 |
| 95.8                                | 2.0K                    | 3.0K | 3.0K | 1.0K                  | 1.0K | 1.0K | 1.0K | 2.0K | 5.0K | 5.0K | 1.0K |
| 99.3                                | 5.0K                    | 4.5K | 4.5K | 1.0K                  | 1.0K | 1.0K | 1.0K | 7.5K | 5.0K | 5.0K | 1.0K |
| 99.9                                | 5.0K                    | 4.5K | 4.5K | -                     | -    | -    | -    | -    | -    | -    | -    |
| 101.9                               | 7.5K                    | 7.5K | 7.5K | 30K                   | 30K  | 35K  | 35K  | 0.14 | 40K  | 40K  | 40K  |
| 167.1                               | ∞                       | ∞    | ∞    | >100                  | >100 | >100 | >100 | ∞    | >100 | >100 | >100 |
| 191.0                               | ∞                       | ∞    | ∞    | >100                  | >100 | >100 | >100 | ∞    | >100 | >100 | >100 |
| 359.8                               | <∞                      | <∞   | <∞   | 50                    | 50   | 50   | 50   | ∞    | 50   | 50   | 50   |
| 575.2                               | >100                    | >100 | >100 | 40                    | 40   | 40   | 40   | ∞    | 40   | 40   | 40   |
| 724.7                               | 30                      | 30   | 30   | 25                    | 25   | 25   | 25   | >100 | 25   | 25   | 25   |
| 726.5                               | ∞                       | ∞    | ∞    | <∞                    | <∞   | <∞   | <∞   | <∞   | <∞   | <∞   | <∞   |

\*Checkout readings taken before start of test.

F-C3441






Figure 4. View Inside Test Chamber at Conclusion of Test







Figure 5. Closeup View Inside Test Chamber at Conclusion of Test

F-C3441





F-C3441

Figure 6. Overall View of Valve Operators After Removal From Test Chamber  
Unit No. 1 is at Right, Unit No. 2 is at Left.





F-C3441

drive gear was removed and found to be covered with grease, with no evidence of water. Water was found in the thrust tube at the valve end of the stem, but there was no corrosion. The grease at this location appeared to have broken down, possibly as a result of hydrolyzation or the exposure to nuclear radiation, but it appeared to have maintained lubrication of the stem. The tapered bearing on the drive sleeve was still well lubricated and there was no sign of wear. No moisture was evident on this bearing.

Unit No. 2 had much the same appearance as Unit No. 1, except that there was less evidence that there had been any breakdown of the grease in the thrust tube, possibly because Unit No. 2 had not been exposed to nuclear radiation.

While the observed partial breakdown of grease in the thrust tube is mentioned for completeness, this part of the unit was an attachment to permit simulation of the valve-seating load. In an actual installation, the external part of the stem (within the thrust tube in our set-up) might not be lubricated at all.



#### 4. CONCLUSION

Two Limitorque SMB-0-25 valve operators were subjected to a Qualification Test consisting of a 30-day exposure to a steam environment, including two temperature cycles going to 340°F during the first day. Unit No. 1 had previously been exposed to nuclear radiation, a seismic test and a steam/chemical environment, as described in a separate report.\* Both units were cycled periodically with a simulated valve-seating load during the test.

The pressure/temperature profile closely followed that recommended by a cognizant IEEE committee.<sup>Δ</sup> The units were subjected to severe flooding with steam condensate during the first few days of the test; this happened because the condensate trap on the test chamber became clogged with grease that came out of the pressure relief valves of the valve actuators.

The units performed satisfactorily throughout the test in spite of the flooding. Inspection of the units following the test revealed that all parts were in satisfactory condition. It was evident that lubrication had been maintained in spite of the loss of grease. Although water had entered in some places, none of the internal parts were corroded.

---

\*See footnote page 2-2.

ΔSee footnote page 3-1



## 5. CERTIFICATION

The undersigned certify that this report constitutes a true account of the tests that were conducted and the results obtained.

S. P. Carfagno

S. P. Carfagno  
Principal Scientist

N. M. Burstein

Nissen M. Burstein  
Sr. Research Engineer

L. E. Witcher

L. E. Witcher  
Test Engineer

APPROVED BY:

W. H. Steigmann

W. H. Steigmann, Manager  
Energy Systems Laboratory



#### 4.0 Conclusion

Since no detrimental effects during the unit aging were discernible, the unit is considered qualified for a 40-year life as outlined in the aging criteria. Furthermore, the unit operated satisfactorily throughout the environmental LOCA test as previously described and it is therefore concluded this test generically qualifies Limitorque Valve Actuators for use in a BWR containment chamber as depicted in IEEE382-72.







BWR Qualifications

APPENDIX A

Franklin Institute Research Laboratories

Test Data Log Sheets





## Appendix

APPENDIX A  
COPIES OF TEST DATA LOG SHEETS



THE FRANKLIN INSTITUTE RESEARCH LABORATORIES  
BENJAMIN FRANKLIN PARKWAY • PHILADELPHIA, PENNA. 19103



181-C3441-01

LIMITORQUE

LOG SHEET --- Page 1

| OPERATOR | DATE    | CLOCK<br>TIME<br>(2400 hr.) | COUNTER<br>TIME<br>(hr.) | TEMPERATURE (of) |         |                         |             |             |                     | PRESSURE (PSIG) |               |                     | REMARKS |    |
|----------|---------|-----------------------------|--------------------------|------------------|---------|-------------------------|-------------|-------------|---------------------|-----------------|---------------|---------------------|---------|----|
|          |         |                             |                          | CHAMBER          |         | COND-<br>ENSAT<br>TC #2 | SWITCH COMP |             | LIMITORQUE<br>MOTOR |                 | CHAM.<br>CAGE | SWITCH COMP<br>CAGE |         |    |
|          |         |                             |                          | TC#1             | THERM.  |                         | #1<br>TC #5 | #2<br>TC #7 | #1<br>TC #6         | #2<br>OHIT      |               | #1                  |         | #2 |
|          | 7/31/72 | 0916                        | 0000.0                   |                  |         | #2                      | #5          | #7          | #6                  | omit            |               |                     |         |    |
| GJV      | "       | 0930                        | RESET Zeros<br>000.0     | 134              | -       | 134                     | 146         | 149         | 153                 | -               | 0             | 0                   | 0       |    |
| "        | "       | 0938                        | RISE TO                  |                  | 05 PSIG | - 19                    | seconds     |             |                     |                 |               |                     |         |    |
| "        | "       | 0939                        |                          | 336              | 337     | 314                     | 289         | 302         | 110                 | -               | 110           | > 100               | > 100   |    |
| "        | "       | 0942                        |                          | 434              | 341     | 263                     | 308         | 313         | 311                 | -               | 110           | > 100               | > 100   |    |
| "        | "       | 0946                        | 0.1                      | 344              | 342     | 260                     | 315         | 320         | 314                 | -               | 109           | > 100               | > 100   |    |
| "        | "       | 0951                        | 0.2                      | 344              | 343     | 256                     | 324         | 330         | 329                 | -               | 109           | > 100               | > 100   |    |
| "        | "       | 0957                        | 0.3                      | 345              | 343     | 246                     | 333         | 337         | 331                 | -               | 109           | > 100               | > 100   |    |
| "        | "       | 1005                        | 0.4                      | 345              | 343     | 250                     | 337         | 340         | 335                 | -               | 109           | > 100               | > 100   |    |
| "        | "       | 1017                        | 0.6                      | 344              | 342     | 246                     | 338         | 340         | 334                 | -               | 105           | > 100               | > 100   |    |
| "        | "       | 1025                        | 0.75                     | 344              | 342     | 245                     | 339         | 340         | 335                 | -               | 105           | > 100               | > 100   |    |
| "        | "       | 1046                        | 1.1                      | 343              | 341     | 237                     | 339         | 341         | 337                 | -               | 105           | > 100               | > 100   |    |
| "        | "       | 1105                        | 1.4                      | 343              | 341     | 241                     | 340         | 341         | 338                 | -               | 104           | > 100               | > 100   |    |
| "        | "       | 1118                        | 1.6                      | 343              | 340     | 237                     | 340         | 341         | 339                 | -               | 104           | > 100               | > 100   |    |
| "        | "       | 1147                        | 2.1                      | 343              | 341     | 246                     | 341         | 341         | 343                 | -               | 105           | > 100               | > 100   |    |
| "        | "       | 1200                        | 2.35                     | 343              | 341     | 250                     | 340         | 342         | 340                 | -               | 103           | > 100               | > 100   |    |
| JEY      | "       | 1215                        | 2.6                      | 343              | 341     | 253                     | 341         | 342         | 341                 | -               | 103           | > 100               | > 100   |    |
| "        | "       | 1230                        | 2.85                     | 343              | 341     | 258                     | 341         | 342         | 341                 | -               | 104           | > 100               | > 100   |    |
| "        | "       | 1248                        | 3.15                     | 338              | 336     | 265                     | 339         | 340         | 338                 | -               | 96            | 96                  | 99      |    |
| GJV      | "       | 1258                        | 3.30                     | 332              | 330     | 269                     | 336         | 336         | 336                 | -               | 88            | 87                  | 90      |    |
| "        | "       | 1326                        | 3.75                     | 308              | 293     | 275                     | 327         | 328         | 328                 | -               | 45            | 44                  | 47      |    |
| JEY      | "       | 1348                        | 4.15                     | 267              | 265     | 210                     | 315         | 317         | 316                 | -               | 0             | 0                   | 0       |    |
| "        | "       | 1537                        | 5.95                     | 164              | -       | 87                      | 217         | 200         | 216                 | -               | 0             | 0                   | 0       |    |



181-CJ441-01

LIMITORQUE

LOG SHEET --- Page 2

LOG SHEET

PAR 9

| OPERATOR | DATE    | CLOCK<br>TIME<br>(2400 hr.) | COUNTER<br>TIME<br>(hr.) | TEMPERATURE (of) |        |                          |             |             |                     | PRESSURE (PSIG) |               |                     |       | REMARKS           |
|----------|---------|-----------------------------|--------------------------|------------------|--------|--------------------------|-------------|-------------|---------------------|-----------------|---------------|---------------------|-------|-------------------|
|          |         |                             |                          | CHAMBER          |        | COND-<br>ENSATE<br>TC #2 | SWITCH COMP |             | LIMITORQUE<br>MOTOR |                 | CHAM.<br>CAGE | SWITCH COMP<br>CAGE |       |                   |
|          |         |                             |                          | TC #1            | TIERN. |                          | #1<br>TC #5 | #2<br>TC #7 | #1<br>TC #6         | #2<br>OMIT      |               | #1                  | #2    |                   |
| JEY      | 7/31/72 | 1539                        | 6.0                      | 338              | 335    | 88                       | 234         | 250         | 291                 | -               | 108           | > 100               | > 100 | 23 sec. rise      |
| "        | "       | 1603                        | 6.4                      | 342              | 343    | 146                      | 337         | 340         | 332                 | -               | 108           | > 100               | > 100 |                   |
| "        | "       | 1622                        | 6.7                      | 342              | 341    | 154                      | 339         | 340         | 330                 | -               | 104           | > 100               | > 100 |                   |
| "        | "       | 1641                        | 7.0                      | 342              | 341    | 164                      | 339         | 340         | 328                 | -               | 104           | > 100               | > 100 |                   |
| "        | "       | 1704                        | 7.4                      | 342              | 341    | 171                      | 340         | 340         | 329                 | -               | 104           | > 100               | > 100 |                   |
| "        | "       | 1740                        | 7.7                      | 341              | 340    | 177                      | 340         | 340         | 329                 | -               | 104           | > 100               | > 100 |                   |
| "        | "       | 1740                        | 8.0                      | 342              | 341    | 181                      | 340         | 340         | 328                 | -               | 105           | > 100               | > 100 |                   |
| "        | "       | 1805                        | 8.4                      | 342              | 341    | 186                      | 340         | 340         | 330                 | -               | 105           | > 100               | > 100 |                   |
| "        | "       | 1829                        | 8.8                      | 342              | 341    | 188                      | 340         | 340         | 328                 | -               | 105           | > 100               | > 100 |                   |
| "        | "       | 1838                        | 9.0                      | 342              | 340    | 190                      | 340         | 339         | 327                 | -               | 105           | > 100               | > 100 |                   |
| GJV      | "       | 1848                        | 9.15                     | 332              | 331    | 190                      | 332         | 332         | 322                 | -               | 92            | 90                  | 93    |                   |
| "        | "       | 1923                        | 9.7                      | 322              | 321    | 192                      | 321         | 319         | 313                 | -               | 77            | 75                  | 78    |                   |
| "        | "       | 1956                        | 10.3                     | 322              | 321    | 194                      | 320         | 319         | 311                 | -               | 77            | 75                  | 78    |                   |
| "        | "       | 2100                        | 11.35                    | 322              | 321    | 195                      | 319         | 319         | 310                 | -               | 77            | 76                  | 78    |                   |
| "        | "       | 2137                        | 12.0                     | 322              | 321    | 194                      | 319         | 319         | 311                 | -               | 77            | 76                  | 78    |                   |
| "        | "       | 2148                        | 12.1                     | 311              | 313    | 194                      | 312         | 310         | 307                 | -               | 67            | 67                  | 69    |                   |
| "        | "       | 2200                        | 12.35                    | 300              | 303    | 195                      | 307         | 303         | 303                 | -               | 58            | 57                  | 59    |                   |
| "        | "       | 2208                        | 12.45                    | 295              | 396    | 196                      | 305         | 301         | 302                 | -               | 52            | 52                  | 53    |                   |
| "        | "       | 2218                        | 12.6                     | 279              | 282    | 195                      | 302         | 297         | 299                 | -               | 40            | 40                  | 40    |                   |
| "        | "       | 2228                        | 12.8                     | 279              | 270    | 195                      | 297         | 292         | 294                 | -               | 31            | 31                  | 31    | Water Coil on for |
| "        | "       | 2238                        | 13.0                     | 254              | 254    | 194                      | 292         | 288         | 290                 | -               | 19            | 19                  | 20    | cooling           |
| JEY      | "       | 2300                        | 13.35                    | 257              | 249    | 191                      | 281         | 278         | 278                 | -               | 14            | 14                  | 15    |                   |
| "        | "       | 2315                        | 13.6                     | 255              | 250    | 186                      | 275         | 272         | 274                 | -               | 15            | 14                  | 15    |                   |





181-C3441-01

## LIMITORQUE

LOG SHEET --- Page 3

| PAGE 3   |         |                             |  |                         |        |                          |             |             |                     |                 |               |                     |                  |    |
|----------|---------|-----------------------------|--|-------------------------|--------|--------------------------|-------------|-------------|---------------------|-----------------|---------------|---------------------|------------------|----|
| OPERATOR | DATE    | CLOCK<br>TIME<br>(2400 hr.) | COUNTER<br>TIME<br>(hr.)                               | TEMPERATURE (of)        |        |                          |             |             |                     | PRESSURE (PSIG) |               |                     | REMARKS          |    |
|          |         |                             |  | CHAMBER                 |        | COND-<br>ENSATE<br>TC #2 | SWITCH COMP |             | LIMITORQUE<br>MOTOR |                 | CHAM.<br>GAGE | SWITCH COMP<br>GAGE |                  |    |
|          |         |                             |  | TC #1                   | THERM. |                          | #1<br>TC #5 | #2<br>TC #7 | #1<br>TC #6         | #2<br>OMIT      |               | #1                  |                  | #2 |
| JEY      | 7/31/72 | 2330                        | 13.85  | 253                     | 251    | 183                      | 269         | 266         | 267                 | 15              | 15            | 16                  |                  |    |
| "        | "       | 2345                        | 19.1   | 252                     | 250    | 180                      | 264         | 260         | 250                 | 15              | 14            | 15                  |                  |    |
| "        | "       | 2900                        | 14.35  | 252                     | 251    | 182                      | 259         | 257         | 251                 | 16              | 15            | 16                  | Press.chart Reco |    |
| "        | 8/1/72  | 0820                        | 22.7   | 247                     | 251    | 179                      | 247         | 246         | 238                 | 16              | 16            | 17                  |                  |    |
| GJV      | "       | 1756                        | 32.3   | 249                     | 251    | 168                      | 244         | 243         | 233                 | 16              | 17            | 17                  |                  |    |
| "        | 8/2/72  | 0831                        | 46.8   | 250                     | 252    | 165                      | 248         | 247         | 238                 | 16              | 17            | 17                  |                  |    |
| "        | "       | 1756                        | 56.3   | 242                     | 253    | 167                      | 246         | 243         | 238                 | 16              | 16            | 17                  |                  |    |
| JEY      | 8/3/72  | 0825                        | 70.8   | 248                     | 251    | 181                      | 250         | 250         | 249                 | 15              | 16            | 17                  |                  |    |
| GJV      | "       | 1756                        | 80.3   | 248                     | 251    | 248                      | 249         | 249         | 249                 | 15              | 17            | 17                  |                  |    |
| "        | 8/4/72  | 0843                        | 95.1   | 248                     | 251    | 248                      | 249         | 249         | 249                 | 15              | 16            | 17                  |                  |    |
| JEY      | 8/4/72  | 1425                        | 100.7  | 248                     | 251    | 249                      | 250         | 250         | 249                 | 15              | 16            | 17                  |                  |    |
| GJV      | "       | 1538                        | 102.0  | 248                     | 251    | 247                      | 248         | 248         | 248                 | 15              | 16            | 17                  | Start of drip    |    |
| JEY      | "       | 1559                        | 102.3  | 237                     | 237    | 225                      | 242         | 242         | 240                 | 10              | 16            | 15.5                |                  |    |
| GJV      | 8/5/72  | 0900                        | set elec. heater air at 10 PSI - All water out of tank |                         |        |                          |             |             |                     |                 |               |                     |                  |    |
| "        | "       | 1022                        | 120.7  | 195                     | 220    | 233                      | 184         | 185         | 184                 | 11              | off           | off                 |                  |    |
| LEW      | "       | 1505                        | 125.4  | 202                     | 240    | 242                      | 204         | 208         | 205                 | 11              | off           | off                 |                  |    |
| "        | 8/7/72  | 0845                        | 0168   | WATER IN BOTTOM OF TANK |        |                          |             |             |                     |                 |               |                     |                  |    |
| JEY      | "       | 2339                        | 0182   | 182                     | 212    | 181                      | 181         | 187         | 182                 | 10              | -             | -                   |                  |    |
| "        | 8/8/72  | 0839                        | 0191.0   | 183                     | 209    | 186                      | 185         | 171         | 187                 | 10              | -             | -                   |                  |    |
| GJV      | "       | 2344                        | 206.1  | 186                     | 211    | 186                      | 186         | 192         | 188                 | 10              | -             | -                   |                  |    |
| "        | 8/9/72  | 1138                        | 218.0  | 189                     | 210    | 192                      | 189         | 194         | 190                 | 11              | -             | -                   |                  |    |
| "        | "       | 1745                        | 224.1  | 191                     | 210    | 115                      | 190         | 197         | 113                 | 10              | -             | -                   |                  |    |
| "        | 8/10/72 | 0915                        | 239.6  | 188                     | 208    | 111                      | 187         | 194         | 190                 | 10              | -             | -                   |                  |    |



181-CJ441-01

LIMITORQUE

LOG SHEET --- Page 6

| OPERATOR | DATE    | CLOCK<br>TIME<br>(2400 hr.) | COUNTER<br>TIME<br>(hr.) | TEMPERATURE (of) |        |                         |             |             |                     | PRESSURE (PSIG) |               |                     |    | REMARKS                      |
|----------|---------|-----------------------------|--------------------------|------------------|--------|-------------------------|-------------|-------------|---------------------|-----------------|---------------|---------------------|----|------------------------------|
|          |         |                             |                          | CHAMBER          |        | COND-<br>ENSAT<br>TC #2 | SWITCH COMP |             | LIMITORQUE<br>MOTOR |                 | CHAM.<br>CAGE | SWITCH COMP<br>CAGE |    |                              |
|          |         |                             |                          | TC #1            | THERH. |                         | #1<br>TC #5 | #2<br>TC #7 | #1<br>TC #6         | #2<br>OHIT      |               | #1<br>TC #1         | #2 |                              |
|          |         |                             |                          |                  |        |                         |             |             |                     |                 |               |                     |    |                              |
| GJV      | 8/10/72 | 1720                        | 247.7                    | 188              | 211    | 191                     | 187         | 193         | 189                 | -               | 11            | -                   | -  |                              |
| "        | 8/11/72 | 0848                        | 263.2                    | 187              | 209    | 190                     | 186         | 193         | 189                 |                 | 11            | -                   | -  |                              |
| "        | "       | 1734                        | 271.9                    | 191              | 209    | 194                     | 190         | 197         | 192                 |                 | 10            | -                   | -  |                              |
| "        | "       | 2138                        | 276.0                    | 192              | 212    | 194                     | 190         | 197         | 193                 |                 | 10            | -                   | -  |                              |
| "        | 8/13/72 | 1052                        | 313.2                    | 187              | 212    | 191                     | 186         | 193         | 189                 |                 | 10            | -                   | -  |                              |
| "        | 8/14/72 | 0841                        | 335.0                    | 187              | 211    | 191                     | 186         | 193         | 189                 |                 | 10            | -                   | -  |                              |
| "        | "       | 2012                        | 346.5                    | 193              | 2.2    | 196                     | 191         | 199         | 195                 |                 | 10            | -                   | -  |                              |
| "        | 8/15/71 | 0850                        | 359.3                    | 192              | 214    | 194                     | 190         | 198         | 194                 |                 | 10            | -                   | -  |                              |
| JEY      | 8/16/72 | 0830                        | 382.8                    | 190              | 211    | 194                     | 190         | 197         | 193                 |                 | 10            | -                   | -  | Removed 8 buckets condensate |
| GJV      | 8/17/72 | 0838                        | 407.0                    | 188              | 211    | 192                     | 187         | 194         | 190                 |                 | 10            | -                   | -  | Removed 8 @12:12p            |
| "        | 8/18/72 | 0836                        | 431.0                    | 190              | 211    | 193                     | 189         | 197         | 192                 |                 | 10            | -                   | -  |                              |
| "        | "       | 1728                        | 439.8                    | 191              | 211    | 194                     | 189         | 196         | 192                 |                 | 10            | -                   | -  |                              |
| "        | 8/19/72 | 2345                        | 470.1                    | 193              | 213    | 196                     | 190         | 198         | 194                 |                 | 10            | -                   | -  |                              |
| "        | 8/21/72 | 0847                        | 503.1                    | 190              | 210    | 193                     | 189         | 195         | 192                 |                 | 10            | -                   | -  |                              |
| "        | "       | 1707                        | 511.5                    | 192              | 216    | 195                     | 191         | 198         | 194                 |                 | 10            | -                   | -  |                              |
| "        | 8/22/72 | 0836                        | 527.0                    | 188              | 217    | 194                     | 189         | 197         | 192                 |                 | 10            | -                   | -  |                              |
| "        | "       | 1744                        | 536.1                    | 189              | 212    | 187                     | 185         | 184         | 187                 |                 | 10            | -                   | -  |                              |
| "        | 8/23/72 | 1759                        | 560.3                    | 189              | 213    | 193                     | 188         | 195         | 191                 |                 | 10            | -                   | -  |                              |
| "        | 8/24/72 | 0835                        | 574.9                    | 188              | 211    | 189                     | 188         | 189         | 188                 |                 | 10            | -                   | -  |                              |
| JEY      | 8/25/72 | 0930                        | 599.8                    | 190              | 211    | not legible on chart    |             |             |                     |                 | 10            | -                   | -  |                              |
| GJV      | "       | 1737                        | 608.0                    | 194              | 210    | 196                     | 195         | 197         | 196                 |                 | 10            | -                   | -  |                              |
| LEV      | 8/26/72 | 1415                        | 628.6                    |                  | 212    | 198                     | 203         | 203         | 102                 |                 | 11            | -                   | -  |                              |
| GJV      | 8/27/72 | 1317                        | 651.6                    | 195              | 210    | 195                     | 193         | 195         | 195                 |                 | 10            | -                   | -  |                              |
| JEY      | 8/28/72 | 0836                        | 670.9                    | 200              | 209    | 204                     | 204         | 204         | 203                 |                 | 11            | -                   | -  |                              |




### LIMITORQUE

| OPERATOR | DATE    | CLOCK TIME<br>(2400 hr.) | COUNTER TIME<br>(hr.) | TEMPERATURE (of)        |     |                     |             |             |                  | PRESSURE (PSIG) |            | REMARKS |                   |    |
|----------|---------|--------------------------|-----------------------|-------------------------|-----|---------------------|-------------|-------------|------------------|-----------------|------------|---------|-------------------|----|
|          |         |                          |                       | CHAMBER<br>TC #1 THERM. |     | COND-ENSAT<br>TC #2 | SWITCH COMP |             | LIMITORQUE MOTOR |                 | CHAM. GAGE |         | SWITCH COMP. GAGE |    |
|          |         |                          |                       |                         |     |                     | #1<br>TC #5 | #2<br>TC #7 | #1<br>TC #6      | #2<br>OMIT      |            |         | #1                | #2 |
| GJV      | 8/28/72 | 1803                     | 680.4                 | 200                     | 212 | 201                 | 190         | 196         | 194              | 10              | -          | -       |                   |    |
| "        | 8/29/72 | 0859                     | 695.3                 | 191                     | 213 | 197                 | 189         | 197         | 191              | 10              | -          | -       |                   |    |
| "        | "       | 1755                     | 704.2                 | 191                     | 210 | 196                 | 190         | 198         | 193              | 10              | -          | -       |                   |    |
| "        | 8/30/72 | 0838                     | 719.0                 | 200                     | 212 | 202                 | 202         | 203         | 199              | 10              | -          | -       |                   |    |
| "        | "       | 1454                     | 725.2                 | 191                     | 209 | 203                 | 203         | 205         | 205              | 0               | -          | -       | 5 mins. after     |    |

shutting air off,  
htrs.off,pwr.off,  
& removing con-  
densate while  
reducing press.  
to 0 psig.

|     |         |      |  |
|-----|---------|------|--|
| CFV | 8/30/72 | 1504 | Cover removed to autoclave   |
|     |         | -    | Picture taken  |
|     |         | 1530 | Switch comp. cover removed to new operator - a very strong noxious odor was evident immediately. |





## Appendix

### APPENDIX B

#### LIST OF INSTRUMENTS USED IN OBTAINING TEST DATA







## APPENDIX B

## LIST OF INSTRUMENTS USED IN OBTAINING TEST DATA

1. Honeywell-Brown Electronik 2-pen recorder, Model No. Y153X(22)-VV-X-IV-K-(G)(V), Ranges: 0 to 500°F with Type J thermocouples: 0 to 200 psig with Ametek Pressure Transducer. (Calibrated 4/13/72.)
2. Honeywell-Brown Electronik Multipoint Recorder, Model No. 15305846-24-02-2-000-030-10 097, 0 to 500°F with Type T Thermocouples. (Calibrated 4/13/72.)
3. Westinghouse Industrial Analyzer, Type PG-191, 25 to 150 Hz, Style 292B948A09. Connected for 25 A, 600 V, and 25 kW full-scale readings. (Calibrated 3/13/72.)
4. Westinghouse AC Wattmeter, Type PF-44, Style PH 10632N3 2, used in conjunction with Weston Potential Transformers, Model 311, No. 3283 and No. 3284, and Universal Current Transformers, Serial Nos. 56975 and 56976, for 25-kW full scale. (Calibrated 3/13/72.)
5. Sanborn 150, 4-channel recorder, with DC Coupling Pre-Amplifier, Model 150-300. (Calibrated 6/29/72.)
6. James G. Biddle Megger, Insulation Tester, No. 325603, 500 Vdc. (Calibrated 4/13/72.)
7. Ametek Pressure Transducer, Model 50-200-G-B/C. (Calibrated 12/16/71.)
8. 2 Giannini & Co. Pressure Transmitters, 0 to 300 psig. (Calibrated 7/30/72.)
9. Lonergan Maximon Gage, Type OA, 0 to 200 psig. (Calibrated 4/14/72.)



BWR Qualification

APPENDIX C

Reliance Electric Company  
Certificate of Compliance for Heat Aging



**RELIANCE ELECTRIC COMPANY**  
**CERTIFICATE OF COMPLIANCE**

Limitorque Corp.  
5114 Woodall Road  
Lynchburg Va. 24502

March 3, 1972

EQUIPMENT: Qty. 1, R56 Frame, 25 ft.lbs. Start Torque  
REFERENCE: Purchase Order No. 355696-A  
FILE: Order No. 601962-P

We certify that the equipment identified above has been designed, manufactured, inspected, and/or tested in accordance with the requirements established by the following specifications:

Insulation G.F.I. 226.59  
Finish G.F.I. 336.163  
Class H Radiation Insulation  
Heat aged 100 hrs. at 180°C  
Rotor treatment U-475 Varnish  
Winding Epoxy coated 4824-3A  
Drain in B.E. Shield - U.L. approved

*R.G. Lunsford*  
R.G. Lunsford, Manager  
Quality Control Department  
Madison, Indiana

(HPR) OIO VIND 1304 1115

RGL:st



BWR Qualification

APPENDIX D

Radiation International, Inc.  
Certification of Test Unit Irradiation





May 23, 1972

Mr. W. H. Steigelmann, Manager  
Nuclear Systems Laboratory  
Franklin Institute Research Laboratory  
20th and Race Streets  
Philadelphia, Pennsylvania . 19103

Dear Mr. Steigelmann:

This will summarize the parameters pertinent to the irradiation of Limitorque Corporation's materials, described below, per your Case C-3327.

Motor

|                           |   |                         |
|---------------------------|---|-------------------------|
| SN601962P                 | ) | Motor used in FIRL test |
| Reliance Electric Company | ) | report #F-C3441         |

Magnetic Brake and Motor

Motor: SN601960P  
Reliance Electric Company

Brake: Magnetic Brake  
Reliance Electric Company  
Model X7-62008-26  
SN-2-53276  
6 Ft.-Lb. Torque, 460V

Valve and Motor

Limitorque  
SMB Size 0  
SN 144068  
Motor - Limitorque  
Reliance Electric Company  
SN601961-P



Mr. W. H. Steigelmann

- 2 -

May 23, 1972


Components were placed in a cobalt-60 gamma field of 1.0 Mrad per hour intensity for a period of 4 hours, and received a total minimum dose of 4 Mrad. They were then shipped via RII truck to Ogden Technical Labs for testing. The units were then received for further irradiation, and were exposed in a 1.0 Mrad field for an additional 200 hours or 200 Mrad. Portions of the outer sides of the components received a 25% higher dose to assure that inner portions received the designated 204 Mrad. Components were turned several times during exposure to assure a more uniform dose distribution. Irradiation was in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but did not exceed 100°F, as confirmed by measurement of an oil solution in the same relative position.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on January 15, 1971 by the Victoreen Instrument Company, using cobalt-60 and cesium-137 sources whose calibrations are traceable to the U.S. National Bureau of Standards. A copy of the calibration certificate is available.

Following irradiation, components were visually inspected for obvious irradiation damage. None was noted.

Irradiation was completed on May 8, 1972 and picked up by FIRL May 9, 1972.

Very truly yours,

  
George R. Dietz  
Manager, Radiation Services

GRD:km



BWR Qualification

APPENDIX E

Ogden Technology Laboratories, Inc.

Seismic Test Report .



UNIVERSAL REPORT NO. \_\_\_\_\_  
ORIGINATORS REPORT NO. 7192-9  
REVISION \_\_\_\_\_

## REPORT OF TEST ON

OPERATOR VALVE  
P/N 144068  
TWO (2) 25' lb.motors

TEST PERFORMED BY Ogden Technology Laboratories, Inc.

TEST AUTHORIZED BY LIMITORQUE CORPORATION

CONTRACT NUMBER \_\_\_\_\_

PURCHASE ORDER NUMBER 360943

OTL JOB NUMBER 8909

|                                     | Date    | Signature          |             |
|-------------------------------------|---------|--------------------|-------------|
| Test Initiated                      |         |                    |             |
| Test Completed                      | 4/26/72 |                    |             |
| Report Written By                   | 9/26/72 | <i>H. Golinger</i> | H. Golinger |
| Technician                          |         |                    |             |
| Test Engineer                       | 9/26/72 | <i>H. Golinger</i> | H. Golinger |
| Supervisor Gen.Mgr.                 | 9/26/72 | <i>A. Helfand</i>  | A. Helfand  |
| Supervisor                          |         |                    |             |
| Quality Assurance                   | 9/26/72 | <i>J. Bonner</i>   | J. Bonner   |
| Government Repr.<br>(if applicable) |         |                    |             |
| Final Release                       |         |                    |             |
|                                     |         |                    |             |





## TABLE OF CONTENTS

## PAGE

|                               |     |
|-------------------------------|-----|
| Notices                       | iii |
| ADMINISTRATIVE DATA           | iv  |
| 1.0 TEST EQUIPMENT            | 1   |
| 2.0 TEST SEQUENCE             | 3   |
| 3.0 TEST PROCEDURE            | 4   |
| 3.1 Vibration Test            | 4   |
| 4.0 TEST RESULTS              | 5   |
| 4.1 Vibration Test            | 5   |
| 5.0 RECOMMENDATIONS           | 5   |
| APPENDIX A - Photographs      |     |
| APPENDIX B - Test Data Sheets |     |



### Notices

When Government drawings, specifications or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility nor any obligation whatsoever; and the fact that the Government may have in any way formulated, furnished, or supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation of conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.



## ADMINISTRATIVE DATA

TEST REPORT: 7I92-9

TEST CONDUCTED: Vibration Test

MANUFACTURER: Limitorque Corporation  
5114 Woodall Road  
Lynchburg, Va. 24502

MANUFACTURER'S TYPE OR MODEL NO.: Operator Valve, SMB-0-25, S/N 144068  
1 25' lb. motor with brake  
1 25' lb. motor without brake

DRAWING, SPECIFICATION OR EXHIBIT: Per P.O. 360943

QUANTITY OF ITEMS TESTED: Three (3)

SECURITY CLASSIFICATION OF ITEMS: Unclassified

DATE TEST COMPLETED: 26 April 1972

TEST CONDUCTED BY: Ogden Technology Laboratories, Inc.

DISPOSITION OF SPECIMENS: Returned to Limitorque Corporation

DATE OF TEST REPORT: 26 September 1972

MANUFACTURER'S PURCHASE ORDER NO.: 360943

ABSTRACT: Refer to Test Results, Para. 4.0.



- 1.0 TEST EQUIPMENT
- 1.1 Electro-Hydraulic Vibration Machine  
Ogden Technology Laboratories, Inc.  
Type: 6"/25K  
Calibration: None required
- 1.2 Data Track  
Research, Inc.  
Model: FGE-5110  
Calibration: Before each use
- 1.3 Servo Amplifier  
Moog  
Model: 82-104  
Calibration: None required
- 1.4 Function Generator  
Hewlett-Packard Corp.  
Model: 202A  
Calibration Interval: 6 months  
Last Calibration: 3/27/72
- 1.5 Recording Oscillograph  
Consolidated Electrodynamics Corp.  
Model: 5-124  
Calibration: System calibration prior to use
- 1.6 Signal Amplifier  
Unholtz-Dickie Corporation  
Model: 607-RMG-3A  
Calibration Interval: 6 months  
Last Calibration: 4/16/72





1.7      Accelerometer (5)  
          Endevco Corporation  
          Model: 2215C  
          Calibration Interval: 6 months  
          Last Calibration: 12/6/71

All instrumentation and equipment calibration is conducted in accordance with Specification MIL-Q-9858A as further defined in MIL-C-45662A "Calibration System Requirements" and is traceable to the National Bureau of Standards.



2.0 TEST SEQUENCE

2.1 Vibration Test



### 3.0 TEST PROCEDURE

#### 3.1 Vibration Test

Each of the three (3) test items was individually subjected to vibration testing along each of the three (3) mutually perpendicular axes over the frequency range of 1 to 35 Hz with a maximum acceleration of 1.0 g's in order to determine natural frequencies. Three (3) accelerometers were utilized to monitor for the presence of natural frequencies recorded upon a direct print oscillograph. Functional operation of each test item was performed by cognizant personnel of Limitorque Corporation.

At each noted natural frequency (if any) three (3) cycles of vibration at an excitation of 5.3 to 5.8 g's were performed. A one (1) minute rest period was allowed after each 3 cycles. If no natural frequencies were apparent (as was the case) a 10-second dwell was performed at 2, 4, 6, 9.....N Hz utilizing maximum available control displacement up to a cut-off level of 3 g's and at 5.3 to 5.8 g's at 35 Hz. Limitorque personnel monitored the equipment.



#### 4.0 TEST RESULTS

##### 4.1 Vibration Test

No apparent natural frequencies were determined as a result of this testing. In all cases for all test items vibration was applied at 3 g's for ten (10) seconds at all even numbered frequencies from 2 Hz to 34 Hz and at a level between 5.3 and 5.8 g's at 35 Hz.

Photographs of the test item set-ups are included in Appendix A.

There was no visible evidence of damage noted to any unit as a result of this test.

#### 5.0 RECOMMENDATIONS

None. Test results submitted herein are merely presented for your evaluation.






APPENDIX A  
Photographs




VALVE OPERATOR SMB-0-25

S/N 144068




Y AXIS




X AXIS



MOTOR WITH BRAKE




LATERAL AXIS



LONGITUDINAL AXIS





MOTOR WITHOUT BRAKE



LATERAL AXIS

VERTICAL AXIS



LONGITUDINAL AXIS





APPENDIX B  
Test Data Sheets



# DATA SHEETS

Ogden Technology Laboratories, Inc.

Job Number: 8809 Engineer: Salunga

Test: Unit Part No:

Test Technician: Unit Serial No:

Date Photo Taken: Date 4-23-77

X-Axis

Value Operator

2

6" dia

4

38

6

8

10

12

14

16

18

20

22

24

26

28

30

32

34

35

58

1500 - Y-axis - Value operator: start, mon. 1-34 Hz

1570 - start endurance

2

6"

18

38

34

3

4

3"

20

35

58

1/min

6

38

22

8

24

10

26

12

28

14

30

16

32



# DATA SHEETS

Ogden Technology Laboratories, Inc.

Job Number: 8909 Engineer: Salinger  
 Test: VIBRATION Unit Part No: SMVD-25  
 Test Technician: WS Unit Serial No: 144068  
 Date Photo Taken: 4-24-72 Date: 4-24-72

0800-1100 - set up in Vertical (z) Value operator  
motor up brake  
 1 Hz → 2 Hz @ 6" & a  
 2 Hz → 34 Hz @ ±1g  
 1100 Start scan  
 1107 - Completed  
 1107 - Start 10 second dwell at  
 2 Hz - 6" & a  
 4 Hz - 3g  
 6 Hz - 3g  
 8 Hz - 5.5g  
 10 Hz - 5.5g  
 12 Hz - 5.3g  
 14 Hz - 5.4g  
 16 Hz - 3g  
 18 Hz - 3g  
 20 Hz - 3g  
 22 Hz - 3g  
 24 Hz - 3g  
 26 Hz - 3g  
 28 Hz - 3g  
 30 Hz - 3g  
 32 Hz - 3g  
 34 Hz - 3g  
 35 Hz - 5.3g  
 1300 - Changing Value operator to X axis - motor  
 with brake in Z axis  
 1355 - Start scan - 1 to 34 Hz

Accel #1 - control line  
 #2 - motor end  
 #3 - handwheel end



# DATA SHEETS

Ogden Technology Laboratories, Inc.

Job Number:..... *8909* ..... Engineer:..... *Selene* .....

Test:..... Unit Part No:.....

Test Technician:..... Unit Serial No:.....

Date Photo Taken:..... Date *4-26-72* .....

0800 - Motor set in long axis - start scan

0815 - Completed - non op.

0830 - Completed resonance dwell - 2-34 @ 3g  
motor running. 35 @ 5g

accel 1 - control

accel 2 - shaft end

accel 3 - rear end

0900 - Changing to motor with brake

0940 - Start 1g scan 1 Hz to 34 Hz

accel 3 - brake end

0945 - Completed - non operating

0946 - Start 2-34 Hz @ 3g 35 Hz @ 5g

1000 - Completed - unit operating

1300 - Charged motor with brake to 32 axis

1330 - Completed all testing on this unit

1430 - Start survey on motor with brake

accel #3 on end of motor

1500 - Completed all testing on this unit

No visible damage noted on any unit.





APPENDIX C

PWR Containment Qualification

Report 600456



NUCLEAR POWER STATION  
QUALIFICATION TYPE TEST REPORT  
LIMITORQUE VALVE ACTUATORS  
FOR PWR SERVICE  
PROJECT #600456

Tested per IEEE Standard 382-1972  
Test Performed 7 June 1974 to 22 November 1974

Prepared by Limitorque Corporation  
Test Laboratory

Prepared by Walter L. Sykes  
Walter L. Sykes  
Test Engineer  
Date 12/9/75

Approved W. J. Denkowski  
W. J. Denkowski  
Chief Engineer  
Date Dec 9, 75



TABLE OF CONTENTS

|       |   |         |
|-------|---|---------|
| 1.0   | Introduction .....                            | page 1  |
| 2.0   | Identification of Sample Valve Actuator ..... | page 1  |
| 3.0   | Type Test Procedure .....                     | page 2  |
| 3.1   | Aging Simulation                              |         |
| 3.1.1 | Thermal Aging                                 |         |
| 3.1.2 | Mechanical Aging                              |         |
| 3.1.3 | Radiation Aging                               |         |
| 3.2   | Seismic Qualification                         |         |
| 3.3   | Radiation Exposure                            |         |
| 3.4   | Accident Simulation                           |         |
| 3.4.1 | Test Description                              |         |
| 3.4.2 | Test Procedure for LOCA Test                  |         |
|       | Figure 5 - Specified Accident Profile         |         |
| 3.5   | Post Test Inspection                          |         |
| 3.6   | Post LOCA Load Cycling Test                   |         |
| 3.7   | Final Inspection                              |         |
| 4.0   | Test Results .....                            | page 11 |
| 4.1   | Mechanical Aging                              |         |
| 4.2   | Seismic Qualification                         |         |
| 4.3   | Radiation Aging & Exposure                    |         |



TABLE OF CONTENTS (cont.)

|       |   |         |
|-------|---|---------|
| 4.4   | Accident Environmental Simulation Test Results            |         |
| 4.4.1 | Temperature and Pressure Profile                          |         |
|       | Figure 6 - Actual Accident Profile                        |         |
|       | Figure 7 - 1st Transient PWR Profile                      |         |
|       | Figure 8 - 2nd Transient PWR Profile                      |         |
| 4.4.2 | Chemical Spray Delivery                                   |         |
| 4.4.3 | Chamber Humidity  |         |
| 4.4.4 | Insulation Resistance Measurements                        |         |
|       | Table II - Insulation Resistance of Power & Control Leads |         |
| 4.4.5 | Actuator Cycling Data                                     |         |
|       | Table III - Valve Actuator Cycling Data                   |         |
| 4.5   | Post LOCA Inspection                                      |         |
|       | Figure 9 - Post LOCA Conditions (photograph)              |         |
| 4.6   | Post LOCA Load Cycling                                    |         |
| 4.7   | Final Inspection Results                                  |         |
| 4.7.1 | Motor Inspection and Dismantling                          |         |
| 4.7.2 | Valve Actuator Inspection and Dismantling                 |         |
|       | Figure 10 - Test Unit Final Inspection (photograph)       |         |
| 5.0   | Conclusion .....  | page 28 |





APPENDICES

- APPENDIX A - Reliance Electric Company's Certificate of Compliance
- APPENDIX B - Mechanical Aging, Load Cycling and Thrust Measurements
- Appendix C - Certificate of Compliance from Isomedix Corporation
- APPENDIX D - Lockheed Environmental Labs' Seismic Report No. 3521-4811
- APPENDIX E - Figure 1 - Test Chamber  
Figure 2 - Steam Generator  
Figure 3 - Control & Instrumentation Panel
- APPENDIX F - Figure 4 - Schematic - Instrumentation and Power System  
Table I - Summary of Data Acquisition System



2

## PWR Qualification

### 1.0 Introduction

A typical Limitorque Valve Actuator, SMB-0 with a 40 ft-lb motor (SMB-0-40) was submitted for qualification to the type test specified by IEEE std. 382- '72' for service in a Presurized Water Reactor (PWR) containment chamber in Nuclear Power Station application.

The SMB-0-40 Valve Actuator was subjected to mechanical aging simulation to approximate 40 years service life, radiation exposure (Both Normal Life levels plus accumulative doses) and other environmental conditions all as indicated in IEEE Std. 382-'72'. Additional load cycling was performed after LOCA environmental conditions to determine the post accident abilities of the valve actuator.

### 2.0 Identification of Sample Valve Actuator

#### TEST UNIT

A limitorque SMB-0 Nuclear Valve Actuator with a 40 ft-lb nuclear containment motor (RH Insulation Class) was constructed per standard nuclear bill of materials and standard nuclear motor specifications. The following information was taken from the identification tags:



## PWR Qualification

Valve Actuator Type/Size .....SMB-0

Manufacturer .....Limitorque Corporation

Order Number .....600456-A

Serial Number .....189835

### Electric Motor Information:

Size .....40 ft-lb stall  
8 ft-lb run

Manufacturer .....Reliance Electric Company

Identification number .....2Y267074A1EZ

Full Load Speed .....1735 RPM

Frequency .....60 Hz

Voltage .....460 Volts

Insulation Class .....RH

Type .....P

### 3.0 Type Test Procedure

The type test plan as described in IEEE Std. 382-'72', paragraph 4, consists of three basic parts:

1. Aging Simulation
2. Seismic Qualification
3. Accident Environmental Simulation



## PWR Qualification

As an added test margin, the test actuator was submitted to additional load cycling after completion of all the required environmental conditions and prior to final inspection. This additional load cycling is not a requirement of IEEE Std. 382-'72'. A base test motor was processed with the Test Unit for additional engineering information.

### 3.1 Aging Simulation (IEEE Std. 382 para. 4.2)

#### 3.1.1 Thermal Aging

Thermal aging was performed on the motor stators by the motor manufacturer (Reliance Electric Company) in cooperation with Limitorque Corporation.

The motor stator was heat aged for 100 hours at 180<sup>o</sup> C. A certificate of compliance was supplied by Reliance Electric Company verifying the thermal aging of the stator (see Appendix A.)

#### 3.1.2 Mechanical Aging

Mechanical Aging was performed on the Test Unit by the Limitorque Test Laboratory. Data on the Aging & Post test Cycling is presented in Appendix B. Although IEEE Std. 382-'72' requires 500 cycles, the unit was cycled thru 1208 cycles,





## PWR Qualification

each cycle consisting of one close stroke and one open stroke at room ambient conditions. The Limit-torque Valve Actuator was seated at the end of the close stroke and the seating thrust monitored. The thrust applied was equivalent to the thrust & torque ratings of the SMB-0 actuator. A typical stroke time of 40 sec. was chosen for the actuator operating time.

- 3.1.3 Radiation Aging (IEEE Std. 382-'72' Part II Section 1)  
The Aging dose of 4 Megarads was combined with the accident dose (200 Megarad) per IEEE Std. 382-'72' part III and is discussed in the following section 3.3 of this report.

### 3.2 Seismic Qualification (IEEE Std. 382 Para. 4.3)

The Seismic Qualification was performed by Lockheed Electronics, Inc. Environmental Laboratory on a Reaction Vibration machine. The Test Unit with motor, was scanned in each of the three major axis over a frequency range of 5 to 35 Hz to search for resonance. No resonance was found.



## PWR Qualification

The Valve Actuator was mounted on a test fixture to provide simulated valve seating loads, during the dwell portions of the seismic qualifications. The load imposed was equal to the rating of the test actuator.

The vibration machine was adjusted to a displacement (0.050" D. A.) equivalent to 3 g's acceleration at a frequency of 35 Hz. The test sample was then vibrated for a period of ten (10) seconds at each even integer of frequency from 6 Hz to 34 Hz. The unit was operated during the dwell through one cycle from open limit-to-torque switch seated position and back to original point. The vibration machine was adjusted to a displacement (0.100" D. A.) equivalent to 6 g's acceleration at a frequency of 35 Hz. The test sample was then vibrated for a period of ten (10) seconds at 35 Hz and operated during the dwell.

The dwell tests above were performed in each of the three major axis. A report on the Seismic Qualification was prepared by Lockheed Electronics Corporations Environmental Laboratory (Report No.3521-4811 and is presented in Appendix D.) The duration of each stroke was 40 seconds.



## PWR Qualification

### 3.3 Radiation Exposure (IEEE Std. 382 Part II Section 1)

The Limitorque Actuator and motor were subjected to a Gamma Ray Irradiation of 204 Megarads per IEEE Std. 382-'72' requirements.

The Test Unit was placed in a Cobalt-60 and Cesium-137 field of 1 Mrad/hour at an air equivalent dose.

A total radiation dose of 204 Megarads was applied after thermal aging, mechanical aging and seismic qualification.

The radiation exposure was performed by Isomedix Corporation. A Test Certification was supplied by Isomedix Corporation and is presented in Appendix C.

### 3.4 Accident Simulation (IEEE Std. 382-'72')

#### 3.4.1 Test Description

The test was performed at Limitorques' Environmental Test Facility, see figures 1, 2 and 3 in Appendix E. A schematic of the instrumentation system and a summary of instruments used during the test are presented in Figure 4 and Table I located in Appendix F. The limitorque Actuator was mounted on a thrust tube attached to the side of the test chamber with the stem thrusting against the load cell mounted



## PWR Qualification

externally to the test chamber. (see Figure 1, Appendix E)

Control and power lead connections were made through flexible pressure tight conduit. connections run between the units and the access ports of the test chamber. The external wire harness was run to a junction box, where terminal strips provided access to each lead for monitoring insulation resistance. The terminal strips were wired to a control system (see Figure 4, Appendix F). The control panel illustrated in Figure 3, (Appendix E) contains a power monitoring system to monitor line voltage, current in each of the three (3) motor legs and the power consumption of the motor.

Pressure and temperature were monitored on the multipoint temperature recorder and strip chart recorder mounted on the test console (Figure 3, Appendix E). In addition to the automatic monitoring system, the temperature and pressure was monitored by a pressure gauge and two thermometers mounted in the side wall of the test chamber (see Figures 1 and 4.)





## PWR Qualification

During the rapid temperature and pressure transients, the chamber ambient and limit switch compartment internal temperature and pressure were monitored continuously on the strip chart recorder.

Cooling coils mounted inside the chamber provided cooling capacity to reduce the temperature in the chamber to the various temperature plateaus.

A double spray system provided a reliable source of chemical spray during the test profile. Flow meters mounted on the panel near the test chamber (see Figure 1, Appendix E) monitored the chemical fluid flow. Spray nozzles mounted on two sets of manifolds (3 nozzles per manifold) with the ability to switch manifold provided the proper spray pattern. The pressure in each active manifold set was monitored to indicate any restriction of the spray nozzle orifice. A back flush system was provided to back flush the spray manifold.

### 3.4.2 Test Procedure for LOCA Test

The Limitorque Valve Actuator was exposed to steam and chemical spray in accordance with the



## PWR Qualification

criteria listed in Table 1 in the "IEEE Guide for Type Test of Class 1 Electric Valve Operators for Nuclear Power Generating Stations" IEEE Std. 382-'72'. The temperature/pressure profile is illustrated in Figure 5, which also shows the schedule for measuring the insulation resistance of the power and control leads and cycling of the Limitorque Valve Actuators.

During the first four days of the test, the specified temperature and pressures were maintained by the controlled injection of steam into the test chamber. During the remainder of the test, the 200 F/10 psig state was maintained by filling the test chamber with air controlled to the proper pressure and using electrical heaters. The atmosphere was kept saturated with water vapor by maintaining condensate in the bottom of the tank and by daily injections of steam.

### 3.5 Post Test Inspection

A visual inspection of the limit switch compartment and the limit and torque switches was performed at the conclusion of the accident simulation.



# Specified Accident Profile

Temperature  
°F

Take Insulation  
readings and operate  
Valve Control




Figure 5



## PWR Qualification

### 3.6 Post LOCA Load Cycling Test

Similar to that performed at pre-test mechanical aging, the unit was cycled for a total of 794 cycles (one close & one open stroke per cycle) at room ambient conditions (data supplied in Appendix B).

### 3.7 Final Inspection

A complete physical inspection of the test samples was made after the completion of the Post LOCA Load Cycling to observe the conditions of the actuator.

## 4.0 Test Results

### 4.1 Mechanical Aging

The unit was initially tested on 7 June 1974 and a thrust output of 20,162 lbs. was obtained at a torque switch setting of 1-3/4. (This value is an average of 24 readings.) The unit remained on the test stand and was automatically cycled at room ambient conditions.

The cycling test was performed from 7 June 1974 to 10 June 1974 for a total of 1208 cycles consisting of one torque switch closure in each cycle.

The load was measured after the completion of the mechanical aging and an average of 10 readings produced a thrust output of 19,920 lbs.





## PWR Qualification

The test data obtained is presented in Appendix C.

### 4.2 Seismic Qualification

The Seismic Qualification was performed at Lockheed Electronics Environmental Laboratory on 12 June 1974. The data recorded is presented in Lockheed test Report No. 3521-4811. (Appendix D.) The thrust load was not monitored during seismic testing; however, thrust readings taken after seismic and radiation, 19,350, average of three readings, was within three (3) percent of the post mechanical aging value. The output characteristics did not change during seismic testing or irradiation. The valve actuator and its limit and torque switch functioned during seismic testing.

### 4.3 Radiation Aging & Accident Exposure

The exposure to radiation of the Test Unit was performed on 18 July 1974 at Isomedix Corporation. A total dose of 204 Megarads was used. A Test Certification may be found in Appendix C.

### 4.4 Accident Environmental Simulation Test Results

The LOCA Test was performed at Limitorgues' Environmental Test Facility. The environmental test was started 22 August 1974 and completed 21 September 1974.



## PWR Qualification


### 4.4.1 Temperature and Pressure Profile

The profile specified in paragraph 3.2.5 of this report was closely followed as evidenced in Figure 6. The transient data was obtained by means of the strip chart recorder. At the transient time of ten (10) seconds, the temperature was a temperature within 91% of the specified temperature (300<sup>o</sup> F.) A temperature of 300<sup>o</sup> F was reached in 15.2 seconds. The second transient closely approximated the first reaching a temperature of 300<sup>o</sup> F in 13.8 seconds. Copies of the actual strip chart data are presented in Figures 7 & 8.

After the transient and a dwell of 30 minutes at 300<sup>o</sup> F, the test ambient was brought to a stable condition of 250<sup>o</sup> F and 30 psig. The actual temperature conditions were within minus 2% and plus 6% of specified temperature and the pressure conditions were within plus or minus 3.5%. These conditions were maintained for the balance of four (4) days.


At a test time of 96.1 hours (approx. 4 days) the test ambient was lowered to 200<sup>o</sup> F and 10 psig. The chamber was maintained at these conditions by means






**FIGURE 6**






Ambient  
Side of Chamber



Test Unit  
Limit Switch  
Compartment

Ambient  
Top Rear of  
Chamber

Ambient  
Side of Chamber




Test Unit  
Limit Switch  
Compartment

Ambient  
Top Rear of  
Chamber


Figure #7








Ambient  
Side of Chamber



Test Unit  
Limit Switch  
Compartment

Ambient  
Top Rear of  
Chamber

Ambient  
Side of Chamber



Test Unit  
Limit Switch  
Compartment

Ambient  
Center Line  
near Rear

Figure #8



## PWR Qualification

of strip heaters and air injection through a pressure controlled solenoid valve. Once stability was reached, the ambient was maintained within plus 0% and minus 4% of specified temperature and plus 10% and minus 0% of specified pressure.

### 4.4.2 Chemical Spray Delivery

The chemical mixture (per Table 1 of TEEStd. 382-page 12) was prepared prior to start of the LOCA test and pH values measured. Tank No. 1 had a pH of 10.9 after initial mixing. Tank No. 2 had a pH of 10.5 after initial mixing. The pH was monitored on a sample taken from Tank No. 1 at a test time of 0.1 hours (pH=11.1) and after 4.4 hours (pH=11.1). A sample of Tank No. 2 taken at 24 hours had a pH reading of 10.5.

The chemical flow was maintained at 0.6 gal/min in each spray manifold or an overall flow rate of 1.2 gal/min. A check was made of the average flow rate by recording the total amount of chemical solution used in a given period of time. These average flow rates agreed with the recorded instantaneous flow rates.



## PWR Qualification

### 4.4.3 Chamber Humidity

The relative humidity of the chamber was maintained at 100 percent by the periodic injection of steam and by maintaining the vapor condensate at the bottom of the chamber at the same temperature as the air/vapor mixture. The content of air in the air vapor mixture was minimized by venting the chamber during the thermal transients.

### 4.4.4 Insulation Resistance Measurements

Insulation resistance measurements to ground were made periodically on the power and control leads of the Test Unit prior to operating the valve actuator (see Table II.)

### 4.4.5 Operator Cycling Data

The test unit functioned without problems throughout the entire test. It is worthy to mention that during the final operational cycle (719.1 hours) the close indicating light exhibited a very dim glow when it should have been extinguished. This phenomena was noticed only on the "close" light circuit and no other indicating lights or circuits



TABLE II

## Insulation Resistance of Power and Control Leads

(All resistances are in Megohms except where a K indicates Kilo-ohms)

(all measurements made to ground)

| Time<br>After<br>Start<br>Test<br>(hr.) | MOTOR<br>LEADS |      |      | CONTROL CIRCUIT LEADS |      |      |      |      |      |      |      |      |      |      |      |      |      |      |
|---|----------------|------|------|-----------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
|   | T-1            | T-2  | T-3  | CL-1                  | 61   | 71   | 41   | 43A  | 43B  | 43C  | 45A  | 45B  | 51   | 53A  | 53B  | 53C  | 55A  | 55B  |
| *0                                      | 400            | 400  | 400  | 180                   | 180  | 180  | 2000 | 180  | 180  | 180  | 180  | 180  | 180  | 190  | 180  | 180  | 180  | 180  |
| 0.15                                    | 160K           | 160K | 160K | 300K                  | 400K | 400K | 40.0 | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K |
| 0.5                                     | 120K           | 120K | 120K | 280K                  | 280K | 280K | 5.0  | 280K | 280K | 280K | 280K | 280K | 280K | 280K | 280K | 280K | 280K | 280K |
| 3.9                                     | 100K           | 100K | 100K | 2.0                   | 2.0  | 2.0  | 6.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  | 2.0  |
| 4.2                                     | 50K            | 50K  | 50K  | 400K                  | 400K | 400K | 2.4  | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K | 400K |
| 95.5                                    | 80K            | 80K  | 80K  | 2.0K                  | 2.0K | 3.0K | 40K  | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K | 2.0K |
| 334.9                                   | 60K            | 60K  | 60K  | 1.5K                  | 1.5K | 2.0K | 5.0K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K | 1.5K |
| 719.1                                   | 60K            | 60K  | 60K  | 2.0K                  | 2.0K | 3.0K | 5.0K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K | 1.7K |

\*Check prior to start of test.





## PWR Qualification

exhibited these characteristics. Subsequent investigation concluded that the current flow through this light to duplicate the dim glow was insignificant and coupled with its occurrence in the final hour of a 30 day test did not constitute a malfunction.

The megger readings diminished during the environmental test and the current & power requirements did increase slightly as the test in the environmental chamber continued; however, this had no effect on the actuator performance. The stroke time remained constant throughout the test.

Also a slight variation in the measured output thrust was noted and was attributed to a change in stem efficiency rather than actuator output torque change. It was noted that during periods of non-operation, the thrust tended to become lower, whereas during periods of frequent operations, the thrust increased. Probably, the ambient temperature & moisture effected the lubricity of the lubricant used on the stem.

A summary of the cycling data is presented in Table III.



TABLE

## VALVE ACTUATOR CYCLING DATA

| Time After Start of Test (hr.) | Potential (volts) |            |            | OPEN STROKE        |     |     |               |                    | CLOSE STROKE       |     |     |                             |               |       |                    |                      |
|--------------------------------|-------------------|------------|------------|--------------------|-----|-----|---------------|--------------------|--------------------|-----|-----|-----------------------------|---------------|-------|--------------------|----------------------|
|                                |                   |            |            | Run Current (Amps) |     |     | Power (Watts) | Stroke Time (Secs) | Run Current (Amps) |     |     | Peak Current * (Amps) (T-3) | Power (Watts) |       |                    |                      |
|                                | T-1<br>T-3        | T-1<br>T-2 | T-2<br>T-3 | T-1                | T-2 | T-3 |               |                    | T-1                | T-2 | T-3 |                             | Run           | *Peak | Stroke Time (Secs) | Seating Thrust (lbs) |
| ** 0                           | 490               | 495        | 490        | 4.6                | 4.8 | 4.6 | 620           | 42                 | 4.6                | 4.8 | 4.4 | 5.0                         | 620           | 1350  | 42                 | 19,375               |
| .3                             | 475               | 480        | 480        | 4.5                | 4.6 | 4.5 | 620           | 42                 | 4.3                | 4.3 | 4.2 | 5.1                         | 600           | 1300  | 43                 | 19,425               |
| .6                             | 485               | 490        | 485        | 4.7                | 4.8 | 4.6 | 680           | 42                 | 4.8                | 4.9 | 4.5 | 5.1                         | 680           | 1320  | 43                 | 20,825               |
| 4.1                            | 485               | 490        | 485        | 4.8                | 4.9 | 4.6 | 620           | 42                 | 4.8                | 5.0 | 4.6 | 5.1                         | 610           | 1300  | 43                 | 21,600               |
| 4.3                            | 490               | 490        | 480        | 4.8                | 5.0 | 4.7 | 650           | 42                 | 4.8                | 5.0 | 4.6 | 5.1                         | 640           | 1350  | 43                 | 22,150               |
| 95.5                           | 495               | 500        | 495        | 5.1                | 5.2 | 5.0 | 725           | 42                 | 5.2                | 5.3 | 4.9 | 5.3                         | 750           | 1500  | 43                 | 22,650               |
| 335.4                          | 485               | 490        | 485        | 4.8                | 4.9 | 4.6 | 650           | 41                 | 4.9                | 5.0 | 4.6 | 5.0                         | 650           | 1400  | 42                 | 21,600               |
| 719.1                          | 495               | 500        | 490        | 4.9                | 5.2 | 4.9 | 675           | 42                 | 5.0                | 5.2 | 4.7 | 5.0                         | 675           | 1500  | 42                 | 18,550               |
| 719.5                          | 495               | 500        | 490        | 5.0                | 5.2 | 4.9 | 700           | 42                 | 5.0                | 5.2 | 4.7 | 5.6                         | 675           | 1900  | 42                 | 21,350               |

\* Due to rapid rise of current and power, considering the slow meter response times, these values to be considered as approximation of actual peak.

\*\* Check prior to start of test.



## PWR Qualification

### 4.5 Post LOCA Inspection

The post LOCA Inspection was performed 21 September 1974 after opening the test chamber. Photographs were taken of the test unit with the limit switch compartment cover in place (see Figure 9). Externally, the Test Unit was clean looking with no unusual deposits. The limit switch compartment had approximately one-eighth ( $1/8$ ) of an inch of condensate in the bottom of the compartment.

Both the limit and torque switches were clean and functioned without mechanical difficulties. The motor lead protective sleeving was split in several areas; however, no damage was noted to the motor lead insulation.

### 4.6 Post LOCA Load Cycling

The post LOCA Load Cycling was performed by the Limitorque Test Laboratory from 30 September 1974 to 4 October 1974.

The thrust output of the Test Unit was measured prior to the start of the load cycling. The thrust output was found to be 16,392 (an average of 6 readings). This was accomplished at the same torque






Figure 9 Post LOCA Conditions





## PWR Qualification

### 4.7 Final Inspection and Dismantling

#### 4.7.1 Motor Inspection and Dismantling

The motor (used with the test unit during LOCA test) mounted on the Test Unit was removed from the SMB valve actuator and dismantled for inspection. The inspection was performed on 21 November 1974 with representatives from Reliance Electric Company in attendance.

The rotor turned freely prior to dismantling the motor. The stator and rotor showed little evidence of corrosive build-up and no evidence of physical damage. The end bell was particularly clean with little evidence of water. The bearing lubricant was moist and the bearing turned freely.

#### 4.7.2 Valve Control Inspection and Dismantling

The SMB-0-40 Valve Actuator was completely dismantled for inspection on 22 November 1974. Photographs of the valve actuator components are presented in Figure 10.

The torque switch and limit switch were removed from the SMB-0 Valve Actuator and the



## PWR Qualification

switch setting (1-3/4) as that used throughout the test.

The torque output of the actuator as controlled by the torque switch remains constant with the same torque switch setting, however, the thrust monitor in the test stem depends upon several factors including the efficiency of the acme threads. The lower thrust output monitored after the unit was brought to room temperature was attributed to a degradation of stem efficiency as a result of corrosion of the steel stem and deposition of foreign materials from the exposure to the steam and chemical spray and not attributable to changes in the torque switch operating train or reduction in the torque output of the actuator.

The effect of the corrosion was most noticeable after the stem was exposed to room ambient conditions for several hours. After the completion of the 794 cycles, the thrust monitored returned to its original value indicating the repeated cycling had removed the corrosive deposits in the stem thread area. The cycling data and thrust reading are presented in Appendix B.



## PWR Qualification

A Base Test motor which experienced all the environmental conditions was installed on the test actuator after the planned post LOCA cycling to obtain cyclic information on the base motor and provide additional load cycling on the test unit. The SMB-0 Actuator (with the base test motor) was cycled for an additional 2184 cycles.

The SMB-0 Actuator functioned without difficulty throughout the additional 2184 cycles.

A summary of the load cycles accumulated on the test unit is as follows:

|                                  |                    |
|----------------------------------|--------------------|
| PreTest Mechanical Aging ::..... | 1208 cycles        |
| LOCA Testing cycles .....        | 9 cycles           |
| Post LOCA Load cycling .....     | 794 cycles         |
| Base Test Motor cycling .....    | <u>2184</u> cycles |
| TOTAL                            | 4195 cycles        |






Figure 10  
Test Unit Final Inspection





## PWR Qualification

following observations were made:

- a.) The torque switch and limit switches worked freely.
- b.) The torque switch and limit switch pinions both showed signs of lubrication.

The grease in the main housing and the handwheel clutch compartment was dark in color but maintained its lubricity. A slight amount of separation of the grease was noted. The O-Ring and bearings seemed in good condition with no wear noted.

### 5.0 Conclusion

The Limitorque Valve Actuator SMB-0-40 was subjected to a qualification test consisting of a 30-day exposure to a steam chemical environment, including two temperature & pressure transients from 120 degrees F to 300 degrees F in approximately 10 seconds. Prior to environmental testing, the motor was heat aged, the unit was mechanically tested and subjected to gamma ray irradiation. The unit was cycled with simulated valve seating loads during environmental testing at elevated temperatures and pressures and after environmental test was additionally cycled with a simulated valve seating load.



## PWR Qualification

Since the unit performed satisfactorily, throughout the test, it is concluded this test qualifies similar Limitorque Valve Actuators for use in a PWR containment chamber where environmental conditions depicted by Table I in IEEE Std. 382-'72' are encountered.



PWR Qualification

APPENDIX A

Reliance Electric Company - Certificate  
of Compliance




**RELIANCE ELECTRIC COMPANY**

**CERTIFICATE OF COMPLIANCE**



Limitorque Corporation  
5114 Woodall Road  
Lynchburg, Virginia 24502



EQUIPMENT: Electric Motor  
REFERENCE: Purchase Order No. 600426-C  
FILE: Sales Order No. 2Y-267074A1

We certify that the equipment identified above has been designed, manufactured, inspected, and/or tested in accordance with the requirements established by the following specifications: RCP-242, Limitorque D/S 21-49-001-1  
We further certify that the stator was heat aged 100 hours at 180°C.

*B. L. Hoskins*

Quality Control Department





PWR Qualification

APPENDIX B

INITIAL TORQUE SWITCH SETTING

MECHANICAL AGING


POST MECHANICAL AGING THRUST MEASUREMENT

POST SEISMIC QUALIFICATION AND RADIATION THRUST MEASUREMENT

POST ENVIRONMENTAL THRUST MEASUREMENT

POST ENVIRONMENTAL LOAD CYCLING

POST LOAD CYCLING THRUST MEASUREMENT



# SUMMARY OF LOAD CYCLING DATA

Specimen: TEST UNIT

Limtorque Valve Actuator

Type: SMB

Size: O

Serial No. 189835

Motor size 40 ft-lb

I. D. #2Y267074ALEZ

Instrumentation:

Load Cell: Capacity 20, 000 pounds

Manufacturer BLH

Serial No. 2512

Strain Indicator:

Manufacturer BLH

Type N

Serial No. 443604

## INITIAL TORQUE SWITCH SETTING

Date: 6/7/74

| No. of Readings | Torque Switch Setting | Thrust Output *<br>(pounds) |
|-----------------|-----------------------|-----------------------------|
| 5               | "1"                   | 11,070                      |
| 5               | "1½"                  | 16,010                      |
| 24              | "1 3/4"               | 20,162                      |

\*Average of all readings

## MECHANICAL AGING

Date: 6/7/74 to 6/10/74

Definition: One (1) cycle

Open Limit actuation to close torque

Switch actuation to open limit

actuation. Two (2) strokes per cycle.

Stroke Time: 54 sec \*

Cycle Time: 1 min. 53 sec

Duty Cycle: 'RUN' 7 cycles - 'OFF' 10 min.

Load (Thrust): 20,162 pounds

Total No. of Cycles: 1208



SUMMARY OF LOAD CYCLING DATA (continued)

- \* The unit was cycled for mechanical aging on a different load stand than was used in the test and since the stroke was longer in this stand, a longer stroke time was obtained.

POST MECHANICAL AGING THRUST MEASUREMENT

Date: 6/10/74

| No. of Readings | Torque Switch Setting | Thrust Output *<br>(pounds) |
|-----------------|-----------------------|-----------------------------|
| 10              | "1 3/4"               | 19,920                      |

POST SEISMIC QUALIFICATION AND RADIATION THRUST MEASUREMENT Date: 8/19/74

| No. of Readings | Torque Switch Setting | Thrust Output *<br>(pounds) |
|-----------------|-----------------------|-----------------------------|
| 3               | "1 3/4"               | 19,250                      |

\* Average of all readings

POST ENVIRONMENTAL TEST THRUST MEASUREMENT

Date: 9/30/74

| No. of Readings | Torque Switch Setting | Thrust Output *<br>(pounds) |
|-----------------|-----------------------|-----------------------------|
| 6               | "1 3/4"               | 16,392                      |

Note: The low output thrust readings are a result of poor stem efficiency as a result of accumulated deposits on the acme threads of the stem. The thrust measured during the last test point of the environmental test was 21,350 pounds.



SUMMARY OF LOAD CYCLING DATA (continued)

POST ENVIRONMENTAL LOAD CYCLING

Date: 9/30/74 - 10/4/74

Definition: One (1) cycle  
Open limit to close torque switch  
actuation to open limit. Two (2)  
strokes per cycle.  
Stroke Time: 40 sec  
Duty Cycle: 'RUN' 7 cycles - 'OFF' 10 minutes  
Load (Thrust): 16,392 at start  
19,667 at finish  
Total No. of Cycles: 794

Note: The increase in thrust output is due to improved  
stem efficiency. The repeated cycling removed  
the corrosion in the threaded area of the stem.

The load cycling was discontinued during the  
night and ran during the first shift.

POST LOAD CYCLING THRUST MEASUREMENT

Date: 10/4/74

| No. of Readings | Torque Switch Setting | Thrust Output<br>(pounds) |
|-----------------|-----------------------|---------------------------|
| 3               | "1 3/4"               | 19,667                    |

Note: The output thrust returned to the value recorded  
after the pre-test mechanical aging.





PWR Qualification

APPENDIX C

Radiation Exposure - Isomedix Certificate of Performance





July 19, 1974

Mr. W. J. Denkowski  
Chief Engineer  
Limitorque Corporation  
181 South Gulph Road  
King of Prussia, Pa. 19406

Dear Mr. Denkowski:

This will summarize the perimeters pertinent to the irradiation of one valve operator and motor assembly. Identification on the valve operator and motor assembly was:

SMB O Valve Control  
s/n 189835  
Reliance 40 lb-ft motor  
I.D. 2Y267074A1EZ

Units were placed in a co-60 field of  $1 \times 10^6$  rad per hour, at an air equivalent dose. They were rotated several times during the exposure to achieve a more uniform dose distribution. Total dose received to the centerline of the unit was 204 mrad (air equivalent) with an overdose factor on the edges of the units of 1.2. Irradiation was in air and ambient temperature in a slight negative pressure. The temperature of the samples during irradiation did not exceed 100°F.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on January 15, 1974 by the Victoreen Instrument Company, using Cobalt-60 and Cesium-137 sources whose calibrations are traceable to the U.S. National Bureau of Standards. A copy of the calibration certificate is available.

Confirming dosimetry utilizing a Red Perspex system was also completed.



Mr. W. J. Denkowski

- 2 -

July 19, 1974

Irradiation was completed July 18, 1974 and the units returned to you under separate cover.

Very truly yours,

  
George R. Dietz  
Manager, Radiation Services

GRD:km



PWR Qualification

APPENDIX D

Seismic Qualification - Lockheed Test Report





TEST REPORT NO. 3521-481.1

## REPORT OF TEST

ON

LIMITORQUE CORPORATION  
SMBO OPERATOR W/MOTOR (40 FT. LB.)  
AND  
MOTOR (25 FT. LB.)

REPORT WRITER: *R. F. Soltis*

R. F. Soltis

TEST ENGINEER: *W. A. Black*

W. A. Black

LOCKHEED ELECTRONICS COMPANY, INC.

PLAINFIELD, NEW JERSEY

DATE: June 17, 1974

APPROVED BY: *Nat Johnson*

N. Johnson, Manager  
Environmental Laboratory







TEST REPORT NO. 3521-4811

PURPOSE OF TEST:

To subject the test specimens to the Seismic Test referenced in Limitorque Corporation Purchase Order Number 600456 dated June 11, 1974.

MANUFACTURER:

Limitorque Corporation  
5114 Woodall Road  
Lynchburg, Virginia 24502

SPECIMENS TESTED:

(a) SM80 Operator with 40 ft. lb. motor. S/N 189835

(b) Reliance 25 ft. lb. motor  
ID NO. 2Y267074 A11EZ

APPLICABLE DOCUMENTS:

Limitorque Corporation Purchase Order Number 600456 dated June 11, 1974.

PROJECT NUMBER:

24-8041-3811

QUANTITY OF  
SPECIMENS TESTED:

One (1) each

SECURITY CLASSIFICATION  
OF SPECIMENS TESTED:

Unclassified

DATE TEST COMPLETED:

June 12, 1974

TEST CONDUCTED BY:

LOCKHEED ELECTRONICS COMPANY, INC.  
ENVIRONMENTAL LABORATORY

DISPOSITION OF  
SPECIMENS TESTED:

Returned to Limitorque Corporation per Lockheed Electronics Company, Incorporated Packing Slip Number 97449 dated June 12, 1974.

ABSTRACT:

The test specimens were subjected to the Seismic Test referenced in Limitorque Corporation Purchase Order Number 600456 dated June 11, 1974.

This test was completed with no visible evidence of external damage or resonances.

TEST APPARATUS:

Reaction-Type Vibration Machine, LAB Company Model RVH-72-5000, S/N 51401.



TEST APPARATUS:  
[Continued]

Vibration Pickups, MB Company Type 124,  
S/N 14074 and Type 126, S/N 14006.

Vibration Meter, MB Company Model M-6,  
S/N 539.

Dial-A-Gain Amplifiers, Unholtz-Dickie  
Model 610M, E. L. Number 463 and Model  
610RM-3G, E. L. Number 464.

Accelerometers, Endevco Model 2221D,  
S/N NA94 and FC55.

## TEST PROCEDURE:

The test specimens were secured to the test machine, as shown in Figures 1 through 3, and subjected to the following Seismic Test in accordance with Limitorque Corporation Purchase Order Number 600456 dated June 11, 1974.

1. To determine resonant frequencies, an exploratory scan was performed in each of the three (3) major axes over the frequency range of 5 to 35 Hz with a maximum input acceleration of 1.0 g's.
- 2a. With no resonant frequencies present, the test specimen was subjected to 10 second dwells at the frequencies specified by the Limitorque Corporation representative [see data sheets] in each axis. The vibration amplitude was maintained at the maximum controllable displacement from 5 Hz to the frequency at which 3 g's was attained. The input was then maintained at 3 g's from that frequency up to 34 Hz.
- 2b. The test specimen was vibrated at 35 Hz at an input level of  $6 \pm \frac{1}{4}$  g's for a ten (10) second dwell.

The test specimens were actuated during part 2, and all performance monitoring was performed by and the data retained by Philadelphia Gear Corporation personnel.





TEST REPORT NO. 3521-4811

TEST RESULTS:

The Vibration Test was completed with no visible evidence of external damage noted to either test specimen.

There were no resonances detected in the three (3) axes of vibration.

RECOMMENDATIONS:

None. Data merely submitted.

Test Engineer:

Wm. A. Black  
W. A. Black





FIGURE 1  
TEST SETUP - X AXIS




FIGURE 2  
TEST SETUP - Y AXIS  
A. SMBO OPERATOR W/40' LBS. MOTOR  
B. MOTOR 25' LBS.





FIGURE 3  
TEST SETUP - Z AXIS





VIBRATION TEST DATA SHEET  
 AXIS: 2 Axis

REPORT NO. 3521 - 4811  
 DATE: 6/12/74

NOTE: RECORDED DATA IS  
 DOUBLE AMPLITUDE  
 (INCHES)

| ENDURANCE TEST (PARA.2.23) |       |          |
|----------------------------|-------|----------|
| Hz                         | INPUT | DURATION |
| 35                         | .100  | 10 sec.  |
|                            |       |          |
|                            |       |          |

TEST SPECIMEN  
 NOMENCLATURE

1 mtr. with fixture  
 1 SMO Operator  
 with motor

SERIAL NO.

MANUFACTURER

LIMITORQUE CORPORATION

ACCELEROMETER LOCATION

|       |               |
|-------|---------------|
| CH. 1 | side of motor |
| CH. 2 | top of unit   |

REMARKS:

| Hz           | EXPLORATORY (Para. 1) |       |       | VARI. FREQUENCY (Para. 2.2)                   |       |       |
|--------------|-----------------------|-------|-------|---|-------|-------|
|              | INPUT                 | CH. 1 | CH. 2 | INPUT   | CH. 1 | CH. 2 |
| 4            |                       |       |       |   |       |       |
| 5            | .014                  | .016  | .013  |   |       |       |
| 6            | .016                  | .016  | .014  | .054  | .049  | .047  |
| 7            | .017                  | .016  | .016  |   |       |       |
| 8            | .018                  | .017  | .017  | .054  | .050  | .052  |
| 9            | .018                  | .017  | .018  |   |       |       |
| 10           | .018                  | .017  | .0125 | .052  | .052  | .056  |
| 11           | .018                  | .017  | .019  |   |       |       |
| 12           | .018                  | .017  | .019  | .051  | .054  | .058  |
| 13           | .017                  | .018  | .020  |   |       |       |
| 14           | .017                  | .018  | .020  | .050  | .054  | .059  |
| 15           | .017                  | .018  | .021  |   |       |       |
| 16           | .017                  | .018  | .021  | .050  | .054  | .060  |
| 17           | .017                  | .018  | .021  |   |       |       |
| 18           | .017                  | .019  | .022  | .050  | .054  | .062  |
| 19           | .017                  | .019  | .022  |   |       |       |
| 20           | .017                  | .019  | .022  | .049  | .055  | .063  |
| 21           | .017                  | .019  | .022  |   |       |       |
| 22           | .017                  | .019  | .023  | .048  | .056  | .064  |
| 23           | .017                  | .019  | .023  |   |       |       |
| 24           | .017                  | .019  | .023  | .048  | .056  | .067  |
| 25           | .017                  | .019  | .023  |   |       |       |
| 26           | .017                  | .019  | .023  | .048  | .056  | .066  |
| 27           | .017                  | .019  | .023  |   |       |       |
| 28           | .017                  | .019  | .024  | .048  | .056  | .068  |
| 29           | .017                  | .019  | .024  |   |       |       |
| 30           | .017                  | .019  | .024  | .048  | .056  | .069  |
| 31           | .017                  | .019  | .024  |   |       |       |
| 32           | .0165                 | .0195 | .0245 | .048  | .056  | .072  |
| 33           | .0165                 | .0195 | .0245 |   |       |       |
| 34           | .0165                 | .0195 | .0245 | .048  | .056  | .072  |
| 35           | .0165                 | .0195 | .0245 |   |       |       |
| 36           |                       |       |       |   |       |       |
| 37           |                       |       |       |   |       |       |
| 38           |                       |       |       |   |       |       |
| 39           |                       |       |       |   |       |       |
| 40           |                       |       |       |   |       |       |
| 41           |                       |       |       |   |       |       |
| 42           |                       |       |       |   |       |       |
| 43           |                       |       |       |   |       |       |
| 44           |                       |       |       |   |       |       |
| 45           |                       |       |       |   |       |       |
| 46           |                       |       |       |   |       |       |
| 47           |                       |       |       |   |       |       |
| 48           |                       |       |       |   |       |       |
| 49           |                       |       |       |   |       |       |
| 50           |                       |       |       |   |       |       |
| RES. none Hz |                       |       |       | Operator actuated during this portion of test |       |       |

FORM LEC 922B

TEST ENGINEER

Wm. C. Black



VIBRATION TEST DATA SHEET  
 AXIS: X Axis

REPORT NO. 3521 - 4811  
 DATE: 6/12/74

NOTE: RECORDED DATA IS  
 DOUBLE AMPLITUDE  
 (INCHES)

| ENDURANCE TEST (PARA.2.23) |       |          |
|----------------------------|-------|----------|
| Hz                         | INPUT | DURATION |
| 35                         | .100  | 10 sec   |

TEST SPECIMEN  
 NOMENCLATURE

1 motor with fixture  
 1 SMO Operator  
 with motor

SERIAL NO.

MANUFACTURER

LIMITORQUE CORPORATION

ACCELEROMETER LOCATION

|       |                    |
|-------|--------------------|
| CH. 1 | rear of motor      |
| CH. 2 | front of handwheel |

REMARKS:

| EXPLORATORY (Para. 1) |       |       |       | VARI.FREQUENCY (Para.2.2) |       |       |
|-----------------------|-------|-------|-------|---------------------------|-------|-------|
| Hz                    | INPUT | CH. 1 | CH. 2 | INPUT                     | CH. 1 | CH. 2 |
| 4                     |       |       |       |                           |       |       |
| 5                     | .014  | .014  | .015  | .038                      | .044  | .035  |
| 6                     | .017  | .015  | .016  |                           |       |       |
| 7                     | .018  | .016  | .016  |                           |       |       |
| 8                     | .019  | .0165 | .017  |                           |       |       |
| 9                     | .019  | .017  | .018  |                           |       |       |
| 10                    | .019  | .017  | .019  | .052                      | .050  | .050  |
| 11                    | .0185 | .018  | .020  |                           |       |       |
| 12                    | .0185 | .018  | .020  |                           |       |       |
| 13                    | .018  | .018  | .021  |                           |       |       |
| 14                    | .018  | .018  | .021  |                           |       |       |
| 15                    | .018  | .018  | .021  | .050                      | .052  | .058  |
| 16                    | .0175 | .019  | .022  |                           |       |       |
| 17                    | .0175 | .019  | .022  |                           |       |       |
| 18                    | .017  | .019  | .022  |                           |       |       |
| 19                    | .017  | .019  | .023  |                           |       |       |
| 20                    | .017  | .019  | .023  | .048                      | .054  | .062  |
| 21                    | .017  | .019  | .023  |                           |       |       |
| 22                    | .017  | .019  | .023  |                           |       |       |
| 23                    | .017  | .019  | .0235 |                           |       |       |
| 24                    | .017  | .019  | .024  |                           |       |       |
| 25                    | .017  | .019  | .024  | .047                      | .055  | .066  |
| 26                    | .0165 | .019  | .024  |                           |       |       |
| 27                    | .0165 | .019  | .025  |                           |       |       |
| 28                    | .0165 | .019  | .025  |                           |       |       |
| 29                    | .0165 | .0195 | .025  |                           |       |       |
| 30                    | .016  | .0195 | .026  | .047                      | .056  | .072  |
| 31                    | .016  | .0195 | .026  |                           |       |       |
| 32                    | .016  | .0195 | .027  |                           |       |       |
| 33                    | .016  | .0195 | .027  |                           |       |       |
| 34                    | .016  | .0195 | .028  |                           |       |       |
| 35                    | .016  | .0195 | .028  | .047                      | .056  | .086  |
| 36                    |       |       |       |                           |       |       |
| 37                    |       |       |       |                           |       |       |
| 38                    |       |       |       |                           |       |       |
| 39                    |       |       |       |                           |       |       |
| 40                    |       |       |       | Operator actuated during  |       |       |
| 41                    |       |       |       | this portion of test      |       |       |
| 42                    |       |       |       |                           |       |       |
| 43                    |       |       |       |                           |       |       |
| 44                    |       |       |       |                           |       |       |
| 45                    |       |       |       |                           |       |       |
| 46                    |       |       |       |                           |       |       |
| 47                    |       |       |       |                           |       |       |
| 48                    |       |       |       |                           |       |       |
| 49                    |       |       |       |                           |       |       |
| 50                    |       |       |       |                           |       |       |
| RES. none Hz          |       |       |       |                           |       |       |

FORM LEC 922B

TEST ENGINEER

Wm. C. Black



**VIBRATION TEST DATA SHEET**  
**AXIS: Y Axis**

**REPORT NO. 3521 - 4811**  
**DATE: 6/12/74**

**NOTE: RECORDED DATA IS  
 DOUBLE AMPLITUDE  
 (INCHES)**

| ENDURANCE TEST (PARA.2.23) |       |          |
|----------------------------|-------|----------|
| Hz                         | INPUT | DURATION |
| 35                         | .100  | 10 sec   |
|                            |       |          |
|                            |       |          |

**TEST SPECIMEN  
 NOMENCLATURE**

1 motor with fixture  
 1 SMO Operator  
 with motor

**SERIAL NO.**

**MANUFACTURER**

**LIMITORQUE CORPORATION**

**ACCELEROMETER LOCATION**

|       |              |
|-------|--------------|
| CH. 1 | Top of motor |
| CH. 2 | Top front of |

**Handwheel  
 REMARKS:**

Operator actuated during  
 this portion of test

**TEST ENGINEER**

Wm. C. Black

| Hz           | EXPLORATORY (Para. 1) |       |       | VARI.FREQUENCY(Para.2.2) |       |       |
|--------------|-----------------------|-------|-------|--------------------------|-------|-------|
|              | INPUT                 | CH. 1 | CH. 2 | INPUT                    | CH. 1 | CH. 2 |
| 4            |                       |       |       |                          |       |       |
| 5            | .009                  | .016  | .010  |                          |       |       |
| 6            | .009                  | .014  | .012  | .052                     | .049  | .032  |
| 7            | .013                  | .017  | .013  |                          |       |       |
| 8            | .014                  | .017  | .014  |                          |       |       |
| 9            | .015                  | .017  | .015  |                          |       |       |
| 10           | .0155                 | .017  | .016  | .051                     | .049  | .042  |
| 11           | .016                  | .017  | .016  |                          |       |       |
| 12           | .0165                 | .017  | .017  |                          |       |       |
| 13           | .017                  | .017  | .017  |                          |       |       |
| 14           | .017                  | .018  | .017  |                          |       |       |
| 15           | .017                  | .018  | .0175 | .049                     | .052  | .047  |
| 16           | .017                  | .018  | .018  |                          |       |       |
| 17           | .017                  | .018  | .018  |                          |       |       |
| 18           | .017                  | .018  | .018  |                          |       |       |
| 19           | .017                  | .018  | .0185 |                          |       |       |
| 20           | .017                  | .0185 | .019  | .048                     | .052  | .050  |
| 21           | .017                  | .0185 | .019  |                          |       |       |
| 22           | .017                  | .0185 | .019  |                          |       |       |
| 23           | .017                  | .019  | .019  |                          |       |       |
| 24           | .017                  | .019  | .020  | .048                     | .054  | .052  |
| 25           | .017                  | .019  | .020  |                          |       |       |
| 26           | .017                  | .019  | .020  |                          |       |       |
| 27           | .017                  | .019  | .0205 |                          |       |       |
| 28           | .017                  | .0195 | .021  |                          |       |       |
| 29           | .017                  | .0195 | .021  |                          |       |       |
| 30           | .017                  | .020  | .022  | .048                     | .056  | .058  |
| 31           | .017                  | .020  | .0225 |                          |       |       |
| 32           | .017                  | .020  | .023  |                          |       |       |
| 33           | .017                  | .020  | .023  |                          |       |       |
| 34           | .017                  | .020  | .024  |                          |       |       |
| 35           | .017                  | .0205 | .024  | .049                     | .058  | .062  |
| 36           |                       |       |       |                          |       |       |
| 37           |                       |       |       |                          |       |       |
| 38           |                       |       |       |                          |       |       |
| 39           |                       |       |       |                          |       |       |
| 40           |                       |       |       |                          |       |       |
| 41           |                       |       |       |                          |       |       |
| 42           |                       |       |       |                          |       |       |
| 43           |                       |       |       |                          |       |       |
| 44           |                       |       |       |                          |       |       |
| 45           |                       |       |       |                          |       |       |
| 46           |                       |       |       |                          |       |       |
| 47           |                       |       |       |                          |       |       |
| 48           |                       |       |       |                          |       |       |
| 49           |                       |       |       |                          |       |       |
| 50           |                       |       |       |                          |       |       |
| RES. none Hz |                       |       |       |                          |       |       |

FORM LEC 922B





APPENDIX E

- Figure 1      Test Chamber
- Figure 2      Steam Generator
- Figure 3      Control and Instrumentation  
                 Panel






Figure 1  
Test Chamber






Figure 2  
Steam Generator






Figure 3  
Control and Instrumentation  
Panel





APPENDIX F

Figure 4 - Schematic - Instrumentation

Table I      Summary of Instruments used for  
Data Acquisition

---








TABLE I

## SUMMARY OF DATA ACQUISITION SYSTEM

|   |                        |           |   |  |   |  |                     |                  |                  |
|---|------------------------|-----------|---|--|---|--|---------------------|------------------|------------------|
| Measurement Categories<br>IEEE Std.382 Par:4.51 |                        | PARAMETER | Item No.  | MEASURING SYSTEM   |   |  |                     | LAST CALIBRATION | NEXT CALIBRATION |
|   |                        |           |   | Indicator  | Signal<br>Conditioner   | X-Ducer  | Monitoring<br>Point |                  |                  |
| I - ENVIRONMENT                                 | TEMPERATURE            | 1.        | Multipoint<br>Temperature<br>Recorder<br>Type J T. C.<br><br>Honeywell<br>Model No.<br>K153x80-c-<br>II-W6-65<br>Serial No.<br>T11806-83004 | 1<br>2<br>3<br>4<br>5<br>6<br>7,10<br>8,11<br>9,12<br>13,15,17<br>14,16,18<br>19,21,23<br>20,22,24 | 1B T. C.-J(2)<br>2A T. C.-J(2)<br>3B T. C.-J(2)<br>4B T. C.-J(2)<br>- -<br>- -<br>5 T. C.-J<br>6 T. C.-J<br>7 T. C.-J<br>8 T. C.-J<br>9 T. C.-J<br>10 T. C.-J<br>11 T. C.-J | Chamber Amb.<br>Test Unit<br>L.S.Comp<br>Chamber Amb.<br>Room Amb.<br>Shorted<br>Condensate<br>Press x-D#2<br>Press x-D#3<br>Press x-D#4<br>Press x_D#1<br>H2O input<br>H2O output | Feb.<br>1974        | Feb.<br>1975     |                  |
|   | TEMPERATURE & PRESSURE | 2.        | Strip Chart<br>Recorder<br>8 Channel<br><br>Gulton<br>TR888<br><br>S/N<br>3042802<br><br>Note: Amp. TSC 801<br>T.C.Mod. TSC 500J            | 1 Amplif.<br>2 "<br>3 "<br>4 "<br>5 T.C. Mod.<br>6 "<br>7 "<br>8 "                                 | Press x-D#1<br>Press x-D#2<br>Press x-D#3<br>Press x-D#4<br>1A:T.C.-J(2)<br>2B T.C.-J(2)<br>3A T.C.-J(2)<br>4A T.C.-J(2)  | Chamber Amb.<br>Test Unit<br>L.S. Comp.<br>Chamber Amb.<br>Chamber Amb.<br>Test Unit<br>L.S. Comp.<br>Chamber Amb.   | Mar.<br>1974        | Sept.<br>1974    |                  |

Measurement Categories  
IEEE Std. 382 Par. 4.51

I - ENVIRONMENT



TABLE I (continued)

## SUMMARY OF DATA ACQUISITION SYSTEM

| Measurement Categories, IEEE Std. 382 para. 4.5.1 | PARAMETER   | Item No. | Measuring System   |  |         | Monitoring Point        | LAST CALIBRATION | NEXT CALIBRATION |
|---|-------------|----------|--|--|---------|-------------------------|------------------|------------------|
|   |             |          | Indicator  | Signal Conditioner                                   | X-Ducer |                         |                  |                  |
| I - Environment                                   | TEMPERATURE | 3        | Mercury bulb Thermometer<br>Wexler 50-400 F                |  |         | Chamber Ambient         | New 2/74         | 2/75             |
|   |             | 4        | Bi-metal Dial Thermometer<br>Wexler 50-400 F               |  |         | Chamber Ambient         | New 2/74         | 2/75             |
|   | Pressure    | 5        | Dial Pressure Gage<br>Ashcroft 30 in Hg to 200 psig        |  |         | Chamber Pressure        | 5/74             | 11/74            |
|   | Time        | 6        | Time of Day<br>Wall-Clock                                  |  |         | Time of Day             | -                | -                |
|   |             | 7        | Running Time Clock<br>1000 hours 0.1 hr.<br>Resolution     |  |         | Total Test Time         | -                | -                |
|   | LOAD        | 8        | Strain Indicator<br>Bridge<br>BL &H<br>Typen<br>S/N 443604 | 20,000 lb<br>Load<br>Cell<br>BL&H<br>U-1<br>S/N 2512 |         | Test Unit Thrust Output | 12/73            | 12/74            |
| II Power & Cycle Time                             |             |          |  |  |         |                         |                  |                  |





TABLE I (continued)

## SUMMARY OF DATA ACQUISITION SYSTEM

| MEASUREMENT<br>Categories IEEE<br>Std. 382 Para.<br>4.5.1 | PARAMETER | Item No. | Measuring System   |                   |         | Monitoring<br>Point                    | LAST<br>Calibration | Next<br>Calibration |
|---|-----------|----------|--|-------------------|---------|--|---------------------|---------------------|
|   |           |          | Indic-<br>ator   | Signal<br>Condit. | X-Ducer |  |                     |                     |
| II - POWER & CYCLE TIME                                   | POWER     | 9.       | 3 phase Recording<br>Watimeter<br><br>Esterline Angus<br>Model A 601C<br>S/N 192358  |                   |         | Power<br>Consumption<br>of<br>operator | New<br>2/74         | 2/75                |
|   | CURRENT   | 10.      | Panel Meters<br><br>3 meters one in each<br>phase<br><br>Low Range - 3-0-10<br>amp meters<br>Triplett Type 430<br><br>Hi Range - 3-0-50<br>amp meters<br>Triplett Type 430 |                   |         | Test Unit<br>Current                   | New<br>3/74         | 3/75                |
|   | VOLTAGE   | 11.      | Panel Meters<br>3 meters one across<br>each phase<br><br>0-500VAC Triplett<br>Type 430   |                   |         | Test Unit<br>Voltage                   | New<br>3/74         | 3/75                |



TABLE I (continued)

## SUMMARY OF DATA ACQUISITION SYSTEM

| Measurement Categories    | PARAMETER | Item No. | Measuring System   |                    |         | Monitoring Point                   | LAST CALIBRATION                     | NEXT CALIBRATION |
|---------------------------|-----------|----------|--|--------------------|---------|------------------------------------|--------------------------------------|------------------|
|                           |           |          | Indicator  | Signal Conditioner | X-Ducer |                                    |                                      |                  |
| II Power & Cycle          | TIME      | 12       | Stopwatch<br>Hever S/N 512406  |                    |         | Stroke Time                        | -                                    | -                |
|                           |           | 13       | Flow Meters (2)<br>Fisher & Porter<br><br>Model S/N<br>10A1735Y 7309A0574A1<br>10A1735 7407A0403A1 |                    |         | Chemical Flow                      | New 2/74                             | 2/75             |
| III Fluid Characteristics | PRESSURE  | 14       | 2 Dial Pressure Gages<br>(2) Wesler Model BA14P<br>1 Acco Helicoid<br>0-200 psig                   |                    |         | Manifold Pressure<br>Pump Pressure | New 2/74<br>Indicator only           | 2/75             |
|                           |           | 15       | PH Meter   |                    |         | PH of Chem. Solution               | Comparison Against Standard Solution |                  |
|                           |           | 16       | Megohmmeter<br><br>James G. Biddle<br><br>Model 21159<br><br>S/N 732521                            |                    |         | Motor & Control Leads              | New 2/74                             | 2/75             |



APPENDIX D

Outside Containment Qualification

Report B0003



Qualification Type Test Report

Limitorque Valve Actuators

For Class 1E Service

Outside Primary Containment

In Nuclear Power Station Service

Per IEEE 382-72 & IEEE 323-71

Test Performed Nov. 13, 1974 to Jan. 23, 1975

PROJECT NO. 600461

REPORT NO. B0003

Prepared by-

LIMITORQUE CORPORATION TEST LABORATORY

PREPARED BY

Thomas O. Hess Jr.  
T. Hess Jr. - Test Eng.

DATE:

May 28, 1976

APPROVED:

W. Denkowski  
W. Denkowski - Vice Pres. Eng.

DATE:

June 2, 1976

ACCEPTED:

C. Formica  
C. Formica - Q.A. Administrator

DATE:

June 7, 1976





## TABLE OF CONTENTS

|     |  |        |
|-----|--|--------|
| 1.0 | Purpose of Test                            | Page 1 |
| 2.0 | Test Plan                                  | Page 1 |
| 2.1 | Thermal Aging                              |        |
| 2.2 | Mechanical Aging                           |        |
| 2.3 | Radiation Exposure                         |        |
| 2.4 | Seismic Aging                              |        |
| 2.5 | Environmental Test                         |        |
| 3.0 | Identification of Actuator and Test Motors | Page 6 |
| 3.1 | Test Actuator with Motor (Unit #1)         |        |
| 3.2 | Test Motor #1                              |        |
| 3.3 | Test Motor #2                              |        |
| 4.0 | Test Procedure                             | Page 7 |
| 4.1 | Thermal Aging                              |        |
| 4.2 | Mechanical Aging                           |        |
| 4.3 | Radiation Exposure                         |        |
| 4.4 | Seismic Aging                              |        |
| 4.5 | Environmental Test                         |        |
| 5.0 | Conclusions                                |        |



## PROFILE AND DATA SHEETS

|   |         |
|---|---------|
| Figure 1 - Temperature Profile                        | Page 10 |
| Figure 2A- Insulation Resistance                      | Page 11 |
| Figure 2B- Actuator Electrical Characteristics        | Page 12 |
| Figure 3 - Electrical Characteristics - Test Motor #1 | Page 13 |
| Figure 4 - Electrical Characteristics - Test Motor #2 | Page 14 |

## APPENDICES

|   |
|---|
| Appendix I - Instrumentation and Calibration                  |
| Appendix II - Certificate of Compliance, - Radiation Exposure |
| Appendix III - Test Report - Seismic Aging                    |
| Appendix IV - Photographs - At Test Conclusion                |



## 1.0 Purpose of Test

The purpose of this test was to determine the capabilities of a Limitorque Valve Actuator (type SMB) equipped with an electric motor with Class B insulation to satisfactorily operate during a Post LOCA or Steam Line Break environmental condition. The parameters stipulated in the test plan were obtained by Limitorque Corporation from Power Plant designers and consultants using IEEE 382 as a guide for formulating a test plan. The valve actuator is considered acceptable on provision it proves capable of satisfactorily operating against a simulated valve load in both opening and closing directions within 15 days following the start of environmental exposure.

## 2.0 Test Plan

The test was conducted in Limitorque Corporation's Environmental Facility at King of Prussia, Pa. One Limitorque Valve Actuator (Unit #1), one test motor #1 and one test motor #2 (all with Class B insulation) was subjected to test conditions according to the following test plan.

### 2.1 Thermal Aging

2.1.1 Install the Valve Actuator with motor on a mechanism to simulate seating load and the two test motors in the Environmental Chamber.

2.1.2 Establish an ambient condition in the chamber of 165°F. and 100% relative humidity at atmospheric pressure and retain this condition for 200 hours.



2.1.3 Cycle - The valve actuator to close position and then to open position once per hour for a total of 200 cycles.

2.1.4 Operate the motors once per hour for 30 seconds in one direction and for 30 seconds in the other direction for the duration of thermal aging.

## 2.2 Mechanical Aging

2.2.1 Cycle the valve actuator for 200 cycles during thermal aging. Cycle the unit for 1800 additional times at room ambient to obtain a total of 2000 closing and opening strokes. All valve simulated cycles to be completed at the approximate output rating of the actuator.

2.2.2 At room ambient, run each motor for 15 minutes in one direction and then for 15 minutes in the opposite direction.

## 2.3 Radiation Exposure

2.3.1 Irradiate the test actuator with motor to  $2.0 \times 10^7$  rads (gamma radiation) and the two test motors to  $2.04 \times 10^8$  rads (gamma radiation) at the rate of  $1.0 \times 10^6$  rads per hour.

Rev. A

## 2.4 Seismic Aging

2.4.1 Install three (3) accelerometers on the Limitorque valve control housing arranged to measure accelerations in each of these axes (one vertical and two horizontal).

2.4.2 Mount the Limitorque valve control with fixture to the shaker table with the axis of the stem nut mounted vertically.

Rev. A 12-15-81 - Added Missing Phrase





- 2.4.3 Connect the limit switches and torque switches into the control. Connect a contact of the limit switch in series with the torque switch to detect switch chatter. Connect spare switch contacts to lights for further indication of chatter.
- 2.4.4 Scan in each of the 3 axes at a minimum of .1g from 5HZ to 33HZ, dwelling for 6 seconds at each frequency. Repeat scan from 33HZ to 5HZ, dwelling at each integer frequency. Record the accelerometer readings at each scan dwell point of each of three axes, - V (vertical)  $H_1$  (horizontal parallel to motor axis) and  $H_2$  (horizontal perpendicular to motor axis) for determination of cross coupling. Note resonance frequency in axis being scanned. (Resonance is defined as a minimum acceleration multiplication factor of 2).
- 2.4.5 Prepare to conduct dwell test in vertical axis V at resonant frequency determined in step 4 (Dwell at 33HZ, if resonant frequencies not evident).
- A. On basis of 6.0g on V axis and 3.2g on both  $H_1$  and  $H_2$  axes, determine dwell g-level as follows:
- 1) At dwell frequency, note cross coupling on V axis determined during scan on  $H_1$  and  $H_2$  axes.



2) If any cross coupling noted, calculate acceleration adder to V axis.

a)  $H_1$  axis

$$\text{Adder} = \frac{3.2g \times \text{cross couple } g \text{ level at scan}}{g\text{-level of scan at dwell frequency}}$$

b)  $H_2$  axis

$$\text{Adder} = \frac{3.2g \times \text{cross couple } g \text{ level at scan}}{g\text{-level of scan at dwell frequency}}$$

c) Add resultant of a) and b) to 6.0g, establishing the G-level for the dwell test.

B. Conduct dwell test for 30 seconds on V axis using g-level determined from A.2.c. During the dwell, operate the unit in an open and close stroke. (Simulated thrust seat at same torque switch setting established during mechanical aging). Note results.

2.4.6 Prepare to conduct swell test in horizontal axis  $H_1$  at resonant frequency determined in step 2.4. (Dwell at 33HZ if resonant frequencies not evident).

A. On basis of 6.0g on  $H_1$  axis and 3.2 on both  $H_2$  and V axes, determine dwell g level as indicated in 2.3.5A except substitute V axis for  $H_1$  axis.

B. Conduct dwell test as indicated in 2.4.5B.

2.4.7 Prepare to conduct dwell test in horizontal axis  $H_2$  at resonant frequency determined in step 3. (Dwell at 33HZ if resonant frequencies not evident).



- A. On basis of 6.0g on H<sub>2</sub> axis and 3.2g on both H<sub>1</sub> and V axes, determine dwell g level as indicated in 2.3.5A, except substitute V axis for H<sub>2</sub> axis.
- B. Conduct dwell test as indicated in 2.4.5B

## 2.5 Environmental Test

- 2.5.1 Install valve actuator with thrust tube and two test motors in test chamber.
- 2.5.2 Fill bottom of test chamber with water to assure saturation of the atmosphere in the chamber.
- 2.5.3 Heat test chamber to 120°F.
- 2.5.4 Conduct transient temperature rise (120°F. to 250°F.) in 10 secs.
- 2.5.5 Hold 250°F. for 30 mins.
- 2.5.6 Cool to 120°F. @ 90°F/hr. ave.
- 2.5.7 Conduct second transient temperature rise (120°F. to 250°F.) in 10 secs.
- 2.5.8 Hold 250°F for 24 hours.
- 2.5.9 Cool to 200°F. @ 90°F./hr. ave.
- 2.5.10 Hold 200°F. for 16 days after start of test.
- 2.5.11 Megger and cycle actuator prior to start of test and the following nominal times after start of test.

|          |             |
|----------|-------------|
| Event 3  | .3 hours    |
| Event 6  | 2.6 hours   |
| Event 19 | 23.4 hours  |
| Event 21 | 25.7 hours  |
| Event 80 | 383.5 hours |



### 3.0 Identification of Actuator and Test Motors

#### 3.1 Test Actuator with Motor (Unit #1)

##### 3.1.1 Limiterorque Actuator

|            |        |
|------------|--------|
| Model      | SMB-O  |
| Order No.  | 600461 |
| Serial No. | 195004 |

##### 3.1.2 Motor

|                  |                   |
|------------------|-------------------|
| Manufacturer     | Reliance Electric |
| I.D. No.         | 447014-BZ         |
| Start Torque     | 25 ft. lbs.       |
| Run Torque       | 5 ft. lbs.        |
| Horsepower       | 1.6               |
| RPM              | 1700              |
| Duty             | 15 min.           |
| Volts            | 230/460           |
| Amps.            | 8.0/4.0           |
| Temperature Rise | 75°C.             |
| Insulation       | Class B           |

#### 3.2 Test Motor #1

|                    |                   |
|--------------------|-------------------|
| 3.2.1 Manufacturer | Reliance Electric |
| I.D. No.           | 447014-JZ         |
| Start Torque       | 25 ft. lbs.       |
| Run Torque         | 5 ft. lbs.        |
| Horsepower         | 1.6               |
| RPM                | 1700              |
| Volts              | 230/460           |
| Amps.              | 8.0/4.0           |
| Temperature Rise   | 75°C.             |
| Insulation         | Class B           |

#### 3.3 Test Motor #2

|                    |                    |
|--------------------|--------------------|
| 3.3.1 Manufacturer | Electric Apparatus |
| I.D. No.           | 742-19564K-09      |
| Start Torque       | 40 Ft. lbs.        |
| Run Torque         | 8 ft. lbs.         |
| Horsepower         | 2.6                |
| RPM                | 1705               |
| Volts              | 220/440            |
| Amps               | 11.6/5.8           |
| Temperature Rise   | 75°C.              |
| Insulation         | Class B            |





In addition (2) Engineering Development Units and motor were included for Limitorque information.

#### 4.0 Test Procedure

#### 4.1 Thermal Aging

- 4.1.1 The Valve Actuator Unit #1 was installed on a test stand to establish a thrust load of 20,000 lbs. A thrust load of 20,350 lbs. (approx. 466 ft. lbs. torque at a torque switch setting of 2-1/2) was measured. (an average of 6 readings)
- 4.1.2 A thrust tube was then installed in the Valve Actuator Unit #1 and the two test motors were mounted on a stand. After the Actuator and motors were placed in the environmental chamber, they were wired to an external control source with a timing circuit that would operate them once per hour.
- 4.1.3 The Valve Actuator was set for a 30 second stroke time and the test motors were run hourly for 30 seconds in each direction of rotation.
- 4.1.4 The Test Chamber was filled to the bottom of the rail with water to insure 100% relative humidity. The chamber was then heated to 165°F. at 0 psig pressure and the ambient maintained for 199.8 hours.
- 4.1.5 The Actuator and test motors cycling was started Nov. 4, 1974 and completed Nov. 13, 1974 with a total of 176 cycles. Failure of the timer circuit (not part of the normal Valve Actuator Control) prevented the completion of the 200 cycles originally planned.



#### 4.2 Mechanical Aging

- 4.2.1 The Test Chamber Cover was removed, the strip heaters deenergized and the test motors disconnected from the timing circuit.
- 4.2.2 The Valve Actuator cycling continued on Nov. 13 with the unit operating on an accelerated timing sequence completing 1817 additional cycles. The mechanical aging was concluded Nov. 19, 1974.
- 4.2.3 The test motors were run on Nov. 13 for a total of 15 minutes in one direction and for 15 minutes in the other direction on Nov. 14, 1974.

#### 4.3 Radiation Exposure

- 4.3.1 The Limitorque Valve Actuator and two test motors received  $2.0 \times 10^7$  Rads gamma radiation at Isomedix, Inc., Parsippany, N.J. Irradiation was completed on Nov. 22, 1974. A copy of the Isomedix certificate of compliance is in Appendix II.

#### 4.4 Seismic Aging

- 4.4.1 Seismic Aging was conducted at Aero Nav Laboratories, Inc., College Point, New York according to the procedure listed in Section 2.4.1. The two test motors were mounted on the table next to Valve Actuators and received the same aging as the unit. The Seismic Aging was completed Dec. 3, 1974. A copy of Aero Nav test reports 5720 and 5722 are included in Appendix III.



#### 4.5 Environmental Test

4.5.1 The environmental test was initiated on Jan. 6, 1975 according to the test plan presented in Section 2.5. The test profile is presented in Fig. 1. The operating characteristics of test unit #1 is included in figures 2A and 2B, of test motor #1 in figure 3 and of test motor #2 in figure 4.

4.5.2 Event 19 (24 hours after test start)

Event 21 (25.8 hours after test start)

Valve Actuator Unit #1 operated satisfactorily in the "close" direction, but in the "open" direction of stroke, overran the "open" limit. The torque switch would normally have prevented this over travel, but was unable to operate due to the fact the thrust tube had no stop in the opening direction. It is surmised this was caused by a momentary electrical short due to localized condensate build up, a malfunction of the reversing contactor or a combination of both. Since this did not occur before event 19, during event 20, nor recurred after event 21, it is assumed this was caused by an abnormal condition during this short time period. Both the "open" and "close" indicator lights exhibited a very dim glow when it should have been extinguished which could be attributed to a floating ground. (The ground had been removed to facilitate meggering of the control circuit). Also an investigation concluded the current flow to duplicate the dim glow was insignificant and did not constitute a mal-function.



# TEMPERATURE PROFILE




FIGURE 1





| UNIT - I CONTROL LEAD INSULATION RESISTANCE - ACCIDENT SIMULATION |          |   |       |       |        |       |       |       |       |       |       |       |       |       |       |       |
|---|----------|---|-------|-------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Event No.   | Run time | INSULATION RESISTANCE TO GROUND                             |       |       |        |       |       |       |       |       |       |       |       |       |       |       |
|   |          | all values in ohms x 10 <sup>3</sup> unless otherwise noted |       |       |        |       |       |       |       |       |       |       |       |       |       |       |
|   | hr.      | 0-1   | 6I    | 7I    | 4I     | 43A   | 43B   | 43C   | 45A   | 45B   | 5I    | 53A   | 53B   | 53C   | 55A   | 55B   |
| 0   | 0        | 500 M   | 500 M | 500 M | 2000 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M | 500 M |
| 1   | 0        | 1.7M  | 1.7M  | 1.7M  | 4M     | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  | 1.7M  |
| 3   | 0.3      | .1M   | .1M   | .1M   | .5M    | .1M   | .1M   | .1M   | .2M   | .1M   | .1M   | .1M   | .1M   | .1M   | .1M   | .1M   |
| 6   | 2.6      | .04M  | .04M  | .04M  | .08M   | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  | .04M  |
| 19  | 23.4     | 1.2K  | 1.2K  | 2.1K  | 4K     | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  | 1.3K  |
| 21  | 25.8     | 3K  | 3K    | 4K    | 12K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    | 3K    |
| 80  | 383.3    | 2K  | 2K    | 3K    | 5K     | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    | 2K    |


FIGURE 2A



# UNIT 1 ELECTRICAL CHARACTERISTICS - ACCIDENT SIMULATION

| Event No. | Run Time | Resistance (ohms) |      |      | Potential (volts) |     |     | Operator (Opening) |     |     |      |     | Operator (Closing) |     |     |     |     |        |     |      |
|-----------|----------|-------------------|------|------|-------------------|-----|-----|--------------------|-----|-----|------|-----|--------------------|-----|-----|-----|-----|--------|-----|------|
|           |          |                   |      |      |                   |     |     |                    |     |     |      |     |                    |     |     |     |     |        |     |      |
|           |          | T1                | T2   | T3   | T1                | T2  | T3  | T1                 | T2  | T3  | Watt | Sec | T1                 | T2  | T3  | T1  | Run | Peak   | Sec | Time |
| 0         | 0        | ∞                 | ∞    | ∞    | 495               | 500 | 495 | 3.8                | 4.2 | 3.9 | 500  | 30  | 4.0                | 4.0 | 3.6 | 4.5 | 500 | 1K     | 30  |      |
| 1         | 0        | 24M               | 24M  | 24M  | 500               | 500 | 500 | 3.8                | 4.2 | 3.8 | 450  | 30  | 4.0                | 4.2 | 3.8 | 4.5 | 450 | 1.1K   | 31  |      |
| 3         | 0.3      | 5M                | 5M   | 5M   | 495               | 500 | 495 | 3.9                | 4.2 | 3.9 | 450  | 30  | 4.1                | 3.9 | 3.8 | 4.4 | 450 | 1.1K   | 31  |      |
| 6         | 2.6      | 1.5M              | 1.5M | 1.5M | 495               | 500 | 495 | 3.8                | 4.2 | 3.9 | 475  | 30  | 4.1                | 4.0 | 3.8 | 4.5 | 500 | 1.25K  | 31  |      |
| 19        | 23.4     | 2.9K              | 2.9K | 2.9K | 490               | 495 | 490 | 3.8                | 4.0 | 3.8 | 500  | —   | 4.0                | 3.8 | 3.7 | 4.5 | 550 | 1.325K | 31  |      |
| 21        | 25.8     | 40K               | 40K  | 40K  | 495               | 500 | 490 | 3.8                | 4.0 | 3.8 | 475  | 30  | 4.0                | 3.8 | 3.7 | 4.5 | 475 | 1.3K   | 31  |      |
| 80        | 383.8    | 15K               | 15K  | 15K  | 495               | 500 | 495 | 3.7                | 4.1 | 3.8 | 475  | 33  | 4.0                | 3.9 | 3.7 | 4.6 | 475 | 1.4K   | 33  |      |

FIGURE 2B



TEST MOTOR #1 - ELECTRICAL CHARACTERISTICS - ACCIDENT SIMULATION

| Event No. | Run Time | Insulation Resistance (KOHMS) |      |      | Potential (Volts) |     |     | Operator "Opening"     |     |       |             |                 |     | Operator "Closing" |          |              |             |      |     |
|-----------|----------|-------------------------------|------|------|-------------------|-----|-----|------------------------|-----|-------|-------------|-----------------|-----|--------------------|----------|--------------|-------------|------|-----|
|           |          |                               |      |      |                   |     |     | Running Current (Amps) |     | Power | Stroke Time | Running Current |     | Amps               | Es. Peak | Power (Watt) | Stroke Time |      |     |
|           |          | T1                            | T2   | T3   | T1                | T2  | T3  | T1                     | T2  | T3    | Watt        | Sec             | T1  | T2                 | T3       | T1           | Run         | Peak | Sec |
| 0         | 0        | ∞                             | ∞    | ∞    | 495               | 500 | 490 | 3.8                    | 3.7 | 3.9   | 350         | 30              | 4.0 | 3.9                | 3.6      | -            | 350         | -    | 30  |
| 1         | 0        | ∞                             | ∞    | ∞    | 495               | 500 | 495 | 3.9                    | 3.8 | 3.9   | 350         | 30              | 4.0 | 3.9                | 3.6      | -            | 375         | -    | 30  |
| 3         | 0.3      | 175M                          | 175M | 175M | 495               | 490 | 495 | 4.0                    | 3.9 | 3.7   | 375         | 30              | 4.0 | 3.8                | 3.6      | -            | 375         | -    | 30  |
| 6         | 2.6      | .4M                           | .4M  | .4M  | 500               | 500 | 495 | 3.9                    | 3.8 | 4.0   | 400         | 30              | 4.1 | 3.9                | 3.7      | -            | 400         | -    | 30  |
| 19        | 23.4     | .1M                           | .1M  | .1M  | 495               | 500 | 495 | 3.8                    | 3.8 | 3.9   | 400         | 30              | 4.0 | 3.9                | 3.7      | -            | 400         | -    | 30  |
| 21        | 25.8     | .6M                           | .6M  | .6M  | 495               | 500 | 495 | 3.8                    | 3.7 | 3.8   | 375         | 30              | 4.0 | 3.9                | 3.6      | -            | 400         | -    | 30  |
| 80        | 383.5    | 1.2M                          | 1.2M | 1.2M | 490               | 495 | 490 | 3.9                    | 3.9 | 3.8   | 375         | 30              | 3.8 | 3.8                | 3.8      | -            | 375         | -    | 30  |

FIGURE 3



TEST MOTOR #2 - ELECTRICAL CHARACTERISTICS - ACCIDENT SIMULATION

| Event No. | Insulation Resistance (Ohms) |       |       |       |     |     | Potential (Volts) |     |     | Operator 'Opening' |     |              |     |             | Operator 'Closing' |     |              |     |             |
|-----------|------------------------------|-------|-------|-------|-----|-----|-------------------|-----|-----|--------------------|-----|--------------|-----|-------------|--------------------|-----|--------------|-----|-------------|
|           | 1                            |       |       | 2     |     |     | 3                 |     |     | Running Current    |     | Power (Watt) |     | Stroke Time | Running Current    |     | Power (Watt) |     | Stroke Time |
|           | 1                            |       |       | 2     |     |     | 3                 |     |     | 1                  |     | 2            |     | 3           | 1                  |     | 2            |     | 3           |
|           | 1                            | 2     | 3     | 1     | 2   | 3   | 1                 | 2   | 3   | Watt               | Sec | 1            | 2   | 3           | 1                  | Run | Peak         | Sec |             |
| 0         | 0                            | ∞     | ∞     | ∞     | 495 | 500 | 490               | 6.5 | 6.0 | 6.5                | 800 | 30           | 7.0 | 6.2         | 5.6                | -   | 800          | -   | 30          |
| 1         | 0                            | 2000M | 2000M | 2000M | 495 | 500 | 495               | 6.5 | 6.2 | 6.6                | 800 | 30           | 7.2 | 6.3         | 5.7                | -   | 800          | -   | 30          |
| 3         | 0.3                          | .6M   | .6M   | .6M   | 490 | 495 | 490               | 6.9 | 6.0 | 5.6                | 800 | 30           | 8.0 | 6.0         | 6.3                | -   | 800          | -   | 30          |
| 6         | 2.6                          | .1M   | .1M   | .1M   | 500 | 500 | 495               | 6.5 | 6.1 | 6.5                | 800 | 30           | 7.1 | 6.1         | 5.7                | -   | 850          | -   | 30          |
| 19        | 23.4                         | 5K    | 5K    | 5K    | 490 | 495 | 490               | 6.4 | 6.0 | 6.4                | 850 | 30           | 7.0 | 6.0         | 5.8                | -   | 850          | -   | 30          |
| 21        | 25.8                         | .2M   | .2M   | .2M   | 495 | 500 | 495               | 6.4 | 6.0 | 6.4                | 800 | 30           | 7.0 | 6.1         | 5.6                | -   | 800          | -   | 30          |
| 80        | 383.8                        | 40K   | 40K   | 40K   | 490 | 495 | 490               | 7.0 | 6.2 | 5.6                | 825 | 30           | 6.3 | 6.0         | 6.4                | -   | 825          | -   | 30          |

FIGURE A





#### 4.5.3 Post-Test Inspection

A white powdery deposit was found on the limit switch gear housing, the metallic frame parts of the torque switch and the end bells of the Reliance motors. Photographs are included in Appendix IV. All internal mechanical elements were in excellent condition with no mechanical damage or excessive wear being observed.

#### 5.0 Conclusions

Since no detrimental effects due to aging were discernable, the unit is qualified for a 40 year life as described in aging criteria. The Valve Actuator and Test Motors operated satisfactorily throughout the Environmental LOCA Test, proving its capability of operating under conditions imposed as previously outlined. It is therefore concluded this test generically qualifies Limitorque Valve Actuators type SMB/SB for Class IE Service outside Primary Containment for conditions as defined in this report.



APPENDIX I  
INSTRUMENTATION & CALIBRATION



TABLE I  
SUMMARY OF DATA ACQUISITION SYSTEM

| MEASUREMENT CATEGORIES, IEEE STD. 382 para. 4.5.1 | PARAMETER              | ITEM NO. | MEASURING SYSTEM  |  |  | MONITORING POINT   | LAST CALIBRATION | NEXT CALIBRATION |
|---|------------------------|----------|---|--|--|--|------------------|------------------|
|   |                        |          | INDICATOR   | SIGNAL CONDITIONER   | X-DUCER  |  |                  |                  |
| I - ENVIRONMENT                                   | TEMPERATURE            | 1.       | Multipoint Temperature Recorder Type J T.C.   | 1<br>2<br>3<br>4<br>5<br>6<br>7,10<br>8,11<br>9,12<br>13,15,17<br>14,16,18<br>19,21,23<br>20,22,24 | 1B T.C.-J(2)<br>2A T.C.-J(2)<br>3B T.C.-J(2)<br>4B T.C.-J(2)<br>- -<br>- -<br>5 T.C.-J<br>6 T.C.-J<br>7 T.C.-J<br>8 T.C.-J<br>9 T.C.-J<br>10 T.C.-J<br>11 T.C.-J | Chamber Amb<br>Test Unit<br>L. S. Comp<br>Chamber Amb<br>Room Amb.<br>Shorted<br>Condensate<br>Press x-D#2<br>Press x-D#3<br>Press x-D#4<br>Press x-D#1<br>H <sub>2</sub> O input<br>H <sub>2</sub> O output | Feb. 1974        | Feb. 1975        |
|   | TEMPERATURE & PRESSURE | 2.       | Strip Chart Recorder 8 Channel<br><br>Gulton TR888<br><br>S/N 3042802<br><br>Note: Amp. TSC 801<br>T.C. Mod. TSC 500J | 1 Amplif.<br>2 "<br>3 "<br>4 "<br>5 T.C. Mod<br>6 "<br>7 "<br>8 "                                  | Press x-D#1<br>Press x-D#2<br>Press x-D#3<br>Press x-D#4<br>1A T.C.-J(2)<br>2B T.C.-J(2)<br>3A T.C.-J(2)<br>4A T.C.-J(2)   | Chamber Amb<br>Test Unit<br>L. S. Comp.<br>Chamber Amb<br>Chamber Amb<br>Test Unit<br>L. S. Comp.<br>Chamber Amb   | Sept. 1974       | March 1975       |



TABLE I (continued)  
SUMMARY OF DATA ACQUISITION SYSTEM

| MEASUREMENT CATEGORIES, IEEE STD. 382 para. 4.5.1 | PARAMETER   | ITEM NO. | MEASURING SYSTEM  |   |         | MONITORING POINT        | LAST CALIBRATION | NEXT CALIBRATION |
|---|-------------|----------|---|---|---------|-------------------------|------------------|------------------|
|   |             |          | INDICATOR   | SIGNAL CONDITIONER                                      | X-DUCER |                         |                  |                  |
| I - ENVIRONMENT                                   | TEMPERATURE | 3        | Mercury bulb Thermometer<br>Wexler 50-400 F.                |   |         | Chamber Ambient         | New 2/74         | 2/75             |
|   |             | 4        | Bi-metal Dial Thermometer<br>Wexler 50-400 F.               |   |         | Chamber Ambient         | New 2/74         | 2/75             |
|   | PRESSURE    | 5        | Dial Pressure Gage<br>Ashcroft 30 in Hg to 200 psig         |   |         | Chamber Pressure        | 11/74            | 5/75             |
|   | TIME        | 6        | Time of Day<br>Wall-clock                                   |   |         | Time of Day             | -                | -                |
|   |             | 7        | Running Time Clock<br>1000 hours, 0.1 hr.<br>Resolution     |   |         | Total Test Time         | -                | -                |
| II-POWER & CYCLE TIME                             | LOAD        | 8        | Strain Indicator<br>Bridge<br>BL & H<br>Typen<br>S/N 443604 | 20,000 lb.<br>Load<br>Cell<br>BL & H<br>U-1<br>S/N 2512 |         | Test Unit Thrust Output | 12/74            | 12/75            |





TABLE I (continued)

## SUMMARY OF DATA ACQUISITION SYSTEM

| MEASUREMENT<br>CATEGORIES, IEEE<br>STD. 382 para. 4.5.1 | PARAMETER | ITEM NO. | MEASURING SYSTEM  |                       |         | MONITORING<br>POINT                    | LAST CALIBRATION | NEXT CALIBRATION |
|---|-----------|----------|---|-----------------------|---------|--|------------------|------------------|
|   |           |          | INDICATOR   | SIGNAL<br>CONDITIONER | X-DUCER |  |                  |                  |
| II - POWER & CYCLE TIME                                 | POWER     | 9        | 3 phase Recording<br>Watimeter<br><br>Esterline Angus<br>Model A 601C<br>S/N 192358   |                       |         | Power<br>Consumption<br>of<br>Operator | New<br>2/74      | 2/75             |
|   | CURRENT   | 10       | Panel Meters<br><br>3 meters one in each phase<br><br>Low Range - 3-0-10<br>amp meters<br>Triplett Type<br><br>Hi Range - 3-0-50<br>amp meters<br>Triplett Type 430 |                       |         | Test<br>Unit<br>Current                | New<br>3/74      | 3/75             |
|   | VOLTAGE   | 11       | Panel Meters<br>3 meters one across<br>each phase<br><br>0-500VAC Triplett<br>Type 430  |                       |         | Test Unit<br>Voltage                   | New<br>3/74      | 3/75             |



TABLE I (continued)  
SUMMARY OF DATA ACQUISITION SYSTEM

| MEASUREMENT CATEGORIES    | PARAMETER | ITEM NO. | MEASURING SYSTEM   |                    |         | MONITORING POINT                   | LAST CALIBRATION                     | NEXT CALIBRATION       |
|---------------------------|-----------|----------|--|--------------------|---------|------------------------------------|--------------------------------------|------------------------|
|                           |           |          | INDICATOR  | SIGNAL CONDITIONER | X-DUCER |                                    |                                      |                        |
| II Power & Cycle          | TIME      | 12       | Stopwatch<br>Hever S/N 512406  |                    |         | Stroke Time                        | -                                    | -                      |
| III Fluid Characteristics | FLOW      | 13       | Flow Meters (2)<br>Fisher & Porter<br><br><u>Model</u> <u>S/N</u><br>10A1735Y                      7309A0574A1<br>10A1735                        7407A0403A1 |                    |         | Chemical Flow                      | New 2/74                             | 2/75                   |
|                           | PRESSURE  | 14       | 2 Dial Pressure Gages<br>(2) Wesler Model BA14P<br>1 Acco Helicoid<br>0-200 psig   |                    |         | Manifold Pressure<br>Pump Pressure | New 2/74                             | 2/75<br>Indicator only |
|                           | PH        | 15       | PH Meter   |                    |         | PH of Chem. Solution               | Comparison Against Standard Solution |                        |
| V Electrical Resistance   |           | 16       | Megohmmeter<br>James G. Biddle<br>Model 21159<br>S/N 732521  |                    |         | Motor & Control Leads              | New 2/74                             | 2/75                   |



APPENDIX II

CERTIFICATE OF COMPLIANCE - RADIATION EXPOSURE





Mr. W. J. Denkowski  
Chief Engineer  
Limitorque Corporation  
181 South Gulph Road  
King of Prussia, Pa. 19406

Dear Mr. Denkowski:

This will summarize the parameters pertinent to the irradiation of three valve operators, three motor assemblies, and several small miscellaneous pieces of electrical equipment. Identification of the test equipment is per your Order #600461, dated November 12, 1974. Included were:

Valve Operators

1. 1 each SMBO unit, 25 ft.# Reliance Motor, Class B
2. 1 each SMB000 unit, 25 ft.# Reliance Motor, Class B
3. 1 each SBB1 unit, 40ft.# Electric Apparators Motor  
Class B

Motors

4. 5 ft.# Paramount Motor
5. 25 ft.# Reliance Motor
6. 40 ft.# Electric Apparatus Motor


Other

7. 3 bags, plastic limit switch and torque switch  
parts contained in Valve Operators.
8. 1 Helipot contained in Item 3.

In Phase I of the exposure, all units were placed in a co-60 field of  $1 \times 10^6$  rad per hour at an air equivalent dose. They were rotated several times during the exposure to achieve a more uniform dose distribution. Total dose received to the centerline of all units was 20 Mrad (air equivalent) with an overdose factor on the edges of the units of up to 1.2. Irradiation was in air at ambient temperature in a slight negative pressure. The temperature of the samples during irradiation did not exceed 100°F.

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey (201) 887-4700  
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

CHICAGO DIVISION • 7828 Nagle Ave., Morton Grove, Illinois 60053 (312) 966-1160





Mr. W. J. Denkowski

-2-


December 24, 1974

Phase I of the irradiation was completed on November 21, 1974, and all units were picked up by your personnel.

Phase II of the test included exposing only the motors and miscellaneous parts to an additional 184 Mrad. The procedure was identical to the Phase I step, and irradiation was completed on December 16, 1974. Their total dose was 204 Mrad, with an overdose factor of up to 1.2 on the outer edges of the units.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on January 15, 1974 by the Victoreen Instrument Company, using Cobalt-60 and Cesium-137 sources whose calibrations are traceable to the U.S. National Bureau of Standards. A copy of the calibration certificate is available. Dosimetry utilizing a Red Perspex system was also completed, and confirmed the Victoreen readings.

Very truly yours,



George R. Dietz  
Manager, Radiation Services


GRD:dp



APPENDIX III  
TEST REPORT - SEISMIC AGING



AERO  
NAV  
LABORATORIES, INC.



14-29 112TH STREET • COLLEGE POINT, N.Y. 11356 • (212) 939-4422

( UNCLASSIFIED )

REPORT OF SEISMIC TEST  
ON  
SMBO-25 MOTOR ACTUATOR  
FOR  
LIMITORQUE CORPORATION  
KING OF PRUSSIA, PENNSYLVANIA


|                   |                    |                         |         |
|-------------------|--------------------|-------------------------|---------|
| TESTED BY         | <i>[Signature]</i> | ETL REPORT              | 5720    |
| CHECKED BY        | <i>[Signature]</i> | AERO NAV<br>SALES ORDER | 711-408 |
| APPROVED BY       | <i>[Signature]</i> | CUSTOMER<br>P.O.        | 600461  |
| DATE              | 6 JANUARY 1975     |                         |         |
| GOVERNMENT<br>QAR | NONE               |                         |         |



( UNCLASSIFIED )

ADMINISTRATIVE DATA

DATE  
6 January 1975



PURPOSE OF TEST: To determine the effects of Seismic Vibration on the physical and operational characteristics of the submitted specimen.

MANUFACTURER: LIMITORQUE CORPORATION  
181 S. Gulph Road  
King of Prussia, Pennsylvania 19406

MANUFACTURER TYPE AND SERIAL NUMBER: See Paragraph 2.0 for name plate data.

DRAWINGS SPECIFICATIONS OR EXHIBIT: Tested in accordance with detailed instructions of client and Limitorque Test Procedure (O/N 383964)

QUANTITY OF ITEMS TESTED: One (1) only

EQUIPMENT: Unclassified  
REPORT: Unclassified

DATE TEST COMPLETED: 25 November 1974

TEST CONDUCTED BY: AERO NAV LABORATORIES, INC.  
14-29 112th STREET  
COLLEGE POINT, NEW YORK 11356

DISPOSITION OF SPECIMEN: Returned to client


ABSTRACT: It is the function of the Aero Nav Laboratories, Inc., as an impartial testing agency in performing this test, to subject the specimen to seismic vibration of magnitude and direction as specified in the detailed specifications.





( UNCLASSIFIED )

FACTUAL DATA



1.0 DESCRIPTION OF TEST APPARATUS:

- 1.1 Vibration Machine and Control System, Type RVH-72-5000, Serial No. 51402, manufactured by L.A.B. Corporation. Calibration Due: 28 March 1975.
- 1.2 Accelerometers, Model 2213E, Serial Nos. CP36, CP37, CP48, LA57, CP38 and CP43, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.3 Amplifier, Model 2616, Serial No. CA13, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.4 Power Supply, Model 2622, Serial No. CA24, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.5 Band Pass Filter, Model No. 330M, Serial No. 2116, manufactured by Krohn-Hite Corporation. Calibration Due: 26 February 1975.
- 1.6 True R.M.S. VTVM, Model 320A, Serial No. 8622, manufactured by Ballantine Labs. Calibration Due: 3 March 1975.

2.0 NAME PLATE DATA:

2.1 Actuator: (See Page 3A for Motor Description)

Limitorque Corp. King of Prussia, Pa.  
Type - SMB-0 Size - 0  
Order - 500461B, SN - 195004

2.2 Extra Motor:

Limitorque Corp. King of Prussia, Pa.  
ID No. - 4470 14 - JZ  
Start - 25 LB FT, H.P. 1.6 Run 5 LB FT  
SF Type - P FR - P56, PH. 3  
RPM - 1700 HZ - 60 Volts 230/460  
Code AMPS - 8.0/4.0  
AMP °C - 40, Ins Class B  
Duty - 15 min.  
Reliance Electric Company  
Cleveland, Ohio



2.1 SMB-O SN-195004

Motor - Reliance

25 ft. lb. start - 5 ft. lb. run

ID 447014-BZ

Type P - 56 Frame

1700 RPM

230/460 volt - 3 phase, 60 hz.

8.0/4.0 amps.


Class B insulation - 15 minute duty

40 degree C.



( UNCLASSIFIED )

FACTUAL DATA



3.0 METHOD OF TEST:

The submitted specimen mounted in a fixture supplied by Limitorque Corporation was affixed to the table of the seismic simulator in such a manner that the axis of the stem nut was vertical. Five (5) accelerometers were used to monitor resonant conditions of the actuator.

A spare motor was also mounted on the seismic simulator and was subjected to the same conditions as the valve actuator, however, the motor was not monitored in any way.

During the test the actuator was electrically connected to a control console supplied by Limitorque.

3.1 Resonant Frequency Search:

The specimen was subjected to a resonant frequency search from 5 to 33 Hz. The applied excitation levels were in accordance with Table I. The frequency range was increased in discrete steps of 1 Hz and vibration was maintained at each frequency for a period of not less than six (6) seconds.

The above test was performed in each of the three (3) mutually perpendicular axis.

Table I - Amplitudes of Vibration

| <u>Frequency</u><br><u>(Hz)</u> | <u>Acceleration</u><br><u>(G peak)</u> |
|---------------------------------|--|
| 5 - 33                          | 0.1 to .75                             |

3.2 Seismic Dwell Test:


Upon completion of the resonant frequency search in each axis, the specimen was subjected to a seismic dwell test at each of the resonant frequencies noted during the resonant frequency search. If no resonant frequencies were noted the seismic dwell test was performed at 33 Hz. Five (5) thirty (30) second dwells were performed at 1/2g levels, and one (1) thirty (30) second dwell was performed at full g level.

During the dwell tests the unit was operated through its open and closed stroke.



( UNCLASSIFIED )

FACTUAL DATA



4.0 RESULTS OF TEST:

The following observations were noted and recorded during the above detailed test procedure:

- 4.1 Vertical Axis: (along the Actuator Stem)  
(Machine Axis - Horizontal)

Accelerometer Locations and Orientation:


- Input - On Table - Horizontal direction of Vibration
- Outputs - A- On Actuator near Stem - Vertical and perpendicular to direction of Vibration.
- B- On end of Motor - Horizontal in direction of Vibration.
- C- On end of Motor - Vertical and perpendicular to direction of Vibration.
- D- On Actuator near Handwheel Shaft - Horizontal and perpendicular to direction of vibration.
- E- On Actuator near Stem - Horizontal in direction of Vibration.





( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)


4.1.1 Resonant Frequency Search:

| Frequency<br>(Hz) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|-------------------|----------------|---------------|-------|-------|-------|-------|
|                   |                | A             | B     | C     | D     | E     |
| 5                 | 0.240          | 0.035         | 0.270 | 0.120 | 0.060 | 0.240 |
| 6                 | 0.380          | 0.050         | 0.370 | 0.250 | 0.100 | 0.370 |
| 7                 | 0.470          | 0.060         | 0.500 | 0.150 | 0.150 | 0.470 |
| 8                 | 0.660          | 0.060         | 0.670 | 0.250 | 0.200 | 0.640 |
| 9                 | 0.370          | 0.002         | 0.370 | 0.100 | 0.040 | 0.400 |
| 10                | 0.490          | 0.020         | 0.480 | 0.100 | 0.050 | 0.470 |
| 11                | 0.600          | 0.040         | 0.600 | 0.120 | 0.045 | 0.570 |
| 12                | 0.670          | 0.030         | 0.660 | 0.100 | 0.060 | 0.640 |
| 13                | 0.160          | 0.058         | 0.170 | 0.050 | 0.060 | 0.150 |
| 14                | 0.190          | 0.020         | 0.190 | 0.060 | 0.040 | 0.180 |
| 15                | 0.220          | 0.025         | 0.230 | 0.100 | 0.050 | 0.210 |
| 16                | 0.250          | 0.025         | 0.260 | 0.080 | 0.040 | 0.240 |
| 17                | 0.280          | 0.035         | 0.280 | 0.110 | 0.050 | 0.270 |
| 18                | 0.310          | 0.030         | 0.320 | 0.060 | 0.040 | 0.300 |
| 19                | 0.350          | 0.037         | 0.360 | 0.090 | 0.050 | 0.340 |
| 20                | 0.390          | 0.040         | 0.400 | 0.040 | 0.040 | 0.360 |
| 21                | 0.430          | 0.055         | 0.450 | 0.080 | 0.045 | 0.430 |
| 22                | 0.470          | 0.057         | 0.480 | 0.060 | 0.025 | 0.470 |
| 23                | 0.500          | 0.060         | 0.520 | 0.070 | 0.030 | 0.500 |
| 24                | 0.550          | 0.068         | 0.057 | 0.090 | 0.035 | 0.550 |
| 25                | 0.600          | 0.085         | 0.640 | 0.180 | 0.060 | 0.610 |
| 26                | 0.650          | 0.090         | 0.700 | 0.180 | 0.070 | 0.670 |
| 27                | 0.220          | 0.050         | 0.300 | 0.130 | 0.060 | 0.250 |
| 28                | 0.240          | 0.052         | 0.320 | 0.110 | 0.050 | 0.270 |
| 29                | 0.260          | 0.060         | 0.350 | 0.110 | 0.060 | 0.290 |
| 30                | 0.270          | 0.065         | 0.360 | 0.120 | 0.050 | 0.320 |
| 31                | 0.290          | 0.074         | 0.400 | 0.130 | 0.200 | 0.500 |
| 32                | 0.310          | 0.080         | 0.420 | 0.150 | 0.250 | 0.500 |
| 33                | 0.330          | 0.090         | 0.450 | 0.170 | 0.200 | 0.420 |



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TESTS (continued)

- 4.2 Horizontal Axis: (perpendicular to Motor Axis)  
(Machine Axis - Vertical)

Accelerometer Locations and Orientation:

Input - On Table - Vertical - in direction of vibration

Outputs A-On Actuator near Stem - Vertical - in direction  
of Vibration

B-On end of Motor - Horizontal - Perpendicular to  
direction of Vibration

C-On end of Motor - Vertical - in direction of  
Vibration


D-On actuator near handwheel shaft - Horizontal and  
perpendicular to  
direction of  
Vibration

E-On actuator near stem - Horizontal - perpendicular  
to direction  
of Vibration



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TESTS.(continued)


4.2.1 Resonant Frequency Search:

| Frequency<br>(Hz) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|-------------------|----------------|---------------|-------|-------|-------|-------|
|                   |                | A             | B     | C     | D     | E     |
| 5                 | 0.230          | 0.230         | 0.030 | 0.230 | 0.040 | 0.035 |
| 6                 | 0.340          | 0.340         | 0.035 | 0.340 | 0.040 | 0.060 |
| 7                 | 0.410          | 0.410         | 0.035 | 0.400 | 0.040 | 0.040 |
| 8                 | 0.540          | 0.530         | 0.040 | 0.540 | 0.024 | 0.050 |
| 9                 | 0.690          | 0.690         | 0.050 | 0.680 | 0.035 | 0.045 |
| 10                | 0.220          | 0.220         | 0.048 | 0.250 | 0.040 | 0.050 |
| 11                | 0.250          | 0.250         | 0.040 | 0.240 | 0.025 | 0.025 |
| 12                | 0.300          | 0.290         | 0.030 | 0.300 | 0.015 | 0.020 |
| 13                | 0.340          | 0.330         | 0.030 | 0.330 | 0.015 | 0.023 |
| 14                | 0.390          | 0.380         | 0.035 | 0.380 | 0.100 | 0.150 |
| 15                | 0.460          | 0.450         | 0.045 | 0.460 | 0.040 | 0.040 |
| 16                | 0.530          | 0.510         | 0.035 | 0.520 | 0.035 | 0.050 |
| 17                | 0.580          | 0.570         | 0.045 | 0.580 | 0.100 | 0.200 |
| 18                | 0.660          | 0.650         | 0.060 | 0.700 | 0.200 | 0.100 |
| 19                | 0.320          | 0.310         | 0.040 | 0.340 | 0.040 | 0.025 |
| 20                | 0.350          | 0.350         | 0.050 | 0.380 | 0.200 | 0.200 |
| 21                | 0.380          | 0.390         | 0.070 | 0.420 | 0.150 | 0.200 |
| 22                | 0.420          | 0.430         | 0.050 | 0.470 | 0.200 | 0.200 |
| 23                | 0.450          | 0.470         | 0.050 | 0.500 | 0.200 | 0.200 |
| 24                | 0.490          | 0.520         | 0.058 | 0.570 | 0.100 | 0.150 |
| 25                | 0.540          | 0.570         | 0.070 | 0.640 | 0.120 | 0.150 |
| 26                | 0.240          | 0.250         | 0.090 | 0.290 | 0.100 | 0.100 |
| 27                | 0.260          | 0.290         | 0.110 | 0.380 | 0.100 | 0.100 |
| 28                | 0.270          | 0.290         | 0.070 | 0.350 | 0.060 | 0.060 |
| 29                | 0.290          | 0.320         | 0.080 | 0.370 | 0.150 | 0.100 |
| 30                | 0.300          | 0.330         | 0.070 | 0.400 | 0.120 | 0.150 |
| 31                | 0.320          | 0.360         | 0.080 | 0.440 | 0.120 | 0.200 |
| 32                | 0.350          | 0.390         | 0.080 | 0.480 | 0.080 | 0.120 |
| 33                | 0.370          | 0.420         | 0.090 | 0.540 | 0.200 | 0.200 |



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TESTS (continued)

- 4.3 Horizontal Axis: (Parallel to Motor Axis)  
(Machine Axis - Horizontal)

Accelerometer Locations and Orientation:

Input - On Table - Horizontal - in direction of vibration

Outputs A-On Actuator near Stem - Horizontal and perpendicular  
to direction of vibration

B-On Motor End - Horizontal and perpendicular to  
direction of vibration

C-On Motor End - Vertical and perpendicular to  
direction of vibration

D-On Actuator near Handwheel Shaft - Horizontal -  
in direction of  
vibration


E-On Actuator near Stem - Vertical and perpendicular  
to axis of vibration





( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TESTS (continued)


4.3.1 Resonant Frequency Search:

| Frequency<br>(Hz) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|-------------------|----------------|---------------|-------|-------|-------|-------|
|                   |                | A             | B     | C     | D     | E     |
| 5                 | 0.170          | 0.020         | 0.060 | 0.050 | 0.200 | 0.050 |
| 6                 | 0.230          | 0.025         | 0.060 | 0.070 | 0.300 | 0.030 |
| 7                 | 0.330          | 0.050         | 0.070 | 0.045 | 0.340 | 0.050 |
| 8                 | 0.440          | 0.040         | 0.070 | 0.050 | 0.410 | 0.080 |
| 9                 | 0.530          | 0.040         | 0.060 | 0.030 | 0.530 | 0.080 |
| 10                | 0.650          | 0.035         | 0.050 | 0.030 | 0.650 | 0.020 |
| 11                | 0.180          | 0.015         | 0.040 | 0.035 | 0.200 | 0.100 |
| 12                | 0.210          | 0.015         | 0.045 | 0.030 | 0.200 | 0.025 |
| 13                | 0.240          | 0.020         | 0.040 | 0.035 | 0.250 | 0.030 |
| 14                | 0.290          | 0.015         | 0.030 | 0.030 | 0.280 | 0.035 |
| 15                | 0.330          | 0.015         | 0.030 | 0.030 | 0.310 | 0.050 |
| 16                | 0.370          | 0.030         | 0.050 | 0.035 | 0.370 | 0.040 |
| 17                | 0.420          | 0.017         | 0.040 | 0.030 | 0.400 | 0.060 |
| 18                | 0.470          | 0.015         | 0.030 | 0.030 | 0.480 | 0.090 |
| 19                | 0.520          | 0.013         | 0.030 | 0.030 | 0.560 | 0.070 |
| 20                | 0.590          | 0.015         | 0.030 | 0.030 | 0.570 | 0.080 |
| 21                | 0.650          | 0.025         | 0.055 | 0.035 | 0.630 | 0.070 |
| 22                | 0.160          | 0.030         | 0.070 | 0.045 | 0.160 | 0.040 |
| 23                | 0.170          | 0.025         | 0.070 | 0.050 | 0.180 | 0.070 |
| 24                | 0.190          | 0.040         | 0.090 | 0.045 | 0.190 | 0.035 |
| 25                | 0.210          | 0.035         | 0.080 | 0.045 | 0.220 | 0.120 |
| 26                | 0.220          | 0.035         | 0.090 | 0.050 | 0.230 | 0.050 |
| 27                | 0.240          | 0.035         | 0.070 | 0.045 | 0.240 | 0.080 |
| 28                | 0.250          | 0.030         | 0.070 | 0.045 | 0.300 | 0.080 |
| 29                | 0.270          | 0.025         | 0.060 | 0.050 | 0.310 | 0.080 |
| 30                | 0.290          | 0.025         | 0.070 | 0.060 | 0.310 | 0.100 |
| 31                | 0.310          | 0.060         | 0.120 | 0.050 | 0.380 | 0.300 |
| 32                | 0.330          | 0.130         | 0.300 | 0.060 | 0.400 | 0.200 |
| 33                | 0.350          | 0.100         | 0.220 | 0.060 | 0.470 | 0.200 |



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TESTS (continued)

4.4 Seismic Dwell Tests:

4.4.1 Vertical Axis (along the actuator stem)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 3.0 g's and one run was performed at an input of 6.0 g's.

During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.

4.4.2 Horizontal Axis (parallel to motor axis)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 4.9 g's and one run was performed at an input of 6.1 g's.

During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.

4.4.3 Horizontal Axis (perpendicular to motor axis)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 3.2 g's and one run was performed at an input of 6.2 g's.


During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.



( UNCLASSIFIED )

FACTUAL DATA



5.0 VISUAL POST TEST EXAMINATION:

Visual post test examination revealed no evidence of any external physical damage as a result of the stress of this test.

6.0 RECOMMENDATIONS:


None, data merely submitted.

7.0 CONCLUSIONS:


Final evaluation of the submitted specimen for conformance to the requirements of the detailed specifications will be accomplished by Limitorque Corporation upon review of the results reported herein and further examination as required.



( UNCLASSIFIED )



LIMITORQUE CORPORATION  
KING OF PRUSSIA, PENNSYLVANIA  
SMBO-25 MOTOR ACTUATOR



Seismic Test Setup





## TEST REPORT

Subject: Pre Seismic Torque Switch calibration and Operation  
monitoring performed during seismic testing SMB-O-25.

Reference: Limitorque P.O. 383964

Aero Nav Report 5720

### Unit Identification & Description

SMB-O Limitorque Valve Control with Reliance

25 ft. lb. motor

Unit Serial No. 195004

Motor I.D. No. 447014-BZ

Test Motor (#1)

I.D. No. 447014-JZ

### Pre-Test Torque Switch Calibration

Procedure: Measure thrust output of SMB-O using a 2-3/8 x 1/4 x 1/4  
stem and 20,000 lb. load cell.

Results: A thrust load of 20,350 lbs. (Ave. of 6 readings) was  
obtained at a torque switch setting of 2-1/2.

Approximate Torque:

Torque = Thrust x Stem Factor

SF 2 3/8" x 1/4 x 1/4 stem = .0229

Torque = 20,350 x .0229 = 466 ft. lbs.

### Seismic Test Operation Monitoring

Procedure: All limit switch rotors were monitored by means of  
indicator lights.



Two (2) contacts (one each on each of two (2) spare rotors) were wired in series with a sensitive relay to detect chatter during the stroke of the actuator. The actuator was run from an open position (controlled by a limit switch) to a closed torqued-out position (controlled by the torque switch) back to the open limit position during each of the dwells and at the end of the seismic aging cycle. The test motor (#1) was mounted next to the SMB-O to receive the same seismic aging as the unit.

Results:

The unit functioned properly, performing all control functions and indicating functions. There was no evidence of contact chatter during the dwells.

Conclusion:

Due to severe "cross talk" detected on the seismic table, attempts to include "cross coupling" was disregarded and the unit run at 3g's for five dwells and 6g acceleration for one dwell in each axis. Later tests on an equivalent unit (Aero Nav Report 5772) proved cross coupling to be negligible. Since the Valve Actuator performed satisfactorily in all functions, and since later tests indicated negligible cross-coupling, the unit is considered qualified per IEEE 344-75 specification for seismic levels up to 6g's.




AERO NAV REPORT 5722

VERIFICATION OF SEISMIC AGING

TEST MOTOR #2



AERO  
NAV  
LABORATORIES, INC.



14-29 112TH STREET • COLLEGE POINT, N.Y. 11356 • (212) 939-4422

( UNCLASSIFIED )

REPORT OF SEISMIC TEST  
ON  
SMB-1 MOTOR ACTUATOR  
FOR  
LIMITORQUE CORPORATION  
KING OF PRUSSIA, PENNSYLVANIA

|                   |                    |                         |         |
|-------------------|--------------------|-------------------------|---------|
| TESTED BY         | <i>[Signature]</i> | ETL REPORT              | 5722    |
| CHECKED BY        | <i>[Signature]</i> | AERO NAV<br>SALES ORDER | 711-408 |
| APPROVED BY       | <i>[Signature]</i> | CUSTOMER<br>P.O.        | 600461  |
| DATE              | 7 JANUARY 1975     |                         |         |
| GOVERNMENT<br>QAR | NONE               |                         |         |






( UNCLASSIFIED )

ADMINISTRATIVE DATA

DATE  
7 January 1975



PURPOSE OF TEST: To determine the effects of Seismic Vibration on the physical and operational characteristics of the submitted specimen.

MANUFACTURER: LIMITORQUE CORPORATION  
181 S. Gulph Road  
King of Prussia, Pennsylvania 19406

MANUFACTURER TYPE  
AND SERIAL NUMBER: See Paragraph 2.0 for name plate data.

DRAWINGS SPECIFICATIONS  
OR EXHIBIT: Tested in accordance with detailed instructions of client and Limitorque Test Procedure (O/N 383964)

QUANTITY OF ITEMS  
TESTED: One (1) only

EQUIPMENT:  
REPORT: Unclassified  
Unclassified

DATE TEST COMPLETED: 3 December 1974

TEST CONDUCTED BY: AERO NAV LABORATORIES, INC.  
14-29 112th STREET  
COLLEGE POINT, NEW YORK 11356


DISPOSITION OF SPECIMEN: Returned to client

ABSTRACT: It is the function of the Aero Nav Laboratories, Inc., as an impartial testing agency in performing this test, to subject the specimen to seismic vibration of magnitude and direction as specified in the detailed specifications.



( UNCLASSIFIED )

FACTUAL DATA



1.0 DESCRIPTION OF TEST APPARATUS:

- 1.1 Vibration Machine and Control System, Type RVH-72-5000, Serial No. 51402, manufactured by L.A.B. Corporation. Calibration Due: 28 March 1975.
- 1.2 Accelerometers, Model 2213E, Serial Nos. CP36, CP37, CP48, LA57, CP38 and CP43, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.3 Amplifier, Model 2616, Serial No. CA13, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.4 Power Supply, Model 2622, Serial No. CA24, manufactured by Endevco Corporation. Calibration Due: 18 January 1975.
- 1.5 Band Pass Filter, Model No. 330M, Serial No. 2116, manufactured by Krohn-Hite Corporation. Calibration Due: 26 February 1975.
- 1.6 True R.M.S. VTVM, Model 320A, Serial No. 8622, manufactured by Ballantine Labs. Calibration Due: 3 March 1975.

2.0 NAME PLATE DATA:

2.1 Actuator: (See Page 3A for Motor Description)

Limitorque Corp. King of Prussia, Pa.  
Type SMB Size - 1  
Order 600461C Serial 195005

2.2 Extra Motor:

|                          |             |               |
|--------------------------|-------------|---------------|
| Serial - 742-19564K-09   | Frame C184Y | RPM 1705      |
| Start Torque - 40 ft lbs | Type Dat    | Phase 3       |
| Run Torque - 8 ft lbs    | Hz 60       | Code L        |
| Volts - 220/440          | °C Rise 75  | Duty - 15 min |
| Amps - 11.6/5.8          |             | SF 1.0        |
| Ins - Class B            |             |               |




2.1 SMB-1 SN-195005

Motor

Electric Apparatus  
40 ft. lb. start, 8 ft. lb. run  
1D 733-18869-12  
Type DAT - 140 Y Frame  
1720 RPM  
220/440 volt- 3 phase - 60 hz  
12.6/6.3 amps.  
Class B insulation - 15 minute duty  
75 degree C rise



FACTUAL DATA



3.0 METHOD OF TEST:

The submitted specimen mounted in a fixture supplied by Limitorque Corporation was affixed to the table of the seismic simulator in such a manner that the axis of the stem nut was vertical. Five (5) accelerometers were used to monitor for resonant conditions of the actuator.

A spare motor was also mounted on the seismic simulator and was subjected to the same conditions as the valve actuator, however, the motor was not monitored in any way.

During this test the actuator was electrically connected to a control console supplied by Limitorque.

3.1 Resonant Frequency Search:

The specimen was subjected to a resonant frequency search from 5 to 33 Hz. The applied excitation levels were in accordance with Table I. The frequency range was increased in discrete steps of 1 Hz and vibration was maintained at each frequency for a period of not less than six (6) seconds.

The above test was performed in each of the three (3) mutually perpendicular axis.

Table I - Amplitudes of Vibration

| <u>Frequency</u><br><u>(Hz)</u> | <u>Acceleration</u><br><u>(G peak)</u> |
|---------------------------------|--|
| 5 - 33                          | .1 to .75                              |

3.2 Seismic Dwell Test:

Upon completion of the resonant frequency search in each axis, the specimen was subjected to a seismic dwell test at each of the resonant frequencies noted during the resonant frequency search. If no resonant frequencies were noted the seismic dwell test was performed at 33 Hz.

Five (5) thirty (30) second dwells were performed at 1/2 g levels, and one (1) thirty (30) second dwell was performed at full g level.


During the dwell tests the unit was operated through its open and closed stroke.





( UNCLASSIFIED )

FACTUAL DATA



4.0 RESULTS OF TEST:

The following observations were noted and recorded during the above detailed test procedure:

- 4.1 Vertical Axis: (Along the actuator stem)  
(Machine Axis - Horizontal)

Accelerometer Locations and Orientation:

Input - On Table - Horizontal - in direction of vibration

Outputs A-On actuator near stem - Horizontal - in direction  
of vibration

B-On end of motor - Horizontal - in direction of  
vibration

C-On end of motor - Vertical and perpendicular to  
direction of vibration


D-On actuator near stem - Vertical and perpendicular  
to direction of vibration

E-On actuator near hand wheel shaft - horizontal and  
perpendicular  
to direction of  
vibration



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)


4.1.1 Resonant Frequency Search:

| Frequency<br>(Hz) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|-------------------|----------------|---------------|-------|-------|-------|-------|
|                   |                | A             | B     | C     | D     | E     |
| 5                 | 0.160          | 0.160         | 0.160 | 0.040 | 0.080 | 0.060 |
| 6                 | 0.270          | 0.280         | 0.280 | 0.090 | 0.070 | 0.070 |
| 7                 | 0.370          | 0.370         | 0.370 | 0.120 | 0.080 | 0.070 |
| 8                 | 0.450          | 0.460         | 0.450 | 0.110 | 0.100 | 0.100 |
| 9                 | 0.600          | 0.620         | 0.610 | 0.250 | 0.160 | 0.150 |
| 10                | 0.720          | 0.730         | 0.720 | 0.100 | 0.120 | 0.110 |
| 11                | 0.130          | 0.140         | 0.140 | 0.030 | 0.040 | 0.060 |
| 12                | 0.150          | 0.170         | 0.170 | 0.035 | 0.045 | 0.040 |
| 13                | 0.210          | 0.230         | 0.230 | 0.030 | 0.040 | 0.050 |
| 14                | 0.270          | 0.280         | 0.280 | 0.030 | 0.050 | 0.050 |
| 15                | 0.320          | 0.340         | 0.340 | 0.025 | 0.015 | 0.020 |
| 16                | 0.350          | 0.380         | 0.380 | 0.030 | 0.040 | 0.040 |
| 17                | 0.400          | 0.430         | 0.430 | 0.035 | 0.050 | 0.060 |
| 18                | 0.430          | 0.470         | 0.470 | 0.070 | 0.035 | 0.030 |
| 19                | 0.490          | 0.550         | 0.550 | 0.080 | 0.050 | 0.035 |
| 20                | 0.550          | 0.610         | 0.610 | 0.060 | 0.050 | 0.018 |
| 21                | 0.610          | 0.720         | 0.710 | 0.080 | 0.060 | 0.020 |
| 22                | 0.690          | 0.800         | 0.790 | 0.120 | 0.090 | 0.060 |
| 23                | 0.700          | 0.880         | 0.860 | 0.140 | 0.090 | 0.012 |
| 24                | 0.180          | 0.230         | 0.230 | 0.040 | 0.050 | 0.040 |
| 25                | 0.200          | 0.250         | 0.250 | 0.060 | 0.050 | 0.070 |
| 26                | 0.220          | 0.280         | 0.280 | 0.060 | 0.060 | 0.035 |
| 27                | 0.230          | 0.310         | 0.300 | 0.080 | 0.080 | 0.070 |
| 28                | 0.250          | 0.350         | 0.340 | 0.100 | 0.120 | 0.090 |
| 29                | 0.260          | 0.390         | 0.360 | 0.110 | 0.090 | 0.060 |
| 30                | 0.270          | 0.440         | 0.410 | 0.160 | 0.150 | 0.100 |
| 31                | 0.300          | 0.510         | 0.460 | 0.230 | 0.110 | 0.120 |
| 32                | 0.310          | 0.580         | 0.510 | 0.340 | 0.150 | 0.090 |
| 33                | 0.330          | 0.720         | 0.590 | 0.540 | 0.250 | 0.150 |



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued):

- 4.2 Horizontal Axis: (Perpendicular to Motor Axis)  
(Machine Axis - Vertical)

Accelerometer Locations and Orientation:

Input - On Table - Vertical - in direction of vibration

Outputs A-On actuator near stem - Horizontal - perpendicular  
to direction  
of vibration

B-On end of motor - Horizontal - perpendicular to  
direction of vibration

C-On end of motor - Vertical - in direction of  
vibration


D-On actuator near stem - Vertical - in direction of  
vibration

E-On actuator near handwheel shaft - Horizontal and  
perpendicular to  
direction of  
vibration.



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)

4.2.1 Resonant Frequency Search:


| Frequency<br>(Hz.) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|--------------------|----------------|---------------|-------|-------|-------|-------|
|                    |                | A             | B     | C     | D     | E     |
| 5                  | 0.170          | 0.012         | 0.017 | 0.180 | 0.170 | 0.012 |
| 6                  | 0.250          | 0.013         | 0.019 | 0.250 | 0.240 | 0.013 |
| 7                  | 0.290          | 0.013         | 0.022 | 0.300 | 0.280 | 0.012 |
| 8                  | 0.370          | 0.018         | 0.022 | 0.390 | 0.360 | 0.025 |
| 9                  | 0.440          | 0.025         | 0.035 | 0.480 | 0.450 | 0.060 |
| 10                 | 0.580          | 0.035         | 0.030 | 0.610 | 0.560 | 0.050 |
| 11                 | 0.640          | 0.044         | 0.035 | 0.710 | 0.660 | 0.035 |
| 12                 | 0.790          | 0.060         | 0.040 | 0.850 | 0.780 | 0.070 |
| 13                 | 0.250          | 0.027         | 0.060 | 0.250 | 0.250 | 0.050 |
| 14                 | 0.290          | 0.070         | 0.065 | 0.330 | 0.350 | 0.060 |
| 15                 | 0.330          | 0.050         | 0.200 | 0.360 | 0.320 | 0.070 |
| 16                 | 0.380          | 0.048         | 0.040 | 0.420 | 0.400 | 0.060 |
| 17                 | 0.420          | 0.060         | 0.045 | 0.480 | 0.430 | 0.025 |
| 18                 | 0.460          | 0.070         | 0.065 | 0.530 | 0.490 | 0.050 |
| 19                 | 0.510          | 0.090         | 0.070 | 0.630 | 0.540 | 0.035 |
| 20                 | 0.570          | 0.110         | 0.065 | 0.700 | 0.580 | 0.050 |
| 21                 | 0.640          | 0.170         | 0.080 | 0.850 | 0.680 | 0.060 |
| 22                 | 0.700          | 0.170         | 0.090 | 0.940 | 0.750 | 0.050 |
| 23                 | 0.190          | 0.050         | 0.045 | 0.250 | 0.210 | 0.045 |
| 24                 | 0.210          | 0.065         | 0.120 | 0.300 | 0.250 | 0.070 |
| 25                 | 0.230          | 0.080         | 0.160 | 0.350 | 0.270 | 0.080 |
| 26                 | 0.240          | 0.090         | 0.090 | 0.380 | 0.290 | 0.035 |
| 27                 | 0.250          | 0.110         | 0.080 | 0.430 | 0.330 | 0.100 |
| 28                 | 0.270          | 0.120         | 0.080 | 0.470 | 0.370 | 0.110 |
| 29                 | 0.360          | 0.400         | 0.090 | 0.540 | 0.400 | 0.130 |
| 30                 | 0.320          | 0.190         | 0.110 | 0.630 | 0.420 | 0.120 |
| 31                 | 0.330          | 0.220         | 0.130 | 0.720 | 0.470 | 0.110 |
| 32                 | 0.350          | 0.290         | 0.150 | 0.850 | 0.550 | 0.150 |
| 33                 | 0.370          | 0.340         | 0.180 | 1.000 | 0.600 | 0.200 |





( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)

- 4.3 Horizontal Axis: (Parallel to Motor Axis)  
(Machine Axis - Horizontal)

Accelerometer Locations and Orientation:


Input - On Table - Horizontal - in direction of vibration

Outputs A-On actuator near stem - Horizontal and perpendicular  
to direction of vibration  
B-On motor end - Horizontal and perpendicular to  
direction of vibration  
C-On motor end - Vertical and perpendicular to  
direction of vibration  
D-On actuator near stem - Vertical and perpendicular  
to axis of vibration  
E-On actuator near handwheel shaft - Horizontal - in  
direction of  
vibration.



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)


4.3.1 Resonant Frequency Search:

| Frequency<br>(Hz) | Input<br>(G's) | Outputs (G's) |       |       |       |       |
|-------------------|----------------|---------------|-------|-------|-------|-------|
|                   |                | A             | B     | C     | D     | E     |
| 5                 | 0.130          | 0.025         | 0.020 | 0.025 | 0.025 | 0.160 |
| 6                 | 0.170          | 0.025         | 0.070 | 0.060 | 0.070 | 0.180 |
| 7                 | 0.250          | 0.030         | 0.055 | 0.060 | 0.070 | 0.300 |
| 8                 | 0.320          | 0.035         | 0.055 | 0.060 | 0.060 | 0.350 |
| 9                 | 0.390          | 0.035         | 0.045 | 0.050 | 0.070 | 0.470 |
| 10                | 0.530          | 0.035         | 0.050 | 0.060 | 0.070 | 0.560 |
| 11                | 0.630          | 0.070         | 0.075 | 0.075 | 0.060 | 0.670 |
| 12                | 0.740          | 0.065         | 0.070 | 0.080 | 0.080 | 0.760 |
| 13                | 0.240          | 0.015         | 0.040 | 0.035 | 0.080 | 0.280 |
| 14                | 0.260          | 0.018         | 0.045 | 0.040 | 0.060 | 0.370 |
| 15                | 0.320          | 0.016         | 0.050 | 0.040 | 0.070 | 0.390 |
| 16                | 0.360          | 0.017         | 0.050 | 0.050 | 0.075 | 0.450 |
| 17                | 0.380          | 0.014         | 0.045 | 0.045 | 0.060 | 0.410 |
| 18                | 0.400          | 0.025         | 0.050 | 0.060 | 0.070 | 0.450 |
| 19                | 0.490          | 0.018         | 0.080 | 0.080 | 0.070 | 0.510 |
| 20                | 0.550          | 0.024         | 0.060 | 0.090 | 0.070 | 0.550 |
| 21                | 0.610          | 0.070         | 0.075 | 0.160 | 0.065 | 0.620 |
| 22                | 0.660          | 0.050         | 0.090 | 0.150 | 0.055 | 0.670 |
| 23                | 0.700          | 0.035         | 0.110 | 0.180 | 0.080 | 0.760 |
| 24                | 0.170          | 0.030         | 0.060 | 0.080 | 0.035 | 0.170 |
| 25                | 0.180          | 0.030         | 0.080 | 0.090 | 0.040 | 0.190 |
| 26                | 0.180          | 0.035         | 0.070 | 0.090 | 0.043 | 0.210 |
| 27                | 0.200          | 0.035         | 0.070 | 0.100 | 0.070 | 0.230 |
| 28                | 0.210          | 0.040         | 0.080 | 0.120 | 0.070 | 0.270 |
| 29                | 0.230          | 0.055         | 0.080 | 0.140 | 0.090 | 0.290 |
| 30                | 0.240          | 0.060         | 0.100 | 0.160 | 0.160 | 0.360 |
| 31                | 0.260          | 0.065         | 0.090 | 0.190 | 0.150 | 0.380 |
| 32                | 0.280          | 0.076         | 0.065 | 0.220 | 0.110 | 0.400 |
| 33                | 0.290          | 0.090         | 0.080 | 0.250 | 0.130 | 0.430 |



( UNCLASSIFIED )

FACTUAL DATA



RESULTS OF TEST (continued)

4.4 Seismic Dwell Tests:

4.4.1 Vertical Axis (along the actuator stem)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 3.0 g's and one run was performed at an input of 6.3 g's.

During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.

4.4.2 Horizontal Axis (parallel to motor axis)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 3.0 g's and one run was performed at an input of 6.0 g's.

During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.


4.4.3 Horizontal Axis (perpendicular to motor axis)

The Seismic Dwell tests were performed at 33 Hz for a duration of 30 seconds for each run.

Five runs were performed at an input of 3.0 g's and one run was performed at an input of 6.0 g's.


During the dwells the actuator was opened and closed.

There was no evidence of external physical damage as a result of the stress of this test.



( UNCLASSIFIED )

FACTUAL DATA



5.0 VISUAL POST TEST EXAMINATION:

Visual post test examination revealed no evidence of any additional external physical damage as a result of the stress of this test.

6.0 RECOMMENDATIONS:

None, data merely submitted.


7.0 CONCLUSIONS:

Final evaluation of the submitted specimen for conformance to the requirements of the detailed specifications will be accomplished by Limitorque Corporation upon review of the results reported herein and further examination as required.






( UNCLASSIFIED )



LIMITORQUE CORPORATION  
KING OF PRUSSIA, PENNSYLVANIA  
SMB-1 ACTUATOR




Seismic Test Setup




APPENDIX IV  
PHOTOGRAPHS - AT TEST CONCLUSION






742-19564K-09 PR. C184Y





74219564K-09 PR-C184Y




74219564K-09 PR. C184Y

TEST MOTOR #2  
POST TEST INSPECTION







447014-JZ P56 FR



447014-JZ P56 FR



447014-JZ P56 FR




447014-JZ P56 FR


TEST MOTOR #1  
POST TEST INSPECTION









TEST CHAMBER AFTER TEST






TEST UNIT #1 AFTER TEST





447014-B2 P56 FR.



447014-B2 FR P56



447014-B2 P56 FR.

MOTOR - VALVE ACTUATOR UNIT #1  
POST TEST INSPECTION



APPENDIX E

DC Actuator Qualification

Report B0009





QUALIFICATION TYPE TEST REPORT

LIMITORQUE DC VALVE ACTUATORS  
FOR NUCLEAR POWER STATION

SERVICE CONDITIONS

PER IEEE 382, 323 and 344

TEST PERFORMED SEPT. 2, 1975 to NOV. 3, 1975

PROJECT 600426

REPORT NO. B-0009

PREPARED BY

LIMITORQUE CORPORATION TEST LABORATORY

PREPARED BY:

Thomas D. Hess  
Tom Hess - Test Engineer

DATE:

4-30-76

APPROVED:

W.J. Bankowski  
W.J. Bankowski  
Chief Engineer

DATE:

4/30/76

ACCEPTED

C.D. Formica  
C.D. Formica  
Q.A. ADMINISTRATOR

DATE:

4/30/76



## TABLE OF CONTENTS

|     |                        |        |
|-----|------------------------|--------|
| 1.0 | Purpose of Test        | Page 1 |
| 2.0 | Test Plan              | Page 1 |
| 2.1 | Thermal Aging          |        |
| 2.2 | Mechanical Aging       |        |
| 2.3 | Radiation Exposure     |        |
| 2.4 | Seismic Aging          |        |
| 2.5 | Environmental Test     |        |
| 3.0 | Identification of Unit | Page 6 |
| 4.0 | Test Procedure         | Page 6 |
| 4.1 | Thermal Aging          |        |
| 4.2 | Mechanical Aging       |        |
| 4.3 | Radiation Exposure     |        |
| 4.4 | Seismic Aging          |        |
| 4.5 | Environmental Test     |        |
| 5.0 | Conclusions            | Page 9 |



## PROFILE AND DATA SHEETS

|   |         |
|---|---------|
| Figure 1 - Temperature Profile                  | Page 10 |
| Figure 2A - Insulation Resistance               | Page 11 |
| Figure 2B - Actuator Electrical Characteristics | Page 12 |
| Figure 3A - Environmental Parameters (sheet 1)  | Page 13 |
| Figure 3B - Environmental Parameters (sheet 2)  | Page 14 |
| Figure 3C - Environmental Parameters (sheet 3)  | Page 15 |

## APPENDICES

|  |  |
|--|--|
| Appendix 1 - Certificate of Compliance-Radiation Exposure    |  |
| <del>Appendix II - Test Report - Seismic Qualification</del> |  |
| Appendix III - Certificate of Compliance - Motor Heat Age    |  |
| Appendix IV - Progress Photographs                           |  |



## 1.0 Purpose of Test

The purpose of this test was to determine the capabilities of a Limitorque Valve Operator (type SMB) equipped with a Porter-Peerless DC electric motor to satisfactorily operate during an environmental condition following unit aging. The Parameters stipulated in the test plan were as required by Bechtel-Philadelphia Electric for Limerick Station and simulates the most severe environment to which the Limitorque operator will be subjected in Boiling Water Reactor Nuclear Power Generating Station during a Post Loca Environment (Loss of Coolant Accident). The operator is considered acceptable on provision it proves capable of satisfactorily operating a valve in both opening and closing directions within a 25 hour period following the start of environmental exposure.

## 2.0 Test Plan

The test was conducted in Limitorque Corporations Environmental Test Facility at King of Prussia, Pa. One Limitorque Valve Operator equipped with a Peerless DC electric motor (radiation Class H insulation) was subjected to test conditions according to the following test plan.





## 2.1 Thermal Aging

2.1.1 Thermally age motor stator to 180°C for 100 hours.

Refer to Appendix III for certificate of compliance.

Regarding the Nuclear Valve Actuator switches and seals, the aging temperature would not exceed 200°F for 200 hours. The switch and seal materials are rated by the manufacturers for use at 300°F and 450°F respectively. Since Limitorque Corporation has successfully used Valve Actuators with these materials at continuous temperatures of 300°F, heat aging these components at lower temperatures was not considered necessary.

## 2.2 Mechanical Aging

2.2.1 Perform 2,000 operating cycles at rated load (20,000# thrust).

2.2.2 After completion of cycling, disassemble the test unit motor, permanently mark motor by commutation for rotational identification and take photographs of the brushes and commutator.

## 2.3 Radiation Exposure

2.3.1 Irradiate the test unit with motor to  $1.0 \times 10^7$  Rads (gamma radiation).

2.3.2 After irradiation disassemble motor and take photographs as in 2.2.2.



## 2.4 Seismic Aging

- 2.4.1 Install three (3) accelerometers on the Limitorque Valve Control housing arranged to measure accelerations in each of these axes (one vertical and two horizontal).
- 2.4.2 Mount the Limitorque Valve Control with fixture to the shaker table with the axis of the stem nut mounted vertically.
- 2.4.3 Connect the limit switches and torque switches into the control. Connect a contact of the limit switch in series with the torque switch to detect switch chatter. Connect spare switch contacts to lights for further indication of chatter.
- 2.4.4 Scan in each of the 3 axes at a minimum of .1g from 5HZ to 33HZ, dwelling for 6 seconds at each frequency. Repeat scan from 33HZ to 5 HZ, dwelling at each integer frequency. Record the accelerometer readings at each scan dwell point of each of three axes - V (vertical)  $H_1$  (horizontal parallel to motor axis) and  $H_2$  (horizontal perpendicular to motor axis) for determination of cross coupling. Note resonance frequency in axis being scanned. (Resonance is defined as a minimum acceleration multiplication factor of 2).
- 2.4.5 Prepare to conduct dwell test in vertical axis V at resonant frequency determined in step 4 (Dwell at 33HZ, if resonant frequencies not evident)



A. On basis of 3.0g on V axis and 3.0g on both H<sub>1</sub> and H<sub>2</sub> axes, determine dwell g-level as follows:

- 1) At dwell frequency, note cross coupling on V axis determined during scan on H<sub>1</sub> and H<sub>2</sub> axes.
- 2) If any cross coupling noted, calculate acceleration adder to V axis.

a) H<sub>1</sub> axis

$$\text{Adder} = \frac{3.0g \times \text{cross couple g level at scan}}{\text{g-level of scan at dwell frequency}}$$

b) H<sub>2</sub> axis

$$\text{Adder} = \frac{3.0g \times \text{cross couple g level at scan}}{\text{g-level of scan at dwell frequency}}$$

c) Add resultant of a) and b) to 3.0g, establishing the G-level for the dwell test.

B. Conduct dwell test for 30 seconds on V axis using g-level determined from A.2.c. During the dwell, operate the unit in an open and close stroke.

(Simulated thrust seat at same torque switch setting established during mechanical aging). Note results.

2.4.6 Prepare to conduct dwell test in horizontal axis H<sub>1</sub> at resonant frequency determined in step 2.4. (Dwell at 33HZ if resonant frequencies not evident).

A. On basis of 3.0g on H<sub>1</sub> axis and 3.0g on both H<sub>2</sub> and V axes, determine dwell g level as indicated in 2.3.5A except substitute V axis for H<sub>1</sub> axis.



B. Conduct dwell test as indicated in 2.4.5B.

2.4.7 Prepare to conduct dwell test in horizontal axis  $H_2$  at resonant frequency determined in step 3. (Dwell at 33HZ if resonant frequencies not evident).

A. On basis of 3.0g on  $H_2$  axis and 3.0g on both  $H_1$  and V axes, determine dwell g level as indicated in 2.3.5A, except substitute V axis for  $H_2$  axis.

B. Conduct dwell test as indicated in 2.4.5B

2.4.8 After seismic aging disassemble motor and take photographs as in 2.2.2..

## 2.5 Environmental Test

2.5.1 Install unit in test chamber.

2.5.2 Fill bottom of test chamber with water to assure saturation of the atmosphere in the chamber.

2.5.3 Heat test chamber to 120°F.

2.5.4 Conduct transient temperature rise (120°F to 340°F.)

2.5.5 Hold 340°F. for 1 hour.

2.5.6 Cool test chamber to 330°F. and hold to 4 hours after start of test.

2.5.7 Cool test chamber to 310°F. and hold to 7 hours after start of test.

2.5.8 Cool at 212°F. and hold to conclusion of test (25 hours).





2.5.9 Megger and cycle operator prior to start of test and the following nominal times after start of test.

1. 5 minutes
2. 1 hour - 5 minutes
3. 1 hour - 50 minutes
4. 3 hours - 50 minutes
5. 6 hours - 50 minutes
6. 24 hours - 50 minutes

2.5.10 Record thrust of test unit during each operating cycle.

2.5.11 Remove unit from test chamber, disassemble and inspect, noting condition of various parts. Take photographs.

### 3.0 Identification of Unit

#### 3.1 Limitorque Operator

|               |          |
|---------------|----------|
| Model         | SMB-O/25 |
| Order Number  | 600426   |
| Serial Number | 189839   |
| Overall Ratio | 108 to 1 |

#### 3.2 Motor Mounted to Limitorque Operator

Manufacturer - H. K. Porter Co., Inc.  
Serial No. - UC-02810  
Full Load Torque - 25' #  
Run Torque - 5' #  
Volts - 125 Volts DC  
Amps. - 14.5  
RPM - 1900  
HP - 1.805  
Duty - 5 min.  
Insulation - Class H  
Winding - Compound  
Commutator Bar - 48  
Ambient - 40°C.  
Temperature Rise - 115°C.

### 4.0 Test Procedure

#### 4.1 Thermal Aging

4.1.1 The motor was heat aged by the motor manufacturer to 180°C for 100 hrs. A copy of the H.K. Porter certificate of compliance is in Appendix III..



#### 4.2 Mechanical Aging

- 4.2.1 The Limitorque Operator with Porter-Peerless DC motor was installed on a test stand to establish a thrust load of 20,000# using the torque switch adjustment to attain the desired load. A thrust load of 19,794# (approx. 453' torque) was measured. (An average of 37 readings).
- 4.2.2 The test unit was then aged for 2,004 operating cycles from September 2 to September 9, 1975. One aging cycle consisted of a 30 second closing stroke going into torque seat (approx. 20,000 lb. thrust per 4.2.1) and a 30 second opening stroke.

#### 4.3 Radiation Exposure

- 4.3.1 The Limitorque Valve Operator with motor received a dose of  $1.0 \times 10^7$  Rads gamma radiation at Isomedix, Inc. Parsippany, N.J. Irradiation was completed on Sept. 22, 1975. A copy of the Isomedix certificate of compliance is in Appendix I.

#### 4.4 Seismic Aging

- 4.4.1 Seismic Aging was conducted at American Electronic Laboratories, Inc. Colmar, Pa. The test unit was qualified according to the procedure listed in Section 2.3.1. A copy of the AEL test report is in Appendix II. The seismic test was completed October 16, 1975.



#### 4.5 Environmental Test

4.5.1 The environmental test was initiated on October 30, 1975 according to the test plan presented in Section 2.5. A chart of the test unit operating characteristics for the environmental test is presented in Fig. 2.

4.5.2 Event 0 9:40 A.M. 10/30/75

The test unit operated satisfactorily in the "close" direction, but in the "open" direction of the stroke, overran the "open" limit. During event 2 when this recurred, it was determined this was caused by a sluggish reversing contactor which was not part of the valve actuator. At the conclusion of event 2, the reversing contactor was disassembled, cleaned and reassembled which resolved the problem.

4.5.3 Event 1 9:58 A.M. (5 minutes after test start)

The test unit operated satisfactorily in both directions.

4.5.4 Event 2 10:57 A.M. - 1.1 hours after test start

Event 3 11:45 A.M. - 1.8 hours after test start

Event 4 1:40 P.M. - 3.9 hours after test start

Event 5 4:40 P.M. - 6.8 hours after test start

Event 6 10:35 A.M. - 24.8 hours after test start

Event 7 10:25 A.M. - 96.7 hours after test start



With the exception of Event 2 where the starter problem (event 0) recurred (refer explanation paragraph 4.5.2), the test unit operated satisfactorily in both directions, with the exception of the red indicator light remaining lit through the entire stroke.

#### 4.5.5 Post-Test Inspection

The condition of the test unit after the Environmental Test was excellent, as is indicated in the photographs in Appendix IV. No mechanical damage or excessive wear was observed in the unit itself, however, a broken gear tooth was noted in the limit switch, which explained the malfunction of the red indicator light. The cause of this failure was indeterminable, however, it did not have any harmful effect on the ability of the unit to operate satisfactorily due to the torque switch back-up normally in the circuit.


#### 5.0 Conclusions

Inasmuch as no detrimental effects due to aging were discernable, the unit is qualified for a 40 year life as described in the aging criteria. Furthermore, the unit operated satisfactorily throughout and after the Environmental LOCA Test, proving its capability of operating during and after the conditions imposed on the unit as previously outlined. Both the environmental test and post-test inspection were witnessed by representatives of Philadelphia Electric, who approved the unit as being acceptable for the service intended.





FIGURE 1  
TEMPERATURE PROFILE - ENVIRONMENTAL TEST





Ref. : IEEE 382-72  
Rev. 1 (3/8/74)  
Para 4.7.1

### CATEGORY V INSULATION RESISTANCE

TEST NO. 389280

Sheet No. 1

Test Eng. \_\_\_\_\_

**TEST UNIT      CLASS H RADIATION INSULATION**

VALVE OPERATOR S/N 189839

D.C. Motor S/N UC02810 (Peerless)

[illegible]



Ref. : IEEE 382-72  
Rev. 1 (3/8/74)  
Para. 4.7.1

## VALVE OPERATOR POWER & MECHANICAL CHARACTERISTICS

Sheet No. 1

TEST NO. 389280

Test Eng. \_\_\_\_\_

TEST UNIT CLASS H INSULATION

VALVE OPERATOR S/N 189839

Motor S/N UC 02810 (Peerless)

[illegible]



Ref. IEEE 382-72  
Rev. 1 (3/8/74)  
Para. 4.7.1

TEST LOG SHEET  
TEST NO. 389280

Sheet No. 1

Test Eng. \_\_\_\_\_

Honeywell/TR-888

| OPERATOR | DATE  | RUN<br>TIME | TIME OF DAY | EVENT NO. | CATEGORY 1 - ENVIRONMENT |                         |            |            |              |                                    |         |         |                 |     |     | CAT. III<br>FLUID<br>CHAR. | REMARKS   |
|----------|-------|-------------|-------------|-----------|--------------------------|-------------------------|------------|------------|--------------|------------------------------------|---------|---------|-----------------|-----|-----|----------------------------|---|
|          |       |             |             |           | TEST CHAMBER<br>AMBIENT  |                         |            |            |              | UNIT SWITCH COMPARTMENT<br>AMBIENT |         |         |                 |     |     | TEMP.                      |   |
|          |       |             |             |           | TEMPERATURE              |                         |            | PRESSURE   |              | TEMPERATURE                        |         |         | PRESSURE        |     |     | CONDENS.                   |   |
|          |       |             |             |           | T.C.<br>#1               | Thermometer<br>top Bulb | side Bulb2 | Gage<br>#1 | Xducer<br>#1 | Thermocouples                      |         |         | Pressure Xducer |     |     | T.C.<br>#5                 |   |
|          |       |             |             |           | °F                       | F                       | °F         | psig       | psig         | 2                                  | 3       | 4       | 2               | 3   | 4   | °F                         |   |
| TDH      | 10-30 | 0           | 9:35        | 0         | 124/119                  | 117                     | 118        | 0          | 0            | 121/120                            | 121/119 | 118/116 | 0               | 0   | 0   | 130                        | T.C.#3-In limit switch compartment.<br>Xducer#3-attached to limit switch compl. |
|          |       | 0           | 9:53        |           | /226                     | 217                     | 225        | 7          | 8            | /228                               | /142    | /222    | 8               | 9   | 8   | 133                        |   |
|          |       |             | 9:55        |           | 237/235                  | 241                     | 239        | 14         | 12           | 235/238                            | 187/184 | 238/236 | 12              | 12  | 12  | 140                        |   |
|          |       |             | 9:58        | 1         | 250/257                  | 248                     | 248        | 18         | 20           | 250/251                            | 223/220 | 252/251 | 19              | 19  | 18  | 147                        | T.C.#3-187°F. Operate unit.   |
|          |       |             | 10:03       |           | 263/269                  | 264                     | 263        | 24         | 30           | 265/272                            | 245/248 | 267/269 | 28              | 28  | 27  | 156                        |   |
|          |       |             | 10:06       |           | 272/279                  | 269                     | 269        | 30         | 33           | 271/281                            | 258/261 | 273/276 | 32              | 32  | 31  | 164                        |   |
|          |       |             | 10:09       |           | 281/283                  | 275                     | 274        | 33         | 37           | 281/287                            | 271/269 | 283/283 | 35              | 35  | 34  | 168                        |   |
|          |       |             | 10:13       |           | 284/288                  | 280                     | 280        | 37         | 42           | 286/292                            | 279/279 | 288/288 | 39              | 39  | 39  |                            |   |
|          |       |             |             |           | /295                     | 286                     | 285        | 41         | 45           | /298                               | /289    | /292    | 43              | 43  | 42  | 181                        | Note: Mullipoint Recorder was not monitor                                       |
|          |       |             |             |           | /302                     | 292                     | 291        | 45         | 51           | /302                               | /295    | /297    | 49              | 48  | 48  |                            | from this point due to time lag (recorder                                       |
|          |       |             |             |           | /305                     | 296                     | 296        | 50         | 56           | /309                               | /301    | /302    | 54              | 53  | 52  | 185                        | prints out every 4 min).  |
|          |       |             | 10:24       |           | /312                     | 302                     | 301        | 55         | 61           | /316                               | /308    | /309    | 59              | 57  | 57  |                            |   |
|          |       |             |             |           | /319                     | 307                     | 306        | 59         | 67           | /323                               | /312    | /316    | 65              | 63  | 63  | 196                        |   |
|          |       |             |             |           | /320                     | 311                     | 311        | 64         | 72           | /324                               | /315    | /319    | 69              | 67  | 67  |                            |   |
|          |       |             |             |           | /325                     | 314                     | 314        | 68         | 77           | /327                               | /320    | /320    | 73              | 72  | 72  | 201                        |   |
|          |       |             |             |           | /327                     | 318                     | 319        | 72         | 81           | /331                               | /324    | /324    | 78              | 75  | 75  |                            |   |
|          |       |             |             |           | /334                     | 324                     | 324        | 79         | 90           | /336                               | /331    | /331    | 86              | 82  | 81  | 214                        |   |
|          |       |             |             |           | /340                     | 329                     | 330        | 87         | 99           | /342                               | /337    | /337    | 95              | 91  | 92  |                            |   |
|          |       |             |             |           | /346                     | 333                     | 336        | 96         | 108          | /348                               | /343    | /343    | 105             | 101 | 102 | 220                        |   |
|          |       |             | 10:50       | 2         | /352                     | 342                     | 342        | 105        | 120          | /355                               | /349    | /349    | 117             | 111 | 114 |                            | Operate unit @ 10:57.   |
|          |       |             | 11:30       |           | 341/358                  | 343                     | 344        | 104        | 112          | 342/360                            | 341/355 | 343/357 | 129             | 123 | 126 | 254                        | Start cooling to 330°F @ 11:50.   |





Ref. IEEE 382-72  
Rev. 1 (3/8/74)  
Para. 4.7.1

## TEST LOG SHEET

TEST NO. 389280

Sheet No. 2

Test Eng. \_\_\_\_\_

Honeywell/TR-888

| OPERATOR | DATE  | RUN<br>TIME | TIME OF DAY | EVENT NO. | CATEGORY 1 - ENVIRONMENT |                         |           |            |              |                                    |         |         |                 |      |       | CAT. III<br>FLUID<br>CHAR. | REMARKS                           |
|----------|-------|-------------|-------------|-----------|--------------------------|-------------------------|-----------|------------|--------------|------------------------------------|---------|---------|-----------------|------|-------|----------------------------|-----------------------------------|
|          |       |             |             |           | TEST CHAMBER<br>AMBIENT  |                         |           |            |              | UNIT SWITCH COMPARTMENT<br>AMBIENT |         |         |                 |      | TEMP. |                            |                                   |
|          |       |             |             |           | TEMPERATURE              |                         |           | PRESSURE   |              | TEMPERATURE                        |         |         | PRESSURE        |      |       | CONDENS.                   |                                   |
|          |       |             |             |           | T.C.<br>#1               | Thermometer<br>Top Bulb | Side Bulb | Gage<br>#1 | Xducer<br>#1 | Thermocouples                      |         |         | Pressure Xducer |      |       | T.C.<br>#5                 |                                   |
|          |       |             |             |           | °F                       | F                       | °F        | psig       | psig         | °F                                 | °F      | °F      | psig            | psig | psig  | °F                         |                                   |
| TDH      | 10:30 |             | 11:48       | 3         | 341/357                  | 345                     | 343       | 105        | 119          | 342/361                            | 342/351 | 343/357 | 116             | 109  | 111   | 258                        |                                   |
| "        | "     |             | 12:00       | 4         | 331/344                  | 333                     | 332       | 86         | 109          | 332/346                            | 331/346 | 336/345 | 94              | 92   | 93    | 259                        |                                   |
| "        | "     |             | 12:30       | 5         | 330/342                  | 332                     | 332       | 86         | 99           | 331/346                            | 332/342 | 332/342 | 94              | 90   | 92    | 259                        |                                   |
| "        | "     |             | 1:30        | 6         | 331/342                  | 332                     | 332       | 86         | 99           | 331/346                            | 332/342 | 333/342 | 96              | 91   | 93    | 262                        | Start cooling to 310°F @ 2:02PM.  |
| "        | "     |             | 2:25        | 7         | 311/324                  | 312                     | 312       | 64         | 72           | 313/327                            | 316/327 | 314/323 | 68              | 64   | 64    | 258                        |                                   |
| "        | "     |             | 3:25        | 8         | 311/324                  | 314                     | 312       | 63         | 70           | 312/327                            | 314/324 | 314/324 | 68              | 66   | 66    | 255                        |                                   |
| "        | "     |             | 4:25        | 9         | 312/322                  | 313                     | 313       | 63         | 70           | 313/327                            | 313/324 | 314/324 | 68              | 66   | 66    | 255                        | Start cooling to 212°F @ 4:50PM   |
| "        | "     |             | 5:20        | 10        | 198/203                  | 210                     | 180       | 0          | 0            | 213/224                            | 255/262 | 211/217 | 0               | 0    | 0     | 185                        | turned off cooling coils @ 5:40PM |
| "        | "     |             | 5:50        | 11        | 174/187                  | 195                     | 170       | 0          | 0            | 196/203                            | 242/246 | 199/201 | 0               | 0    | 0     | 125                        | Star heaters controlling.         |
|          |       |             | 6:50        | 12        | 205/205                  | 186                     | 184       | 0          | 0            | 198/203                            | 224/225 | 199/197 | 0               | 0    | 0     | 170                        |                                   |
|          |       |             | 7:50        | 13        | 205/205                  | 186                     | 192       | 0          | 0            | 199/203                            | 203/203 | 197/196 | 0               | 0    | 0     | 195                        |                                   |
|          |       |             | 8:50        | 14        | 206/207                  | 189                     | 197       | 0          | 0            | 199/203                            | 199/200 | 198/198 | 0               | 0    | 0     | 200                        |                                   |
|          |       |             | 9:50        | 15        | 207/210                  | 190                     | 198       | 0          | 0            | 200/204                            | 195/197 | 199/200 | 0               | 0    | 0     | 201                        |                                   |
|          |       |             | 10:50       | 16        | 209/210                  | 193                     | 200       | 0          | 0            | 202/207                            | 198/200 | 202/203 | 0               | 0    | 0     | 205                        |                                   |
|          |       |             | 11:50       | 17        | 210/210                  | 194                     | 200       | 0          | 0            | 203/208                            | 198/200 | 203/204 | 0               | 0    | 0     | 207                        |                                   |
|          |       |             | 12:50       | 18        | 212/213                  | 196                     | 202       | 0          | 0            | 205/210                            | 200/203 | 205/206 | 0               | 0    | 0     | 208                        |                                   |
|          |       |             | 1:50        | 19        | 212/215                  | 197                     | 204       | 0          | 0            | 206/212                            | 201/204 | 206/206 | 0               | 0    | 0     | 210                        |                                   |
|          |       |             | 2:50        | 20        | 212/215                  | 198                     | 205       | 0          | 0            | 206/212                            | 202/206 | 208/208 | 0               | 0    | 0     | 210                        |                                   |
|          |       |             | 3:50        | 21        | 212/215                  | 198                     | 205       | 0          | 0            | 207/212                            | 202/206 | 207/208 | 0               | 0    | 0     | 210                        |                                   |
|          |       |             | 4:50        | 22        | 214/216                  | 199                     | 206       | 0          | 0            | 208/214                            | 203/207 | 208/209 | 0               | 0    | 0     | 210                        |                                   |
|          |       |             | 5:50        | 23        | 213/216                  | 200                     | 206       | 0          | 0            | 208/214                            | 203/207 | 208/210 | 0               | 0    | 0     | 210                        |                                   |
|          |       |             | 6:50        | 24        | 215/217                  | 200                     | 207       | 0          | 0            | 210/214                            | 205/208 | 209/210 | 0               | 0    | 0     | 212                        |                                   |



Ref. IEEE 382-72  
Rev. 1 (3/8/74)  
Para. 4.7.1

# TEST LOG SHEET

TEST NO. 389280

Sheet No. 3

Test Eng. \_\_\_\_\_

**Honeywell/TR-888**

[illegible]



Appendix I

Certificate of Compliance - Radiation Exposure



ISOMEDIX

September 23, 1975

Mr. W. L. Sykes  
Test Engineer  
Philadelphia Gear Corporation  
King of Prussia, Pa. 19406

Dear Mr. Sykes:

This will summarize the perimeters pertinent to the irradiation of one valve operator and motor assembly, one motor, and one set of brushes. Identification on the valve operator and motor assembly was:

SMB O Limitorque Operator  
S/N 189839  
Peerless DC Motor  
S/N WC02810


The single motor was a Peerless D.C. motor, S/N BW 86029. The set of brushes was unmarked.

Units were placed in a cobalt-60 field of  $0.2 \times 10^6$  rad per hour, at an air equivalent dose. They were rotated several times during the exposure to achieve a more uniform dose distribution. Total minimum dose received to the centerline of the operator and motors was 10.0 Mrad (air equivalent) with an overdose factor on the edges of the units of 1.2. The spare set of brushes received a real dose of 5.0 Mrad. Irradiation was in air at ambient temperature and a slight negative pressure. The temperature of the samples during irradiation did not exceed 90°F.

Dosimetry was performed using a Victoreen Model 555 Integrating Dose Rate Meter and Probe. The unit was calibrated on January 15, 1974 by the Victoreen Instrument Company, using Cobalt-60 and Cesium-137 sources whose calibrations are traceable to the U.S. National Bureau of Standards. A copy of the calibration certificate is available. Confirming dosimetry utilizing a Red Perspex system was also completed.

Irradiation was completed September 22, 1975, and the units returned to you under separate cover.

Very truly yours,

  
George R. Dietz  
Manager, Radiation Services

RD:km

Isomedix Inc. • 25 Eastmans Road, Parsippany, New Jersey Telephone (201) 887-4700  
Mailing Address: Post Office Box 177, Parsippany, New Jersey 07054

Isomedix Limited • Bennett Street, Mont. St. Hilaire, Quebec, Canada Telephone (514) 467-1211  
Mailing Address: Post Office Box 7, Beloeil, Quebec, Canada





Appendix II  
Test Report - Seismic Qualification



TEST REPORT NO. 75-149 ETNO. OF PAGES 19REPORT OF TEST  
ON

VALVE OPERATOR

FOR

LIMITORQUE CORPORATION

**AMERICAN ELECTRONIC LABORATORIES, INC.**  
ENVIRONMENTAL TESTING LABORATORY

Purchase Order 389280

Control No. 75-127-6100

|      | PERFORMED BY                      | REPORT BY                   | APPROVED BY                 |  |
|------|-----------------------------------|-----------------------------|-----------------------------|--|
| Name | <i>T. Mitchell</i><br>T. Mitchell | <i>R.W. Hay</i><br>R.W. Hay | <i>R.W. Hay</i><br>R.W. Hay |  |
| Date | 10/29/75                          | 10/29/75                    | 10/29/75                    |  |



ADMINISTRATIVE DATA

TYPE OF TEST: Seismic Vibration

MANUFACTURER: Limitorque Corporation  
5114 Woodall Road  
Lynchburg, VA 24502

UNIT OF TEST: Valve Operator

TYPE OR MODEL NO: SMB-O S/N 189839

DRAWING, SPECIFICATION OR EXHIBIT: Limitorque O/N 389280

QUANTITY OF ITEMS TESTED: One Valve Operator with Motor (S/N UC 02810)  
One Extra Motor (I.D.#BW86029)

SECURITY CLASSIFICATION OF ITEMS: Unclassified

DATE TESTS COMPLETED: October 16, 1975

TESTS CONDUCTED BY: American Electronic Laboratories, Inc.  
Environmental Testing Laboratory  
Richardson Road  
Colmar, Pennsylvania

DISPOSITION OF ITEMS: Returned to the Manufacturer.

REPORT NO. 75-149 ET

PAGE 1



AMERICAN ELECTRONIC LABORATORIES, INC.



1.0 INTRODUCTION

The SMB Type valve control shown in Figure 1 was submitted by Limitorque Corporation for Seismic Vibration Testing in accordance with Test Procedure O/N 389280, a copy of which is attached.

The testing was performed by the Environmental Testing Laboratory personnel of American Electronic Laboratories, Inc., Richardson Road, Colmar, Pa.







## 2.0 TEST PROCEDURE

The test procedure followed is included in Section 2.0. The basic test setup is shown in Figure 1 (horizontal) and Figure 2 (vertical). In all cases it was necessary to support the dead weight of the test item and fixture as evidenced by the ropes shown in Figure 2.

Accelerometers were located as noted in Figure 3 for cross axis and resonance determinations. Data was recorded on oscillograph traces.






### 3.0 DISCUSSION OF RESULTS

The test log is included in Section 6.0 of this report. The oscillograph recordings were not reproducible, but the originals remain on file with AEL in the Environmental Testing Laboratory. The resonance search data was taken from the oscillograph recordings and is included in the data section.

As noted in the test log, there were no resonances in any of the three axes. Crosstalk from 0.3g input in the vertical axis was  $H_1 = .04g$  and  $H_2 = .06g$  as taken from the oscillograph trace.

With the input in either horizontal direction, crosstalk in the vertical axis was extremely high. Because this was not expected, an analysis of the test set up was made. When driving in the horizontal directions, a slip plate was used. The entire assembly was mounted onto the slip plate which in turn is attached to the shaker head with a single line of five 3/8 inch bolts. The driving force through the slip plate is five inches from the system center of gravity. This creates a couple having a resultant vertical force. Because of the flexibility of the attach point at the shaker head and the fluidity of the oil film on which the slip plate is floating, the entire test setup acts as a spring mass system, giving about the bolt line with the driving force applied from the couple. The apparent





### 3.0 DISCUSSION OF RESULTS (continued)

resonance of this spring mass system is near 33 Hz which would account for the vertical component when driving horizontally. Since the basic exciter crosstalk is less than 10 percent of the driven force and the crosstalk from vertical excitation was about 20 percent, a value of 4g's was set by Limitorque as the input force for the seismic dwells.

As a result of damage to the slip plate during the first horizontal dwell, it was necessary to make a modification of fixturing for the other horizontal direction. A bracket was made to attach the operator baseplate to the shaker head as noted in Figure 4. The effect of this setup is identical to that used with a slip plate. This setup was then used to complete the second horizontal axis.


The unit was operated from open to close, electrically, during each dwell by the Limitorque representative. There were no operational problems reported by Limitorque at any time throughout the test.





4.0 ILLUSTRATIONS

FIGURE 1




Valve Operator Set-Up in Horizontal (H1) Plane  
Using Slip Plate







FIGURE 2



Valve Operator Set-Up in Vertical (V) Plane

Report No. 75-149 ET


Page 6 of 19 Pages



AMERICAN ELECTRONIC LABORATORIES, INC.




FIGURE 3



ACCELEROMETER LOCATIONS

Report No. 75-149 ET


Page 7 of 19 Pages



AMERICAN ELECTRONIC LABORATORIES, INC.




FIGURE 4



Valve Operator Set-Up in Horizontal (H1) Plane  
Supported from Crane

Report No. 75-149 ET

Page 8 of 19 Pages



AMERICAN ELECTRONIC LABORATORIES, INC.



# 5.0 APPARATUS LIST

| <u>EQUIPMENT</u>  | <u>MANUFACTURER</u> | <u>MODEL NO.</u> | <u>AEL NO.</u> | <u>CALIBRATION</u> |                 |
|-------------------|---------------------|------------------|----------------|--------------------|-----------------|
|                   |                     |                  |                | <u>DATE</u>        | <u>INTERVAL</u> |
| Accoelerometer    | Endevco             | 2215E            | 3214           | 27 June 75         | 6 mo.           |
| Dial-A-Gain       | Unholtz-Dickie      | 606              | 7685           | 20 July 75         | 3 mo.           |
| Band Pass Filter  | Krohn-Hite          | 330N             | 6209           | 21 Aug 75          | 6 mo.           |
| Vibration System  | M.B. Electronics    | C150             | 8986           | EACH USE           |                 |
| Accelerometer     | Endevco             | 2215E            | 7710           | 27 June 75         | 6 mo.           |
| Accelerometer     | Endevco             | 2215E            | 8685           | 27 June 75         | 6 mo.           |
| Charge Amplifier  | Unholtz-Dickie      | 11MS             | 8723           | 18 Aug 75          | 6 mo.           |
| Vibration Meter   | Unholtz-Dickie      | 1610             | 8436           | 6 Aug 75           | 3 mo.           |
| Servo Monitor     | M.B. Electronics    | N753             | 8751           | EACH USE           |                 |
| Sweep Oscillator  | M.B. Electronics    | N752-5           | 8654           | EACH USE           |                 |
| Counter Timer     | Monsanto            | 101A             | 6186           | 18 Aug 75          | 6 mo.           |
| Accelerometer     | Endevco             | 2215E            | 8684           | 27 June 75         | 6 mo.           |
| Accelerometer     | Endevco             | 2215E            | 7929           | 21 Apr 75          | 6 mo            |
| Accelerometer     | Endevco             | 2215E            | 8078           | 20 Apr 75          | 6 mo.           |
| Accelerometer     | Endevco             | 2215E            | 8324           | 27 June 75         | 6 mo.           |
| Vibration Meter   | M.B. Electronics    | M3               | 1518           | 1. July 75         | 6 mo.           |
| Strobac           | General Radio       | 1531-A           | 8190           | 2 July 75          | 6 mo.           |
| Charge Amplifier  | Unholtz-Dickie      | D11              | 8723-A         | 18 Aug 75          | 6 mo.           |
| Vibration Pick-Up | M.B. Electronics    | 115              | 0719           | EACH USE           |                 |

REPORT NO. 75-149 ET

PAGE 9 OF 19 PAGES



A M E R I C A N E L E C T R O N I C L A B O R A T O R I E S . I N C.






# 5.0 APPARATUS LIST (Continued)

| <u>EQUIPMENT</u>   | <u>MANUFACTURER</u> | <u>MODEL NO.</u> | <u>AEL NO.</u> | <u>CALIBRATION</u> |                 |
|--------------------|---------------------|------------------|----------------|--------------------|-----------------|
|                    |                     |                  |                | <u>DATE</u>        | <u>INTERVAL</u> |
| Charge Amplifier   | Unholtz-Dickie      | D11              | 8723-B         | 18 Aug 75          | 6 mo.           |
| Charge Amplifier   | Unholtz-Dickie      | D11              | 8723-C         | 18 Aug 75          | 6 mo.           |
| Charge Amplifier   | Unholtz-Dickie      | D11              | 8723-D         | 18 Aug 75          | 6 mo.           |
| AC Voltmeter       | Hewlett-Packard     | 400E             | 7028           | 28 Apr 75          | 6 mo.           |
| Datagraph Recorder | CEC                 | 5-126            | 9145           | EACH USE           |                 |
| Timer              | Gra-Lab             | 171              | 7360           | EACH USE           |                 |
| DVM                | Fluke               | 8000A            | 9254           | 29 May 75          | 6 mo.           |

The above equipment has been calibrated by standards which are regularly calibrated and whose accuracies are traceable to the NATIONAL BUREAU OF STANDARDS.






6.0 DATA

REPORT NO. 75-149 ET

PAGE 11 OF 19 PAGES



AMERICAN ELECTRONIC LABORATORIES, INC.



10/2/75      Limitorque Corporation      -      17525- 6100

Vibration: Sine (Res. Search & Dwell)

1 - Valve Assembly & Extra Motor mounted to customer supplied  
fixture and vibrated IAW customer supplied Spec. TP O/N 389280.  
Set up for Res Search in Vertical Axis.

1000 Start Res Scan 5-33 Hz. recording on data graph  
3 accels (V, H1, H2) and control input .1g

1010 Complete scan tape 1  
Resonances are noted on cross axes. The  
amplitude of H1, H2 are relative and are not absolute.

1045 Recalibrated for absolute trace outputs. Rerun vert.

1110 Start scan 5-33-5 Hz. 6 sec/cycle  
Tape 2 .3g Input

1120 End scan. No resonances observed.  
Change to Horizontal

1510 Start scan of H1 axis 5-33-5 Hz.

1520 End scan Tape 3 No Resonances  
.3g input.

10/3      1010 Start scan H2 axis 5-33-5 Hz

1020 End scan Tape 4 No Resonances .3g Input

Check of cross talk readings shows that valves are higher  
than expected. Phonecon with Walt Sykes determined that  
vibration level will be 4 g peak for dwells. 1g base line  
data; checked with DVM will be used to verify existing tapes.



Sine Vibration

0900    H2 Axis vibrated at 1g in to Rv. tape of acels on valve

0905    H2 axis verified tape readings with DVM. All readings  
within .1g.

0910    Dwell at 2 g for 30 secs. On and 1 min. off 5 vibrations.  
1st 2g dwell ok readings taken.

2nd dwell - shut down at 1g in due to noise from fixture.

Removed valve and tightened bolts on aluminum plate.

1010    2nd 2g dwell; Readings OK

3rd 2 g dwell; Readings OK

4th 2g dwell; Readings OK

5th 2g dwell; Readings OK

1020    1 dwell at 33 hz. 4 g's Pk for 30 seconds; shut down  
after 15 secs due to lost accel.

1035    Completed 4 g dwell. Valve oper. OK. Removed aluminum  
plate and noticed inserts on slip table loose.

1505    Set up in vertical axis.

Calibrated all accels at 1g.

1510    Start 33 Hz. scan. Base Line Data.

|  | 1st dwell | 33 Hz. | 2g In. | Readings OK |
|--|-----------|--------|--------|-------------|
|--|-----------|--------|--------|-------------|

|     |   |   |     |     |
|-----|---|---|-----|-----|
| 2nd | " | " | " " | " " |
|-----|---|---|-----|-----|

|     |   |   |     |     |
|-----|---|---|-----|-----|
| 3rd | " | " | " " | " " |
|-----|---|---|-----|-----|

|     |   |   |     |     |
|-----|---|---|-----|-----|
| 4th | " | " | " " | " " |
|-----|---|---|-----|-----|

|     |   |   |     |     |
|-----|---|---|-----|-----|
| 5th | " | " | " " | " " |
|-----|---|---|-----|-----|

1525    30 second dwell at 4g PK. Readings OK

Discontinued testing for now. Slip table to be repaired, or  
replaced.





10/15/75      Limitorque Corp.      -      17525- 6100

Sine Vibration: Continued from Page 41-66

Accelerometers: H1, H2, Vert, Motor & Control.

All Calibrated at .4g In. 20 Hz Readouts as follows:

H2 & Vert Direct .4g = .4 VRHS

Control & Motor Directly on Meters.

H1 = .4g = .1M (volts X 4 = g)

1g Base Line Data H1 = .3V = 1.2g H2 = .11V = .11g

Vertical .27V = .27g

1110 1st dwell at 33 Hz. 30 secs. 2 g In.

Data Recorded by Limitorque Personnel

1111 2nd dwell 33 Hz. 30 secs. 2g In.

1113 3rd " " " "

1115 4th " " " "


1117 5th " " " "

All Data Recorded by LC

1120 Dwell at 33 Hz. 30 secs. 4 g In.

Crosstalk Readings taken by Limitorque Corporation  
Personnel

TEST COMPLETED



## Vibration: Tape Data Recordings

| Tape 2     |      | Vertical |            | Cal. Data |            | 30 Hz.    |
|------------|------|----------|------------|-----------|------------|-----------|
| Trace 1    | H2   | H2       | 2 V        | 3 H1      | H1         | 4 control |
| .5g = .46" |      |          | .5g = .42" |           | .5g = .44" | 5g = .50" |
| 5 Hz.      | .04" |          | .24"       |           | .03"       | .33"      |
| 10 Hz.     | .04  |          | .26        |           | .03        | .34       |
| 14 Hz.     | .07  |          | .23        |           | .03        | .32       |
| 15 Hz.     | .12  |          | .26        |           | .04        | .32       |
| 16 Hz.     | .12  |          | .24        |           | .04        | .32       |
| 17 Hz.     | .09  |          | .28        |           | .04        | .34       |
| 20 Hz.     | .06  |          | .28        |           | .06        | .33       |
| 23 Hz.     | .08  |          | .30        |           | .07        | .34       |
| 24 Hz.     | .09  |          | .30        |           | .08        | .33       |
| 25 Hz.     | .10  |          | .30        |           | .06        | .33       |
| 27 Hz.     | .06  |          | .26        |           | .04        | .33       |
| 30 Hz.     | .05  |          | .26        |           | .04        | .35       |
| 33 Hz.     | .06  |          | .30        |           | .04        | .33       |

| Tape 3 H1 Axis |      | Same cal. as above. |      | 30 Hz. |
|----------------|------|---------------------|------|--------|
| 5 Hz.          | .04" | .04"                | .35" | .34"   |
| 10 Hz.         | .04  | .05                 | .33  | .33    |
| 15 Hz.         | .04  | .04                 | .35  | .34    |
| 20 Hz.         | .04  | .04                 | .33  | .30    |
| 22 Hz.         | .04  | .05                 | .40  | .32    |
| 24 Hz.         | .04  | .04                 | .44  | .34    |
| 25 Hz.         | .04  | .04                 | .45  | .33    |
| 27 Hz.         | .06  | .11                 | .53  | .33    |
| 28 Hz.         | .04  | .10                 | .48  | .36    |
| 29 Hz.         | .06  | .14                 | .44  | .34    |
| 30 Hz.         | .05  | .08                 | .37  | .35    |
| 33 Hz.         | .03  | .07                 | .36  | .38    |


| 10/3/75 | Tape 4 H2 Axis |       | Same Cal. as above. |             |
|---------|----------------|-------|---------------------|-------------|
|         | Trace 1 (H2)   | 2 (V) | 3 (H1)              | 4 (Control) |
| 5 Hz.   | .38"           | .04"  | .04"                | .32"        |
| 10 Hz.  | .38            | .05   | .06                 | .32         |
| 15 Hz.  | .40            | .06   | .06                 | .32         |
| 20 Hz.  | .40            | .08   | .08                 | .33         |
| 22 Hz.  | .44            | .08   | .05                 | .33         |
| 24 Hz.  | .44            | .12   | .07                 | .33         |
| 25 Hz.  | .52            | .12   | .08                 | .33         |
| 26 Hz.  | .51            | .16   | .08                 | .33         |
| 27 Hz.  | .48            | .16   | .10                 | .32         |
| 28 Hz.  | .46            | .10   | .10                 | .32         |
| 29 Hz.  | .44            | .08   | .12                 | .34         |
| 30 Hz.  | .42            | .08   | .12                 | .36         |
| 33 Hz.  | .40            | .05   | .04                 | .38         |



7.0 TEST PROCEDURE

REPORT NO. 75-149 ET

PAGE 17 OF 19 PAGES



A M E R I C A N E L E C T R O N I C L A B O R A T O R I E S  . I N C .



Test Procedure (O/N 389280)

Seismic Testing - Nuclear Power Generating Stations

Limiter Valve Control - D.C. Operators

1. Install (3) accelerometers on the Limitorque Valve Control housing arranged to measure accelerations in each of these axis (one vertical and two horizontal).
2. Mount the Limitorque Valve Control with fixture to the shaker table with the axis of the stem nut mounted vertically.
3. Connect limit switches and torque switches into the control. Connect a contact of the limit switch in series with the torque switch to detect switch chatter. Connect spare switch contacts to lights for further indication of chatter.
4. Scan in each of the 3 axis at a min. .1 g from 5 Hz., to 33 Hz., dwelling for 6 seconds at each frequency. Repeat scan from 33 Hz. to 5 Hz. dwelling at each integer frequency. Record the accelerometer readings at each scan dwell point of each of three axis - - V (Vertical), H1 (horizontal parallel to moto/ axis) and H2 (horizontal perpendicular to motor axis) for determination of cross coupling.

Note resonance frequency in axis being scanned, (Resonance is defined as a minimum acceleration multiplication factor of 2)

5. Prepare to conduct dwell test in vertical axis V at resonant frequency determined in step 4. (Dwell at 33 Hz., if resonant frequencies not evident)
  - A. On basis of 3.0 g on V axis and 3.0 g on both H1 and H2 axis, determine dwell-g level as follows:
    - 1) At dwell frequency, note cross coupling on V axis determined during scan on H1 and H2 axis.
    - 2) If any cross coupling noted, calculate acceleration adder to V axis.
      - a) H1 axis
$$\text{Adder} = \frac{3.0g \times \text{cross couple g level at scan}}{\text{g level of scan at dwell frequency.}}$$





b) H2 axis

Adder -  $\frac{3.0 \times \text{crosscouple } g \text{ level at scan}}{g \text{ level of scan at dwell frequency}}$

c) Add sum of a) and b) to 3.0 g establishing the g level for the dwell test.

B. Conduct five dwell test for 30 seconds each on V axis, using one half g level determined from A.2.c) and one dwell test for 30 seconds using g level determined from A.2.c) above. During each dwell, operate the unit in a close and open stroke. Note results.

6. Prepare to conduct dwell test in horizontal axis H1 at resonant frequency determined in step 4. (dwell at 33 Hz if resonant frequency not evident).

A. On basis 3.0 g on H1 axis and 3.0 g on both H2 and V axis, determine dwelling level as indicated in 5A except substitute V axis for H1 axis.

B. Conduct dwell tests in H1 axis as indicated in 5B above.

7. Prepare to conduct dwell test in horizontal axis H2 at resonant frequency determined in step 3. (Dwell at 33 Hz. if resonant frequencies not evident).

A. On basis of 3.0 g on H2 axis and 3.0 g on both H1 and V axis, determine dwelling level as indicated in 5A except substitute V axis for H2 axis.

B. Conduct dwell tests in H2 axis as indicated in 5B above.

8. At completion of seismic test, run unit for one full close and open stroke.



SEISMIC AGING COMMENTS

Subsequent testing of a similar SMB-0-25 Valve Actuator with a D.C. Motor (AERO NAV Report 5772) conducted on a different type vibration machine disclosed negligible cross coupling existed in this Actuator.

The above confirms the analysis made in American Electronic Laboratories Report 75-149ET indicating the cross coupling that was measured was created by their vibration machine rather than the Valve Actuator.

The seismic aging levels used are therefore considered to meet the requirements of the specified levels.



Appendix III

Certificate of Compliance - Heat Aging of Motor






H. K. PORTER COMPANY, INC.  
ELECTRICAL DIVISION

1401 WEST MARKET STREET • WARREN, OHIO 44485

TELEX NO. 98-2440  
"PEERLESS-WAR"

WARREN WORKS  
AREA CODE 216  
TEL. 399-3651

December 29, 1975



Mr. Al Richards  
Limitorque Corporation  
181 S. Gulph Road  
King of Prussia, PA 19406

Subject: P.O. # 600467-A, Our B-29376  
Motor Model 176-18-0026-0  
Motor Serial Numbers: XC-02809 and UC-02810

Al:

The two radiation test motors supplied against subject purchase order were aged at 180°C for a minimum of 100 hours to obtain an accelerated 40 year life. The motors were tested before and after aging and passed all tests satisfactorily.

The motors were manufactured to Class I radiation requirements for nuclear containment chamber service with material, construction, and insulation system specifications as shown on model 176-18-0026-0. Future motors supplied for Class I service will be of the same construction and materials even though electrical ratings may differ.

If further information is required, please advise.

Sincerely,

Dennis A. Weaver  
Sales Engineer

lm


cc: R. Lambert  
B-29367






Appendix IV  
Progress Photographs






1 - Motor commutator area after 2,000 aging cycles.




2 - Motor brushes after 2,000 aging cycles.







3 - Motor and brushes after 10 MRad radiation exposure.



4 - Motor and brushes after seismic qualification.






5 - Side view of test unit after environmental profile.




6 - Test unit limit switch compartment after environmental profile.








7 - Close-up of limit switch after environmental profile.




8 - Close-up of torque switch after environmental profile.



9 - Motor commutator area after environmental profile.





10 - Test unit after post-test disassembly.



APPENDIX F

Seismic Qualification Envelope

Report 80037



SEISMIC QUALIFICATION ENVELOPE

LIMITORQUE VALVE ACTUATORS

REPORT B0037

TESTS PER IEEE 344-75

PREPARED BY LIMITORQUE CORPORATION

PREPARED BY: J. B. Drab  
J. B. Drab - Special Projects Eng.

DATE: 1-11-'80

APPROVED: W. J. Denkowski  
W. J. Denkowski - Vice President,  
Engineering

ACCEPTED: C. D. Formica  
C. D. Formica - Q.A. Administrator





## TABLE OF CONTENTS

|         |   |               |
|---------|---|---------------|
| 1.0     | INTRODUCTION. . . . .                             | Page 1        |
| 2.0     | DISCUSSION. . . . .                               | Page 1        |
| 2.0.1   | Generic Family. . . . .                           | Page 1 to 2   |
| 2.0.2   | Seismic Qualification Envelope. . . . .           | Page 2        |
| 2.0.3   | Loading Simulation. . . . .                       | Page 2 to 3   |
| 2.0.4   | Weight Distribution . . . . .                     | Page 3        |
| 2.0.5   | Discussion-Test Method. . . . .                   | Page 3 to 4   |
| 2.0.6   | Discussion-Resonance. . . . .                     | Page 4        |
| 2.0.7   | Discussion-Cross Coupling . . . . .               | Page 4 to 5   |
| 2.0.8   | Actuator Test Criteria                            |               |
| 2.0.8.1 | Description-Seismic Fixturing . . . . .           | Page 5 to 6   |
| 2.0.8.2 | Switch Calibration. . . . .                       | Page 6        |
| 2.0.8.3 | Stroke Time . . . . .                             | Page 6        |
| 2.0.9   | Acceptance Criteria . . . . .                     | Page 7        |
| 2.0.10  | Switch Chatter Analysis. . . . .                  | Page 7        |
| 2.0.11  | Motor Insulation Class . . . . .                  | Page 8        |
| 2.0.12  | Seismic Qualification Definition . . . . .        | Page 8        |
| 3.0     | IDENTIFICATION OF TESTED VALVE ACTUATORS. . . . . | Page 9        |
| 4.0     | TYPE TEST PROCEDURE . . . . .                     | Page 9        |
| 4.1     | Standard Seismic Test Procedure . . . . .         | Page 9 to 12  |
| 4.2     | Fragility Test Procedure. . . . .                 | Page 13 to 15 |
| 5.0     | CONCLUSION  |               |
| 5.0.1   | Linear Actuators . . . . .                        | Page 15       |
| 5.0.2   | Rotary Actuators . . . . .                        | Page 16       |



APPENDIX

| <u>REPORT NO.</u>         | <u>UNIT SIZE</u>         | <u>TEST DATE</u>     |
|---------------------------|--------------------------|----------------------|
| <u>SMB-AC Units</u>       |                          |                      |
| Aero Nav Report 5771      | SMB-000-5                | 4/30/75 Appendix 1   |
| Aero Nav Report 5773      | SMB-3-100                | 7/22/75 Appendix 2   |
| Aero Nav Report 6-6246-1  | SMC-04                   | 3/18/76 Appendix 3   |
| <u>SB-AC Units</u>        |                          |                      |
| Aero Nav Report 5774      | SB-0-25                  | 7/23/75 Appendix 4   |
| Aero Nav Report 5770      | SB-3-100                 | 4/24/75 Appendix 5   |
| <u>SMB-DC Units</u>       |                          |                      |
| Aero Nav Report 5772      | SMB-0-25                 | 7/28/75 Appendix 6   |
| Acton Report 13732        | SMB-000-5                | 12/1/77 Appendix 7   |
| Acton Report 13732-1      | SMB-0-40                 | 12/1/77 Appendix 8   |
| <u>SMB/HBC Assemblies</u> |                          |                      |
| Aero Nav Report 5-6167-5  | SMB-1-25/H4BC            | 11/18/75 Appendix 9  |
| Acton Report 14331-2&3    | SMB-000-5/H0BC           | 9/11/78 Appendix 10  |
| Acton Report 14801-1      | SMB-1-60/H3BC            | 5/10/79 Appendix 11  |
| Acton Report 14801        | SMB-3-150/H5BC           | 5/11/79 Appendix 11  |
| <u>Modutronic</u>         |                          |                      |
| Wyle Report 43059-02      | Modutronic<br>(on SMB-5) | 10/30/75 Appendix 12 |



## SEISMIC QUALIFICATION ENVELOPE

### 1.0 INTRODUCTION

A group of Limitorque Valve Actuators, chosen to envelope the entire generic family of available actuators type SMB/SB/SBD sizes 000 to 5 and SMC-04 (refer Fig. 1) were subjected to a seismic qualification per IEEE 344-1975. Included were SMB,SB (which are mod SMB units), as well as SMC actuators. SMB and SMC valve actuators mounted on secondary reducers (type HBC) also were chosen to envelope the worst possible unit assembly combinations and were also subjected to seismic qualifications per IEEE 344-1975.

### 2.0 DISCUSSION


The "Seismic Qualification Envelope" establishes a generic test plan to envelope all standard Limitorque actuators as support for Limitorque's environmental qualifications. This report discusses shake table limitations and presents Limitorque's test philosophy to provide a better understanding of the test methods employed. Figure 1 is included showing representative actuators from the generic family.

#### 2.0.1 Generic Family


The entire line of Valve Actuators, including the electric motors types SMB/SB/SBD/SMC/HBC, is a generic family, all constructed of similar materials and designed to same concepts, tolerance and stress levels with physical size varying as a function of rating.




# LIMITORQUE ACTUATOR GENERIC FAMILY



SMC-04




SMB-000 & SMB-00




SMB-0 THRU 5

NOTE: VIEW WITH BROKEN LINES SHOW ADDITION OF SPRING PACK TO MAKE SB OR SBD ACTUATOR.



SMC-04/HBC



SMB/HBC

FIGURE 1





### 2.0.1 (Continued)

The same principle applies to the electric motors used with our actuators. Valve actuator weight is a mathematical function of torque and further the largest motor permissible on a specific actuator is nominally a fixed percentage of the overall actuator weight, further supporting the generic family concept (refer to Figures 3 and 4).

### 2.0.2 Seismic Qualification Envelope

This document "Seismic Qualification Envelope" - Report B0037, has been created to support our generic envelope used in our various environmental qualifications. Based on the generic family concept, the following applies to seismic qualification:

- A. Since all Limitorque A.C. and D.C. equipment respond and are generically equivalent with regard to seismic excitation under 6g and under 35 hz, the A.C. and D.C. seismic test data would be mutually supportive of each other.
- B. Seismic tests on SMB/HBC assemblies can be used to qualify the SMB actuator to the seismic level obtained from accelerometers on the SMB mounting flange as well as qualify the adaption between the SMB and HBC units to the seismic test levels.

### 2.0.3 Loading Simulation

During each of the seismic test dwells, the actuators are operated from a limit switch position to a torque seated position, back to the limit switch position to assure the actuator is performing






FIGURE 3






FIGURE 4



### 2.0.3 Continued

properly during the seismic excitation. The torque switch is calibrated prior to the seismic test to the units rating for both thrust and torque. The stroke time of the actuator during seismic testing is normally less than established for Environmental Qualifications due to restrictions established by seismic fixturing. However, the actual stroke time during a seismic test is unimportant since the intent is to subject the unit to seismic vibration with operation merely proving the Valve Actuator capable of operating and providing the required torque and thrust.

### 2.0.4 Weight Distribution

Primarily, seismic consideration directs itself to a weight distribution problem and resolves into the necessity of checking the adequacy of various connecting flanges. This document is a group of seismic tests conducted on units that are considered to contain either the typical or worst weight distribution that would provide the most severe loading on connecting flanges during seismic excitations, thereby providing a generic envelope for seismic qualification.

### 2.0.5 Discussion - Test Method

Most actuators are installed on valves mounted in pipe runs. It is the general contention in the industry that during an actual seismic event that, due to the pipe run, the valve and actuator would be





#### 2.0.5 Continued

subject to excitation in one mode dominated by one frequency. This supports the sine dwell method of testing.

Furthermore, the sine dwell seismic test is, from our experience, the most severe test that can be performed on Limitorque actuators and thereby a more important reason for conducting this type of test.

#### 2.0.6 Discussion - Resonance

Seismic tests conducted on a hydraulic shake table supported our engineering opinion that no resonances would be found below 5 hz and that no resonances or cross-coupling exist in the frequency range of 1 to 33 hz. Verification of this can be found in the tests conducted after November 1977 (included in the Appendix of this document). Accelerometer charts, that are light sensitive and not capable of being reproduced, are available for audit.

Currently, no seismic resonance checks have been made on all internal components. However, engineering evaluation of the internal components used in the construction of Limitorque Actuators shows that the elements used are rigid members with closely spaced supports with resonant frequencies much in excess of 33 hz.

#### 2.0.7 Discussion - Cross Coupling

The great number of seismic tests we have conducted have shown no resonant frequencies below 33 hz and clearly provides verification that no cross coupling exists. Since the actuators respond independently



### 2.0.7 Continued

in each of the three orthogonal axis (no cross coupling), our seismic testing, even that performed prior to 1975, was in fact conducted per IEEE 344-1975 (refer to paragraph 6.6.6 of IEEE 344-1975).

In the seismic testing we have performed, we used several test facilities with these facilities having both mechanical and hydraulic shake tables. Some of the test data from the mechanical table illustrates slight indication of cross-coupling, however, shows no signs of resonance. During our progress of seismic testing, we evaluated the mechanical table and found that the slight signs of cross-coupling were in the table itself and not in the Limitorque Actuator.

---

### 2.0.8 Actuator Test Criteria

#### 2.0.8.1 Description - Seismic Fixturing

Limitorque Actuators are required to produce their rated thrust and torque during seismic dwell tests to simulate an actual seismic event and provide assurance all of the actuator components are operating properly.

For linear actuators, such as SMB/SB/SBD/SMC, this is accomplished by use of an acme screw in the Actuator with anti-rotation device and shoulder to bear against the test stem in the seismic test fixture to cause torque switch tripping of the Actuator in the "close" position. This stimulates the seating of a gate or globe valve.



#### 2.0.8.1 (Refer to Fig. 2)

When rotary actuators such as SMB/HBC or SMC/HBC are prepared for a seismic test, the fixture bolted to the secondary reducer (HBC) contains a stop with a key on the HBC output bearing against this stop in the "close" position. The torque switch on the SMB/SMC is calibrated to provide the rated output torque of the HBC.


(Refer Fig. 2)

#### 2.0.8.2 Switch Calibration


Prior to the start of the seismic test, the Actuator's torque switch is calibrated to the units output torque rating. Proper choice of the acme thread assures obtaining or slightly exceeding the units rated thrust for linear actuators.

#### 2.0.8.3 Stroke Time


To provide reasonable fixturing (low silhouette) to insure dynamic stability of the seismic testing machine, the stroke of the valve actuator is substantially reduced (for seismic test only) maintaining the torque seat feature and reducing stroke time. The actual stroke time during seismic testing/aging is unimportant since the intent is to age the unit by seismic vibration with operation merely proving the Valve Actuator capable of operating, providing the required torque and thrust, which has been demonstrated.



# SEISMIC FIXTURING



## LINEAR ACTUATORS-SMB/SB/SBD/SMC



## ROTARY ACTUATORS-SMB/HBC & SMC-04/HBC

FIGURE-2

