

Facility Staff (Cont'd)


- e. A licensed Senior Reactor Operator shall be required in the Control Room during power operations and when the emergency plan is activated. This may be the Station Shift Supervisor - Nuclear or the Assistant Station Shift Supervisor - Nuclear during power operations. When the emergency plan is activated, the Assistant Station Shift Supervisor - Nuclear becomes the Shift Technical Advisor and the Station Shift Supervisor - Nuclear is restricted to the control room until an additional licensed Senior Reactor Operator arrives.
- f. A licensed Senior Reactor Operator shall be responsible for all movement of new and irradiated fuel within the site boundary. All core alterations shall be directly supervised by a licensed senior reactor operator who has no other concurrent responsibilities during this operation. A Licensed Operator will be required to manipulate the controls of all fuel handling equipment except movement of new fuel from receipt through dry storage. All fuel moves within the core shall be directly monitored by a member of the reactor analyst group.
- g. A Fire Brigade of five (5) members* shall be maintained on site as defined by 5.1 at all times.
- h. Administrative procedures shall be developed and implemented to limit the working hours of facility staff who perform safety-related functions; e.g., licensed Senior Operators, licensed Operators, health physicists, auxiliary operators and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the facility is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications on a temporary basis, the following guidelines shall be followed:

* The Radiation Protection qualified individual and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed two hours in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.

Amendment No. 65
Corrected

| | |
|------------|----------------|
| 8505170621 | 850502 |
| PDR | ADOCK 05000220 |
| P | PDR |



Vertical text or markings on the left side of the page, possibly bleed-through or a scanning artifact.

Facility Staff (Cont'd)

- e. A licensed Senior Reactor Operator shall be required in the Control Room during power operations and when the emergency plan is activated. This may be the Station Shift Supervisor - Nuclear or the Assistant Station Shift Supervisor - Nuclear during power operations. When the emergency plan is activated, the Assistant Station Shift Supervisor - Nuclear becomes the Shift Technical Advisor and the Station Shift Supervisor - Nuclear is restricted to the control room until an additional licensed Senior Reactor Operator arrives.
- f. A licensed Senior Reactor Operator shall be responsible for all movement of new and irradiated fuel within the site boundary. All core alterations shall be directly supervised by a licensed senior reactor operator who has no other concurrent responsibilities during this operation. A Licensed Operator will be required to manipulate the controls of all fuel handling equipment except movement of new fuel from receipt through dry storage. All fuel moves within the core shall be directly monitored by a member of the reactor analyst group.
- g. A Fire Brigade of five (5) members* shall be maintained on site as defined by 5.1 at all times.
- h. Administrative procedures shall be developed and implemented to limit the working hours of facility staff who perform safety-related functions; e.g., licensed Senior Operators, licensed Operators, health physicists, auxiliary operators and key maintenance personnel.

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a normal 8-hour day, 40-hour week while the facility is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications on a temporary basis, the following guidelines shall be followed:

* The Radiation Protection qualified individual and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed two hours in order to accommodate unexpected absence, provided immediate action is taken to fill the required positions.



11 11 11

11 11

.

.

.

.

.

.

.

.

.

.

.

.

.

.