

January 23, 1984

DISTRIBUTION Docket NRC PDR Local PDR **ORB** Reading NSIC **DCrutchfield RGilbert** HSmith OELD ELJordan JMTaylor ACRS (10) SEPB KDesai RBevan

Œ

Docket No. 50-237/249 LS05-84-01-032

> Mr. Dennis L. Farrar Director of Nuclear Licensing Commonwealth Edison Company Post Office Box 767 Chicago, Illinois 60690

Dear Mr. Farrar:

\* e =

SUBJECT: RESOLUTION OF NUREG-0737 ITEM II.K.3.45, DEPRESSURIZATION WITH OTHER THAN ADS

Dresden Nuclear Power Station, Units 2 and 3

We have completed our review of the BWR Owners Group (BWROG) response, dated December 30, 1980, to NUREG-0737 Item II.K.3.45, Depressurization With Other than ADS. In your letter of December 15, 1980 you referenced the BWROG position as applying to your facility. Also, the BWROG confirms that its position on this item applies to your facility.

Based on our evaluation of the BWROG submittal, we conclude that alternative modes of depressurization would not contribute to plant safety and no modification in plant design or operation is required.

The issuance of this letter and enclosed Safety Evaluation completes our action on this item.

Sincerely,

Original signed by

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enclosure: Safety Evaluation

8401250040 840123

PDR ADOCK 05000237

cc w/enclosure: See next page

PDR

OFFICED DL: ORB #5. DL: ORB/#5. SURNAMED RG1100.t.cc. DCrutchfield. DATED 5//3/83 (/23/84

NRC FORM 318 (10/80) NRCM 0240

SEDI 1/1 DSU USE EX (16)

OFFICIAL RECORD COPY

۰

• • • 



· -

Mr. Dennis L. Farrar

- 2 -

cc Isham, Lincoln & Beale Counselors at Law One First National Plaza, 42nd Floor Chicago, Illinois 60603

Mr. Doug Scott Plant Superintendent Rural Route #1 Morris, Illinois 60450

U. S. Nuclear Regulatory Commission Resident Inspectors Office Dresden Station RR #1 Morris, Illinois 60450

Chairman Board of Supervisors of Grundy County Grundy County Courthouse Morris, Illinois 60450

Illinois Department of Nuclear Safety Manager, Office of Nuclear Facility Safety 1035 Outer Park Drive, 5th Floor Springfield, Illinois 62704

U. S. Environmental Protection Agency Federal Activities Branch Region V Office ATTN: Regional Radiation Representative 230 South Dearborn Street Chicago, Illinois 60604

James G. Keppler, Regional Administrator Nuclear Régulatory Commission, Region III 799 Roosevelt Road Glen Ellyn, Illinois 60137 ¥

Υ

.

.

.

.

r



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

### SAFETY EVALUATION OF BWR OWNERS' GROUP GENERIC RESPONSE TO ITEM 11.K.3.45 OF NUREG-0737

## "DEPRESSURIZATION WITH OTHER THAN AUTOMATIC DEPRESSURIZATION\_SYSTEM"

## DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3

## DOCKET NOS. 50-237/249

## 1.0 INTRODUCTION

NUREG-0737 Item II.K.3.45 requires an analysis or a feasibility study to examine depressurization modes other than full actuation of the automatic depressurization system (ADS). Slower depressurization would reduce the possibility of exceeding vessel integrity limits by rapid depressurization.

The BWR Owners Group has performed such a feasibility study. The study applies to all licensed BWR plants to which Item II.K.3.45 would apply. The objective of the study was to determine the effects of slower modes of depressurization in comparison to ADS blowdown on reactor pressure vessel (RPV) structural integrity and core cooling capability.

# 2.0 EVALUATION

The automatic depressurization system is an independent backup system for the high pressure emergency core cooling system which reduces the reactor pressure in the event of a small pipe break so that LPCI/LPCS can maintain core cooling and limit for cladding temperature. The ADS employs safety and relief valves (SRVs) to relieve high pressure steam to the suppression pool.

The BWR Owners Group generic response to this item is given in a letter to Darrell G. Eisenhut (NRC) from D. B. Waters (BWR Owners' Group), BWROG-80-12, "BWR Owners' Group Evaluation of NUREG-0737 Requirements," December 29, 1980.

The BWR Owners' Group has analyzed two base transients (an outside steamline break and stuck open relief valve) as candidates for slower modes of depressurization assuming no high pressure cooling system is available.

The feasibility study includes the following various cases to determine core uncovered time and liquid inventory in the core using the SAFE computer code.

. -

• • • • • . •

• ,

#### Depressurization cases:

## Initiation from Top of Active Fuel

- Full ADS blowdown 3.3 minutes (ADS actuation depressurizes reactor pressure from 1050 psig to 180 psig in approximately 3.3 minutes).
- (2) Vessel depressurization within 6 to 10 minutes.
- (3) Vessel depressurization within 15 to 20 minutes.

# Initiation from Level 2 (level at which ECCS initiate) plus 60 seconds

- (1) Full ADS blowdown 3.3 minutes.
- (2) Vessel depressurization within 6 to 10 minutes.
- (3) Vessel depressurization within 15 to 20 minutes.

The BWR Owners' Group has concluded that slower modes of depressurization would not have any significant benefit on RPV fatigue usage but can affect core cooling capability. Earlier depressurization would not affect core cooling capability; however, it will increase challenges to HPCI/HPCS and in turn may result in increased ADS actuations. In addition, an operator will have less time available to restore HPCI/HPCS.

The staff's contractor, EG&G, has performed a confirmatory analysis using the TRAC computer code to verify the GE conclusions and has found similar results. The staff has evaluated the BWR Owners Group response, and concur with the Owners' Group response and conclusions based on the following information.

The reactor pressure vessel stress and fatigue analyses are performed in accordance with ASME Code, Section III (NB-3200) requirements. Detailed fatigue analyses for RPV include pressure/temperature/flow design transients for plant systems operating and testing conditions. GE has concluded that the feedwater nozzle is the limiting components from a RPV fatigue usage point of view. The plant normal heat-up condition contributes the maximum fatigue usage for the feedwater nozzle. The ADS actuation event is not the limiting transient affecting RPV structural integrity. All BWR RPVs could withstand more than one ADS blowdown event based on the GE fatigue analyses information.

However, if a BWR plant should experience the ADS actuation event without HPCI/HPCS, there is a concern for the integrity of welded connections in the core vicinity. These welded connections have a tendency to become embrittled due to their exposure to irradiation and the thermal environment. Also this environment would reduce their fracture toughness. Under these circumstances, licensees must demonstrate integrity of welded connections in the vessel by analysis or inspection before a plant can resume further operation (following an ADS actuation event).

• • , . . ف 1 • , . .

All BWR containment structures are designed to accommodate the loadings associated with the SRV discharge pool dynamic loadings resulting from plant systems design transients. This provides assurance that containment structural integrity would be maintained under the ADS actuation event loadings.

## 3.0 CONCLUSION

The staff concludes that the as designed RPV and containment structures of all BWR plants listed in Table 1 would maintain structural integrity under the ADS event and would be able to withstand more than one ADS event. Slower modes of depressurization could affect core cooling capability without any significant benefit on RPV fatigue usage. Earlier modes of depressurization would not affect core cooling capability. However, they would increase challenges to HPCI/HPCS and also affect ADS actuation frequency. Overall, alternate modes of depressurization in comparison to ADS blowdown would not contribute any significant benefit to plant operation and safety, and therefore, no modifications in plant design and operation are required.

### 4.0 ACKNOWLEDGEMENT

The following NRC employee was the principal contributor to this SE:

∶K. Desai

Date: January 23, 1984

: . ▼

.

· · · · ·

**`**\_\_\_\_\_\_

.

TABLE 1

NUREG-0737 ITEM 11.K.3.45

Boston Edison Carolina Power & Light

Commonwealth Edison

· · · ·

Georgia Pòwer

Iowa Electric Light & Power

Jersey Central Power & Light

Niagara Mohawk Power

Nebraska Public Power District

Northeast Utilities

Northern States Power

Philadelphia Electric

Power Authority of the State of New York Tennessee Valley Authority

Vermont Yankee Nuclear Power Detroit Edison Long Island Lighting Mississippi Power & Light Pennsylvania Power & Light Washington Public Power Supply System Cleveland Electric Illuminating Houston Lighting & Power Illinois Power Public Service of Oklahoma

Pilgrim 1 Brunswick 1/2 · LaSalle 1/2, Dresden 2/3, . Quad Cities 1/2 Hatch 1/2 Duane Arnold Oyster Creek Nine Mile Point 1/2 Cooper Millstone 1 Monticello Peach Bottom 2/3, Limerick 1/2 Fitzpatrick Browns Ferry 1-3, Hartsville 1-4, Phipps Bend 1/2 Vermont Yankee Enrico Fermi 2 Shoreham Grand Gulf 1/2 Susquehanna 1/2 Hanford 2 Perry 1/2 Allens Creek Clinton Station 1/2 Black Fox 1/2

.

.

-

.

-. .

۰ ۲ 

•

. v