

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8601030033 DOC. DATE: 85/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ZWOLINSKI, J. A. BWR Project Directorate 1

SUBJECT: Provides addl info re B40321 application to amend Tech Specs
 3.1.5, 4.1.5, 3.2.9 & 4.2.9. Solenoid actuated pressure relief.
 Valve testing at or near operating pressure & temp
 appropriate based on listed reasons.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: 05000220
 OL: 08/22/69

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	BWR PD1 PD 01	5 5	HERMANN, R	1 1
INTERNAL:	ACRS 09	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	NRR BWR EB	1 1
	NRR PWR-A EB	1 1	NRR PWR-B EB	1 1
	NRR/DHFT/TSCB	1 1	NRR/DSRO DIR	1 1
	NRR/DSRO/RRAB	1 1	NRR/ORAS	1 0
	<u>REG FILE</u> 04	1 1	RGN1	1 1
EXTERNAL:	24X	1 1	EG&G BRUSKE, S	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1		

ADD: EB (LTAU)
 PSB (L. HUBMAN)
 EICSB (SRINIVASAN)
 RSB (Acting)
 FOB (VASSALLO)
 AD - G. LAJMAS (ltr only)

TOTAL NUMBER OF COPIES REQUIRED: LTR ³⁴~~28~~ ENCL ³¹~~25~~



1. The first part of the document
 discusses the general principles
 of the system and its
 objectives. It also outlines
 the scope of the study and
 the methods used to collect
 data. The second part of the
 document presents the results
 of the study and discusses
 their implications. The third
 part of the document provides
 a summary of the findings and
 offers some conclusions and
 recommendations.

December 31, 1985
NMP1 L0007

Director of Nuclear Reactor Regulation
Attention: Mr. John A. Zwolinski, Project Director
BWR Project Directorate Number 1
Division of BWR Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Nine Mile Point Unit 1
Docket No. 50-220
.....DPR-63.....

Dear Mr. Zwolinski:

Our letter of March 21, 1984 proposed changes to technical specification sections 3.1.5, 4.1.5, 3.2.9 and 4.2.9. The following information is provided to supplement and clarify that letter with respect to testing of the solenoid actuated pressure relief valves.

Testing of these valves at or near operating temperature and pressure provides the best assurance that these valves will operate satisfactorily if called upon to actuate. Reasons for this are:

1. Valve operation during automatic depressurization system actuation would be expected to occur during normal power operation. Therefore, valve operation to depressurize the system would likely start at or near normal operating pressure and temperature.
2. Valve operation in response to overpressure would occur slightly above reactor operating pressure.
3. The thermal conditions and pressure loads on the valves are more severe at rated pressure and temperature conditions. In particular, concerns regarding effects of differential thermal expansion of close clearance parts would be greater at reactor operating temperature than at lower temperatures.

8601030033 851231
PDR ADOCK 05000220
P PDR

Add
EB (LIAW)
PSB (L. HULMAN)
EICSB (SRINIVASAN)
RSB (ACTING)
FOB (VASSALLO)
AD - G. LAINAS (Ltr only)


Adol

The following information was obtained from the records of the
 Department of the Interior, Bureau of Land Management, on
 the subject of the above-captioned tract of land.
 The tract of land described in the above caption is
 situated in the County of [County Name], State of [State Name].
 The tract of land is bounded on the north by [Description],
 on the east by [Description], on the south by [Description],
 and on the west by [Description]. The total area of the
 tract is [Area] acres.
 The tract of land is owned by [Owner Name], who is
 the [Relationship] of [Owner Name]. The tract of land
 was acquired by [Owner Name] on [Date]. The tract of
 land is currently being used for [Use]. The tract of
 land is subject to the following conditions:
 1. [Condition 1]
 2. [Condition 2]
 3. [Condition 3]
 4. [Condition 4]
 5. [Condition 5]
 6. [Condition 6]
 7. [Condition 7]
 8. [Condition 8]
 9. [Condition 9]
 10. [Condition 10]

4. While the valves depend on system pressure to actuate the main valve, a system pressure of approximately 250 psig is adequate to open the valves. Further, actual experience with failures of relief valves to open have typically been associated with mechanical problems with the pilot valve, its solenoid actuator and the solenoid-pilot valve linkages, which are not affected by valve pressure.
5. Relief valve actuation at operating temperature and pressure during startup would be verified by flow through the relief valves as indicated by closure of the turbine bypass valves.

Based on the above, testing of the relief valves at operating temperature and pressure is deemed appropriate.

Very truly yours,



C. V. Mangani
Senior Vice President

MGM:ja

The following information is being furnished to you for your information only. It is not to be disseminated outside your organization. This information is being furnished to you for your information only. It is not to be disseminated outside your organization.

The following information is being furnished to you for your information only. It is not to be disseminated outside your organization. This information is being furnished to you for your information only. It is not to be disseminated outside your organization.

The following information is being furnished to you for your information only. It is not to be disseminated outside your organization. This information is being furnished to you for your information only. It is not to be disseminated outside your organization.

SECRET

CONFIDENTIAL