

March 4, 1986

MEMORANDUM FOR: John A. Zwolinski, Director
BWR Project Directorate #1
Division of BWR Licensing

FROM: Gus Lainas, Assistant Director
for BWR
Division of BWR Licensing

SUBJECT: TECHNICAL SPECIFICATION CHANGES - NINE MILE POINT UNIT 1
(TAC 60553)

Plant Name: Nine Mile Point Unit 1
Docket No.: 50-220
Licensing Stage: OR
Responsible Project Directorate: BWR #1
Project Manager: Janet Kelly
Review Branch: EICSB
Review Status: Complete

Enclosed is the Electrical Instrumentation Control Systems Branch's (EICSB) safety evaluation of proposed changes to the Technical Specifications for Nine Mile Point Unit 1 as requested by Niagara Mohawk Power Corporation letter dated January 15, 1986. Based on this review, the proposed changes are found acceptable.

Please note that there is an error on licensee's letter Attachment A Table 3.6.2a. The title for Table 3.6.2a should be "INSTRUMENTATION THAT INITIATES SCRAM" rather than "INSTRUMENTATION THAT INITIATES OR ISOLATES EMERGENCY COOLING".

151

Gus Lainas, Assistant Director
for BWR
Division of BWR Licensing

Enclosure:
As stated

cc w/Enclosure:
W. Houston
T. Speis
E. Rossi
D. Crutchfield
J. Kelly
D. Vassallo
W. Russell

DISTRIBUTION
Docket File
NRC PDR
Local PDR
PD#1 Reading
HLi
MSrinivasan
DVassallo
GLainas

CONTACT: H. Li, EICSB/DBL
x29452

BWR:EICSB
HLi:jg *Li*
3/4/86

MSL for
BWR:EICSB
MSrinivasan
3/4/86

DBL:AD/BWR
GLainas
3/4/86

8603120364 860304
PDR ADDCK 05000220
P PDR

