

July 11, 1986  
(NMP2L 0780)

Ms. Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

Niagara Mohawk's March 3, 1986 letter provided a commitment relative to the undervoltage relay. The testing to confirm the setting on the undervoltage relay has been completed and accepted by Engineering, but it has not been reviewed by the Joint Test Group or Site Operations Review Committee. The test results verified the analytical techniques and assumptions used to perform the degraded grid voltage analysis described in FSAR Section 8.2.2. Our studies show that the computer analysis performed conforms to the general criteria set forth in Branch Technical Position (BTP) PSB-1, Item 4 of Section B. Further, we have discussed these results with the Nuclear Regulatory Commission's resident inspector on site.

Very truly yours,



T. E. Lempges  
Vice President  
Nuclear Generation

TEL/NLR:ja  
1794G

xc: W. A. Cook, NRC Resident Inspector  
Project File (2)



Handwritten scribbles or marks in the top right corner.

Faint, illegible text or markings in the middle left section.

Faint, illegible text or markings in the middle right section.

Faint, illegible text or markings in the lower right section.

Faint, illegible text or markings in the lower right section.

Faint, illegible text or markings in the lower middle section.