

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608010133 DOC. DATE: 86/07/24 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Forwards for info, description & environ assessment of new alternate access point (APP) constructed at facility. Const of new App has not resulted in significant increase in any adverse environ impact previously reviewed & evaluated.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DGAVT/GAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR BWR ADTS	1 1	NRR/DHFT/MTB	1 1
	REG FILE 04	1 1	RGN1	3 3
	RM/DDAMI/NIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 36 ENCL 31

July 24, 1986
(NMP2L 0796)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. NUCLEAR REGULATORY COMMISSION
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

SUBJECT: Nine Mile Point Nuclear Station Unit 2
Operating License Application
Docket No. 50-410

Attached for your information is a description and environmental assessment of the new Alternate Access Point (AAP) constructed at the Nine Mile Point Unit 2 site.

Based on the environmental assessment performed, it is concluded that construction of the new AAP has not resulted in a significant increase in any adverse environmental impact previously reviewed and evaluated in the Nine Mile Point Unit 2 Final Environmental Statement - Operating License Stage.

Very truly yours,

C. V. Mangano

C. V. Mangano
Senior Vice President
Nuclear Engineering & Licensing

JAM/ds
Attachment

cc: W. A. Cook
Project File (2)

8608010133 860724
PDR ADCK 05000410
A PDR

Boo!
||



2744

2744

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 24th day of July, 1986.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:
CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires March 30, 1987

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4187631
My Commission Expires March 30, 19...

NINE MILE POINT NUCLEAR STATION UNIT 2
ALTERNATE ACCESS POINT

Facility Description

The Alternate Access Point (AAP) is a two-story, steel and masonry building located on Niagara Mohawk property just northeast of the Unit 2 cooling tower. This location is within the Nine Mile Point Nuclear Generation Site boundary. The main entrance to the AAP is accessible from Lake Road.

This 30,000 square foot building will house visitor processing areas, access control areas, physical training and examination areas, and general office areas.

The visitor processing area consists of an entry vestibule, visitors and employees check stations, a waiting area, a photo ID area, a meeting room, and three general offices. The purpose of this area is for the processing of Niagara Mohawk employees, contractors, and visitors for entrance to restricted areas in the generating station.

The access control area includes an access control room, site entry and exit turnstiles, and a truck inspection area. The purpose of this area is to check personnel, inspect packages, and search vehicles prior to admittance to the site.

The physical training area consists of a training room, men's and women's locker rooms, and showers. The purpose of this area is for the training of the Security Officers.

The general office areas consist of approximately ten separate offices, two conference rooms, a kitchen, and several storage closets.

Environmental Assessment

This building is located on plant property that was previously cleared, paved, and used as a parking lot during construction of Unit 2. Therefore, no additional impact on vegetation has occurred. Areas that have been disturbed during construction of the building will be graded and landscaped upon completion of the facility.

Potable water and water for fire protection systems are provided through existing domestic and fire protection lines respectively. The domestic water demand for the AAP does not provide any significant additional demand on the Oswego City water supply.



Sanitary wastes from the AAP will be treated at the new 120,000 gpd Sewage Treatment Plant constructed at the Nine Mile Point generation site. The estimated 3500 gpd loading from the AAP can easily be handled by existing treatment capacity available at the Sewage Treatment Plant. Waste water flows at the new sewage treatment plant will be treated and monitored to comply with State Pollutant Discharge Elimination System permit effluent limitations.

Construction and operation of the new Unit 2 AAP will not require any new Federal/State permits or any modifications to existing permits.

In summary, construction and operation of the new Alternate Access Point will not result in any adverse impacts on the environment.

