

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608050191 DOC. DATE: 86/07/30 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Responds to NRC questions re FSAR changes to Table 3.8-1, Page 6 & Table 3.8-12, Page 3 transmitted by Amend 26. Info provided on alternative concrete & steel acceptance criteria utilized in selected structures.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DQAVT/QAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR ROE M L	1 1	NRR/DHFT/MTB	1 1
	<u>REG FILE</u> 04	1 1	RGN1	3 3
	RM/DDANI/MIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02.	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

July 30, 1986
(NMP2L 0800)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

This letter responds to Nuclear Regulatory Commission staff questions about Nine Mile Point Unit 2 Final Safety Analysis Report changes to Table 3.8-1, page 6 and Table 3.8-12, page 3 transmitted by Amendment 26. The staff reviewer asked Niagara Mohawk Power Corporation to furnish information on the alternative concrete and steel acceptance criteria utilized in selected structures at Nine Mile Point Unit 2. We were asked to provide:

1. the structure and location where the practice was used,
2. the load and load combinations where the normal limits are exceeded,
3. the method of calculating governing stresses,
4. the minimum concrete compressive strength,
5. the actual strength and test data used, the expected deviation in those results, the age of the concrete when tested, and how much margin is available.

8608050191 860730
PDR ADOCK 05000410
A PDR

Boo1
//

100

100

100

100

100


100

100

Ms. Elinor G. Adensam
Page 2

The above information was requested separately for concrete and steel.
That information is provided in Attachment 1 including Tables A and B.

Very truly yours,




C. V. Mangan
Senior Vice President

DLH:ja
1873G

Attachment

xc: W. A. Cook, NRC Resident Inspector
Project File (2)

Attachment 1



USE OF MATERIAL TEST RESULTS

FOR DESIGN ADEQUACY AT NMP2

NMP2 structures are designed in accordance with loads and loading combination described in FSAR section 3.8, ACI and AISC manuals for concrete and steel structures. During the normal design process, design stresses were within ACI and AISC minimum allowables. When structures were verified for actual system loads (cable trays, conduits, pipes, ducts, etc) the calculated stresses exceeded the allowable stresses in a few isolated cases. For these cases, actual strength test reports were used to satisfy the design conditions, without deviation from concrete and steel strength acceptance criteria, and the design meets FSAR and code requirements.

Concrete

1. The use of actual compressive strength test reports for concrete were used at the following three locations during final structure verification efforts.

A&B. Two embedment plates at El. 265'-2" primary containment wall - B018 & B019.

C. One embedment plate at El. 386'-10" secondary containment wall - IP-280.

2. The governing loads and load combinations from FSAR section 3.8 were considered to compute maximum member stresses. Structural components are designed for the most severe load combinations. Attached Table A indicates the load combination where the limits are exceeded.
3. Stresses in concrete structures are governed by the American Concrete Institute's (ACI 318-77) design criteria requirements. The design stresses are within ACI allowables (refer to Table A for design and allowable stresses).
4. In general, for the NMP2 project, the specified minimum compressive strength of concrete for major structures is 3000 psi at 28 days. Several structural components, such as primary containment wall, reactor pedestal, fuel pool area, screenwell building and intake tunnel are constructed using concrete with 4000 psi at 28 days.
5. Concrete is tested for compressive strength at 7 and 28 days. Test reports are traceable to specific pour locations and document the actual compressive strength of cylinders at 7 and 28 days.



• • • • •

•

•

•

•

•

•

Generally, the actual compressive strength of these cylinders is found to be between 15% to 40% higher than the minimum specified compressive strength at 28 days. When calculated stresses exceed the allowable design stresses, actual compressive strength test reports for the specific pour under consideration are obtained to justify final stresses by considering actual concrete strength.

A further consideration is the increase in strength that concrete experiences with time. Industry tests have demonstrated a significant increase in strength after the 28 day tests. Using the conservative value of 10%, the strength increase will exceed one standard deviation calculated from the specific test values used in the analysis.

For the first example shown in Table A, Primary Containment plates, the calculated average concrete strength, based on twelve cylinder tests for specimen age of 28 days is found to be 5748 psi.

Structural Steel

1. The use of certified material test reports (CMTRs) for structural steel is used when the stresses in any member, due to final system loads (cable trays, conduits, pipes, duct, etc.) exceed the allowables during final structures verification efforts. This practice is used for steel components at various locations in safety related structures.

For a typical floor in the Primary Containment, approximately 6% of beams (19 out of 320 beams) used CMTRs to satisfy the design conditions.

2. The governing loads and load combinations from FSAR Section 3.8 were considered to compute maximum member stresses. Steel components are designed for most severe load combinations. Table B presents two examples where the original design limits were exceeded.
3. Stresses in structural steel members are governed by the American Institute of Steel Construction (AISC) design criteria requirements. The design stresses are always within AISC allowables.
4. In general, ASTM A36 material with F_y of 36KSI is used for structural steel framing. In certain areas, high strength steel conforming to A572, A588, Grade A or B with F_y of 50 ksi is used.
5. CMTRs are received with the purchased materials and are traceable to specific mark numbers. They provide documentation of the actual yield strength of the material. Generally, the actual yield strengths are found to be a minimum 10% higher than the



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

minimum yield strength required. When calculated stresses exceed the allowable design stresses, CMTRs for that steel member were obtained to justify the final stresses by considering actual yield strengths available during final structures verification efforts.

Typical examples and summary results of beam and column stresses before and after using the test results are represented in Table B of Attachment 1.



11-11-11

TABLE A

Attachment I

Building	Location	Type of Structure	Governing Load Combination	Calc. Pullout Loads (KIPS)	Design Concrete Strength f'c (psi) at 28 days	Concrete Pullout Capacity (KIPS)	Calc. Pullout Ratio to Allow.	Average Comp. Strength Results fc' (psi)	Revised Concrete Pullout Capacity (KIPS)	Revised Load Ratio to Allow. Load with Test Reports
Primary Contmnt	El 265'-2" AZ 349°-38' AZ 10°-57'	Embedded Plate B018 and B019	FSAR Table 3.8-11 Equation 17	1,182	4,000	1,064	1.11	5,748	1,275	0.92
Secondary Contmnt	El 386'-10" AZ 244°	Embedded Plate IP-280	FSAR Table 3.8-11 Equation 4	133	4,000	125	1.06	5,620	148	0.90

TABLE B

Building	Location	Member Size	Governing Load Combination	Yield Strength Fy (KSI)	Interaction Formula Results	Yield Strength from CMTR Fy (KSI)	Interaction Formula Results with CMTR
Primary Contmnt	El 288'-3 1/4"	Beam W14 x 233	FSAR Table 3.8-10 Equation 12	36	1.12	41.50	0.97
Secondary Contmnt	El 261'-0" to 289'-0"	Column W14 x 109	FSAR Table 3.8.10 Equation 5	36	1.05	40.70	0.92



11-11-11

11