

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608050210 DDC DATE: 86/07/31 NOTARIZED: YES DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 LEMPGES, T. E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAN, E. G. BWR Project Directorate 3

SUBJECT: Forwards revised Pages 3 of 4 & 4 of 4 from Preservice insp program Relief Request RR-IWC-8 per NRC 860724 telcon request.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	BWR ADTS		1	1		BWR EB		1	1
	BWR PD3 LA		1	0		BWR PD3 PD 01		5	5
	HAUGHEY, M		1	1					
INTERNAL:	ACRS	16	10	10		ADM/LFMB		1	0
	AEOD/PTB		1	1		ELD/HDS3		1	0
	NRR/PSRO/EIB		1	1		NRR/TAMB		1	1
	<u>REG FILE</u>	04	1	1		RGN1		1	1
EXTERNAL:	LPDR	03	1	1		NRC PDR 02		1	1
	NSIC	05	1	1					

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.
3. 3. 3. 3. 3.
4. 4. 4. 4. 4.
5. 5. 5. 5. 5.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.
3. 3. 3. 3. 3.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.
3. 3. 3. 3. 3.
4. 4. 4. 4. 4.
5. 5. 5. 5. 5.

SECRET
1. 1. 1. 1. 1.
2. 2. 2. 2. 2.
3. 3. 3. 3. 3.
4. 4. 4. 4. 4.
5. 5. 5. 5. 5.

July 31, 1986
(NMP2L 0802)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

This letter transmits revised pages 3 of 4 and 4 of 4 from Nine Mile Point Unit 2 Preservice Inspection Program relief request RR-IWC-8. These pages are being sent as a result of a telephone conversation with Nuclear Regulatory Commission staff members on July 24, 1986 during which additional information about Code requirements was requested. They supersede the same pages transmitted by letter NMP2L-0773 on July 9, 1986.

Very truly yours,



T. E. Lempges
Vice President
Nuclear Generation

TEL/AFZ:ja
1884G

xc: W. A. Cook, NRC Resident Inspector
Project File (2)

8608050210 860731
PDR ADDCK 05000410
Q PDR

A047
111



2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT


T. E. Lempges, being duly sworn, states that he is Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

T. E. Lempges

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 31st day of July, 1986.

Janis M. Macro
Notary Public in and for
Onondaga County, New York

JANIS M. MACRO
My commission expires:
Notary Public in the State of New York
Qualified in Onondaga County No. 4784555
My Commission Expires March 30, 1987...



Nine Mile Point Unit 2

Relief Request No: RR-IWC-8

Due to interferences on the following welds, 100% coverage of could not be accomplished.

<u>Weld</u>	<u>Exam Category</u>	<u>Exam Item</u>	<u>% Cover Vol/Surf</u>	<u>Interferances</u>
2RHS-66-57-FW307	C-C	C3.40	NA/45	Permanent Tube Steel
2RHS-66-12 VWMOV1C-B thru D	C-G	C6.20	NA/85	Permanent Stiffener Plate
2RHS-66-13 VWMOV2A-A thru C	C-G	C6.20	NA/90	Permanent Stiffener Plate
2CSL-26-01 VWMOV112-B thru D	C-G	C6.20	NA/85	Permanent Stiffener Plate
2MSS-01-05-FW-08	C-F	C5.21	95/100	Sock-o-let
2MSS-01-04-FW-12	C-F	C5.21	98/100	Header Configuration
2CSH-25-04-FW-03	C-F	C5.11	70/100	Weld Configuration
2CSH-25-04-FW-07	C-F	C5.11	85/100	Weld Configuration
2CSH-25-04-FW-08	C-F	C5.11	85/100	Weld Configuration
2CSH-25-08-FW-06	C-F	C5.21	85/100	Permanent Restraint
2CSH-25-09-FW-04	C-F	C5.21	66/100	Permanent Restraint
2CSH-25-09-FW-300	C-C	C3.40	NA/55	Concrete Structure
2CSH-25-09-FW-305	C-C	C3.40	NA/55	Concrete Structure
2CSL-26-02 VWHCV118 C & D	C-G	C6.20	NA/80	Welded Attachment
2CSL-26-03-FW-25	C-F	C5.11	90/100	Sweep-o-let
2RHS-66-13-FW-21	C-F	C5.11	50/100	One Side S.S. Exam
2RHS-66-14-FW-01	C-F	C5.11	90/100	Permanent Restraint
2RHS-66-14-PW-114A	C-C	C3.70	NA/70	Integral Attachments
2RHS-66-15-HW-100A	C-A	C1.10	99/100	Welded Attachments



100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

100-100000-100000

Nine Mile Point Unit 2

Relief Request No: RR-IWC-8

<u>Weld</u>	<u>Exam Category</u>	<u>Exam Item</u>	<u>% Cover Vol/Surf</u>	<u>Interferances</u>
2RHS-66-15-HW-101A	C-A	C1.10	98/100	Adjacent Nozzle Weld
2RHS-66-15-HW-102A	C-B	C2.21	90/100	Adjacent Flange Weld
2RHS-66-15-HW-103A	C-B	C2.21	95/100	Sock-o-let
2RHS-66-15-HW-105A	C-B	C2.22	75/100	Nozzle Configuration
2RHS-66-16-FW-304	C-C	C3.40	NA/95	Floor Sleeve
2RHS-66-18-FW-311,312	C-C	C3.40	NA/60	Permanent Restraint
2RHS-66-19-SW-26	C-F	C5.11	95/100	Weld Configuration
2RHS-66-20-FW-303-306	C-C	C3.40	NA/70	Permanent Restraint
2RHS-66-22-FW-19	C-F	C5.11	50/100	One Side S.S. Exam
2RHS-66-32-FW-05	C-F	C5.11	95/100	Sock-o-let
2RHS-66-57-FW-305,306	C-C	C3.40	NA/85	Permanent Restraint



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

100