

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608120300 DOC. DATE: 86/08/07 NOTARIZED: YES DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moho 05000410  
 AUTH. NAME AUTHOR AFFILIATION  
 MANGAN, C. V. Niagara Mohawk Power Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Forwards "Methodology for Combined Radwaste & Reactor Bldg Vent Accident X/Q Values at Control Room Ventilation Air Intakes," in response to NRC concerns raised during 860731 meeting re control room habitability analysis.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 57  
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	BWR ADTS	1	1	BWR EB	1	1
	BWR EICSB	2	2	BWR FOB	1	1
	BWR PD3 LA	1	1	BWR PD3 PD	7	7
	HAUGHEY, M	1	1	BWR PSB	1	1
	BWR RSB	1	1			
INTERNAL:	ADM/LFMB	1	0	IE/DEPER/EPB	3	3
	NRR BWR ADTS	1	1	NRR PAULSON, W	1	1
	NRR PWR-B ADTS	1	1	NRR/DSRO EMRIT	1	1
	NRR/DSRO/EIB	1	1	NRR/DSRO/RSIB	1	1
	<u>REG FILES</u>	1	1	RGN1	1	1
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			



August 7, 1986  
(NMP2L 0808)

Ms. Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

Enclosed is a summary report on the method of development of the Nine Mile Point Unit 2 X/Q values. This report responds to NRC staff questions raised during the July 31, 1986 meeting relative to the control room habitability analysis.

After your review we would be pleased to discuss any questions on the report at your earliest convenience.

Sincerely,

*C. V. Mangan*

C.V. Mangan  
Senior Vice President

NLR/meg  
Attachment  
(1910G)

xc: W. A. Cook Resident Inspector  
Project File (2)

8608120300 860807  
PDR ADDCK 05000410  
A PDR

A003  
1/1

Faint, illegible text at the top of the page, possibly a header or title area.

Faint, illegible text in the middle of the page.

Faint, illegible text at the bottom right of the page.

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Niagara Mohawk Power Corporation ) Docket No. 50-410  
(Nine Mile Point Unit 2) )

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. V. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 7<sup>th</sup> day of August, 1986.

Janis M. Macro  
Notary Public in and for  
Onondaga County, New York

My Commission expires:  
JANIS M. MACRO

Notary Public in the State of New York  
Qualified in Onondaga County No. 478455E  
My Commission Expires March 30, 1987

١٠٠

١٠٠

١٠٠

١٠٠  
١٠٠  
١٠٠

١٠٠


## INTRODUCTION AND SUMMARY

This report provides the methodology and data used in the calculation of the Nine Mile Point-Unit 2 (NMP2) combined radwaste and reactor building vent X/Q values at the control room air intakes.

The combined radwaste and reactor building vent X/Q value calculations were performed using site specific meteorological data. Building wake effects determined through the application of wind tunnel tests to the NMP2 site were also used in these calculations. These X/Q values were calculated using two different accident scenarios--(1) all NMP2 site buildings are standing, and (2) only the seismically qualified NMP2 site buildings are standing. The radiological consequences of the postulated DBA LOCA use the most conservative X/Q value resulting from the two different accident scenarios.

FSAR Sections 2.3.4 and 2.3.5 summarize in detail the accident X/Q values to the EAB and the LPZ from the main stack and combined radwaste and reactor building vent.

Since the main stack is more than twice as high as all adjacent structures, so that the stack plume will be unaffected by the nearby structures. Therefore, the accident X/Q values for the main stack to the control room air intakes are calculated with the same methodology as those used for the EAB and LPZ. (See FSAR Section 2.3)





METHODOLOGY FOR COMBINED RADWASTE AND REACTOR BUILDING  
VENT ACCIDENT X/Q VALUES AT THE CONTROL ROOM  
VENTILATION AIR INTAKES



## I. INTRODUCTION

A release of radioactivity following an accident at the Unit 2 nuclear reactor may reach the atmosphere via (1) the combined radwaste and reactor building vent or (2) the main stack. After dispersion in the atmosphere, the radioactive material may enter the main control room via the fresh air intakes.

The combined radwaste and reactor building vent releases have been analyzed by Dr. James Halitsky using the procedures and methodology described in Section III. All of the conversion factors, assumptions, references, and intermediate calculations are detailed in this report.

## II. PLANT ARRANGEMENT

Figure 1 shows the plant arrangement for the all buildings stand scenario. Figure 2 shows the plant arrangement for the seismic buildings stand scenario. In both figures, the fresh air intakes are shown by small circles and numbers; the numbering scheme is given in Table 1. The documentation of seismic and non-seismic buildings, their dimensions and the location of the fresh air intakes were obtained from the plot plans and the building drawings of References 1, 2, and 3.

Figures 1 and 2 represent the combined radwaste and reactor building vent release, with the 16 sectors centered at the release point and oriented to true North (14.5° clockwise from plant North).



The terrain in the plant area is flat with a grade elevation of 261-ft. MSL. The only large structure nearby is the natural draft cooling tower whose center is about 1,000 ft. south of the reactor building.

The combined radwaste and reactor building vent release configuration is a 5-ft. x 19-ft. rectangular duct terminating at elevation of 447-ft. or 186-ft. (56.7 m) above grade. The release is assumed to have zero exit velocity (Reference 4).

### III. COMBINED RADWASTE AND REACTOR BUILDING VENT ANALYSIS

Dispersion near buildings is strongly affected by disturbances created by the buildings. Conventional Gaussian equations cannot be used because the dispersion coefficients and the mean velocities vary in space in an unknown manner. Reliance must be placed on information derived from measurements of dispersion around buildings resembling the subject buildings. The most detailed of such measurements are obtained in wind tunnel model tests. It is believed that normalized concentrations ( $K_c$  values) from model tests will give reliable predictions of full scale concentrations under neutral stability conditions in the absence of heat in the effluent, if geometric and dynamic similarity are preserved in model and full scales and minimum Reynolds Number criteria are met.



### Conversion of $K_c$ to $Xu_{200}/Q$

The definition of  $K_c$  is

$$K_c(x/L, y/L, z/L) = A(Xu/Q) \quad (1)$$

where:

- $K_c$  = concentration coefficient  
(dimensionless)
- $X$  = real concentration ( $Ci\ m^{-3}$ )
- $A$  = reference building area ( $m^2$ )
- $u$  = reference wind speed ( $m\ s^{-1}$ )
- $Q$  = release rate ( $Ci\ s^{-1}$ )
- $L$  = reference length (m)
- $x, y, z$  = receptor coordinates (m)

In model testing,  $X$  is measured at a variety of receptor locations for known  $Q$ ,  $u$  and  $A$ , and  $K_c$  is computed at each point by Equation 1. Isopleths of  $K_c$  are then drawn through the field along designated surfaces.

When predicting  $Xu/Q$  for a new full-scale configuration that satisfies the similarity requirements, Equation 1 may be rewritten as





$$Xu/Q = K_c/A$$

(1a)

where:

$K_c$  = the model test value at the  
normalized full scale receptor location  
 $x/L, y/L, z/L$

$x, y, z$  = full scale receptor coordinates

$L$  = full scale reference length

$A$  = full scale reference area

It is implied that  $u$  is measured at the same normalized elevation as in the model test.

The most extensive body of data describing concentrations in the cavity region of a building resembling the Unit 2 reactor building, is the set of  $K_c$  isopleths for the EBR-II containment structure in Reference 5. The shape of the EBR-II containment is an 80-ft. hemisphere on a 58-ft. vertical cylinder of the same diameter. The reference length was the diameter  $D = 80$  ft., the reference elevation for wind speed was  $z = 160$  ft., and the full scale roughness length in the logarithmic wind profile was 0.0492 ft.



The Unit 2 base diameter is 171 ft. (52.1 m); therefore, the linear scale factor is  $171/80 = 2.138$  and the equivalent lengths are cylinder height = 124 ft., (37.8 m), wind speed reference height = 342 ft. (104.2 m) and roughness height = 0.105 ft. (0.032 m). The reference area in the model tests was the cross-section in a vertical plane through the building center. The equivalent area for Unit 2 is computed by adding one-half the cross-sectional area of the hemisphere ( $1/2 \pi r^2$ ) plus the area of the base height times the diameter). Substituting the equivalent Unit 2 values, the area is equal to  $1/2 \pi (85.5)^2 + 124 \times 171 = 32,687 \text{ ft.}^2$  ( $3,037 \text{ m}^2$ ).

In calculating  $Xu/Q$  for a new building for a reference height other than the equivalent EBR-II reference height, the following adjustment factor, based on the logarithmic wind profile must be used:

$$u_{\text{new}}/u_{\text{old}} = (\ln z_{\text{new}}/z_0)/(\ln z_{\text{old}}/z_0). \quad (2)$$

For the Unit 2 anemometer at  $z_{\text{new}} = 200 \text{ ft.}$ , Equation 2 becomes:

$$u_{200}/u = (\ln 200/0.105)/(\ln 342/0.105) = 0.934 \quad (2a)$$

Combining Equations 1a and 2a and using  $A = 3,037 \text{ m}^2$  gives:

$$\begin{aligned} Xu_{200}/Q \text{ (m}^{-2}\text{)} &= (Xu/Q)(u_{200}/u) = (K_c/3,037) (0.934) \\ Xu_{200}/Q &= 3.1 \times 10^{-4} K_c \end{aligned} \quad (3)$$



B. Conversion of EBR-II Isopleths to Unit 2 Scale

The first step in using the EBR-II  $K_c$  isopleths is to select those which most plausibly represent Unit 2 flow conditions. The shapes of the two containment structures are not identical, as seen in Figure 3 where the equivalent EBR-II containment is superimposed on the Unit 2 reactor building. The lack of a dome on Unit 2 will create a different  $K_c$  pattern in the vicinity of the combined radwaste and reactor building vent release.

The selection technique was to ignore local disturbances, adopt the isopleths which are in general conformity with source location on the building, and adjust for the effect of major buildings as a final step.

Gases released from the combined radwaste and reactor building vent will be caught in the airflow over the roof and will descend into the reactor building cavity before passing downwind. In this respect, the gas will behave in a similar manner to the EBR-II top release (Figure 10 of Reference 5). The expected behavior in easterly and westerly winds is illustrated in smoke photographs Nos. 6, 7, and 8 of Figure 6 of Reference 5. In northerly and southerly winds, where the vent is displaced laterally from the centerline, a strong asymmetry in high concentrations exists aloft, but the concentrations at lower elevations are more symmetrically distributed, as may be seen in the isopleths of Figure 14 of Reference 5. The asymmetry due to lateral source displacement is also seen in the smoke photographs of Figure 7 of Reference 5, but the effect at lower elevations is exaggerated because of the lower



release point. Since the vent release is nearer the elevation of the top of the dome (Figure 10 isopleths) than the top of the cylinder (Figure 14 isopleths), the former were selected as representative of the combined radwaste and reactor building vent releases in all wind directions.

Thus, use of the EBR-II  $K_c$  isopleths, with adjustments to reflect local wake dispersion, appear to offer reasonable estimates of Unit 2 isopleths.

To make the transition from the normalized distance scales of Reference 5 to the real scale (1 in = 207 ft.) of Figures 1 and 2, Figure 4 was prepared and used as an overlay for transcribing the isopleth contours. The reactor building diameter (171 ft.) was the basis for the conversion, and adjustment was made for the drawing scales of the Reference 5 figure.

Figure 4 for combined radwaste and reactor building vent releases, contains provision for variable roof height of the downwind buildings. Reference-1 calls for  $X/Q$  values at the interiors of non-seismic buildings at ground level. This condition cannot be fulfilled without knowledge of the interior air flow. It was assumed that interior concentrations would be the same as roof-level concentrations at standing buildings because of infiltration and forced ventilation. The Unit 2 buildings were assigned to three roof-height groups corresponding to  $z/D = 0.25, 0.50$  and  $0.75$ .





The grouping is shown in Table 2. The four sets of isopleths in Figure 4 represent plume concentrations at ground and at elevations of 43 ft., 86 ft. and 128 ft., corresponding to the above fractions. They were constructed from the isopleths in Figure 10 of Reference 5.

Using the aforementioned methodology, the  $K_c$  isopleths obtained for the combined radwaste and reactor building vent are presented in Figures 5-20 for the all buildings stand scenario, and in Figures 21-36 for the seismic buildings stand scenario. Specific attention should be given to the control room air intakes (locations indicated in Figures 1 and 2).

The site specific  $K_c$  values by wind direction determined from Figures 5-20 (all buildings stand scenario), and Figures 21-36 (seismic buildings stand scenario), have been tallied for the control room air intake locations in Table 4 (all buildings stand) and Table 5 (seismic buildings stand).

C. Determination of 0.5% Sector-Dependent X/Q Values

Accident X/Q values at the control room building fresh air intakes due to releases from the combined radwaste and reactor building vent are calculated using onsite meteorological data and site-specific wind direction dependent  $K_c$  values. These 0.5% accident X/Q values are calculated for two scenarios; all buildings stand and seismic buildings stand.



In order to determine the 0.5% probability sector-dependent X/Q values, the onsite meteorological tower data are employed. A detailed description of the tower, the meteorological instruments, and accuracies, along with the data recovery, is given in Section 2.3 of the Nine Mile Point Unit 2 FSAR, Reference 6.

Wind direction and speed data for the five-year period, January 1974 through December 1976 and November 1978 through October 1980, are used from the 200-ft. tower level transmitted by Reference 6. Wind direction data from 100-ft. instrumentation are substituted for missing 200-ft. directions. A cumulative frequency distribution of the reciprocal of the wind speed ( $1/u_{200}$ ) is calculated for each of the 16-22.5° sectors in 1 mph wind speed increments by the MES program named SECTOR. Calms are conservatively assigned a wind speed of 1 mph. Calm hours with no directions are distributed in proportion to the number of 1 to 3 mph wind speeds in each 22.5° sector. For each of the distributions, the 0.5% probability value of  $1/u_{200}$  is determined by conservatively enveloping the data points according to the methodology suggested by Markee in Reference 7. The 0.5%  $1/u_{200}$  by sector and the corresponding wind speed,  $u_{200}$ , are listed in Table 3.

The application of the sector-dependent, site-specific  $K_c$  values by wind direction for the control room building fresh air intakes (Tables 4 and 5) and the use of the wind direction dependent 0.5%  $1/u_{200}$  values in Equation 3 permit the calculation of wind dependent 0.5% X/Q values. The highest 0.5% X/Q value independent of wind direction is used as the 0.5% accident X/Q value at the fresh air intake. This 1-hour 0.5% accident X/Q value is assumed to represent the 0-2 hour 0.5% accident X/Q.



D. Interpolation of the 0-2 Hour 0.5% X/Q Values to Longer Time Periods

The use of site-specific meteorological data combined with sector-dependent  $K_c$  values allows for the determination of annual X/Q values. The annual X/Q values at the fresh air intakes are calculated from the frequency of  $1/u_{200}$  in 1 mph increments for each sector multiplied by the corresponding sector-dependent  $K_c$  value and the appropriate conversion factor of  $3.1 \times 10^{-4}$ .

The sum of the  $K_c$  values divided by the wind speed for each of the 1 mph categories multiplied by the corresponding wind speed frequency (f) for all 16 sectors is the annual average X/Q value for the fresh air intake release-scenario combination.

$$\begin{aligned} & 16 \text{ } u = \text{maximum} \\ \text{Annual X/Q} &= \sum_{\text{sector} = 1}^{16} \sum_{u = 1}^{u = u_{\text{max}}} K/U \text{ } f \text{ } \text{conversion factor} \\ & \text{sector} = 1 \quad u = 1 \end{aligned} \quad (4)$$

Using these annual X/Q values and the 0-2 hour 0.5% X/Q values, the intermediate time period X/Q values are logarithmically interpolated.

Results

The control room air intake X/Q values for the combined radwaste and reactor building vent release are presented in Table 7.



## References

1. Letter from A. R. Capellini (Stone & Webster Engineering Corp.) to M. Kramer (Meteorological Evaluation Services, Inc.) dated June 3, 1983.
2. Letter from A. R. Capellini to J. Halitsky dated June 10, 1983.
3. Letter from N. Rademacher (Niagara Mohawk Power Corp.) to M. Kramer dated June 29, 1983.
4. Letter from M. Kramer to J. Halitsky dated June 28, 1983.
5. Halitsky, J., J. Golden, P. Halpern and P. Wu (1963): Wind Tunnel Tests of Gas Diffusion from a Leak in the Shell of a Nuclear Power Reactor and from a Nearby Stack. NYU Dept. of Met. and Ocean. GSL Rept. 63-2.
6. Niagara Mohawk Power Corporation: Nine Mile Point Nuclear Station - Unit 2 - Final Safety Analysis Report, January 1983.
7. Markee E. H. and Levine J. R.: Probabilistic Evaluations of Atmospheric Diffusion Conditions for Nuclear Facility Design and Siting. In proceedings of the American Meteorological Society Conference on Probability and Statistics in Atmospheric Sciences, Las Vegas, NV, 1977, p 146-150.





TABLE 1

IDENTIFICATION OF FRESH AIR INTAKES

<u>Fresh Air Intake No.</u>	<u>Location</u>	<u>Distance (m) From Containment Surface</u>
4a	Control Room Bldg. - East Wall High	39
4b	Control Room Bldg. - East Wall Low	39
9	Control Room Bldg. - West Wall High	57
10	Control Room Bldg. - West Wall Low	48

NINE MILE POINT UNIT 2 RELEASE CHARACTERISTICS

<u>Parameter</u>	<u>Combined Radwaste and Reactor Building Vent</u>
Release Height Above Grade	57.0 187.0
Exit Diameter	3.4* 11.0*

\*Equivalent diameter for the rectangular vent.




TABLE 2

GROUPING OF BUILDING ACCORDING TO HEIGHT

Bldg. No.	Bldg. Name	Parapet Height H (ft.)	Bldg. H/D	Assigned H/D
3	Turbine	120.0	0.70	0.75
4	Radwaste	81.6	0.48	0.50
5	Screenwell	78.8	0.46	0.50
8	Control Room	70.5	0.41	0.50
14	Condensate Storage	59.0	0.35	0.25
15	Switchgear Penthouse	57.8	0.34	0.25
18	Switchgear	36.0	0.21	0.25
19	Diesel Generator	31.0	0.18	0.25



TABLE 3

0.5% PROBABILITY SECTOR DEPENDENT (200-FT WIND SPEED)<sup>-1</sup>  
JANUARY 1974 THROUGH DECEMBER 1976 AND  
NOVEMBER 1978 THROUGH OCTOBER 1980

Wind Direction Sector (°)	0.5% (1/ u <sub>200</sub> ) (sec/m)	Equivalent u <sub>200</sub>	
		(m/sec)	(mph)
360.0	0.497	2.0	4.5
22.5	0.476	2.1	4.7
45.0	0.533	1.9	4.2
67.5	0.447	2.2	5.0
90.0	0.533	1.9	4.2
112.5	0.476	2.1	4.7
135.0	0.678	1.5	3.3
157.5	0.699	1.4	3.2
180.0	0.799	1.3	2.8
202.5	0.658	1.5	3.4
225.0	0.639	1.6	3.5
247.5	0.722	1.4	3.1
270.0	0.799	1.3	2.8
292.5	0.639	1.6	3.5
315.0	0.559	1.8	4.0
337.5	0.466	2.2	4.8



TABLE 4

VALUES OF  $K_c$  AT THE FRESH AIR INTAKES  
COMBINED RADWASTE AND REACTOR BUILDING VENT RELEASE - ALL BUILDINGS STAND

<u>Ventilation Air Intake</u>	<u>Wind Direction</u>															
	<u>N</u>	<u>NNE</u>	<u>NE</u>	<u>ENE</u>	<u>E</u>	<u>ESE</u>	<u>SE</u>	<u>SSE</u>	<u>S</u>	<u>SSW</u>	<u>SW</u>	<u>WSW</u>	<u>W</u>	<u>WNW</u>	<u>NW</u>	<u>NNW</u>
Control Room Building																
West Wall																
High	2.0	2.0	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Low	2.2	2.2	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
East Wall																
High	1.9	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
Low	1.9	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0





TABLE 5

VALUES OF  $K_c$  AT THE FRESH AIR INTAKES  
COMBINED RADWASTE AND REACTOR BUILDING VENT RELEASE - SEISMIC BUILDINGS STAND

<u>Ventilation Air Intake</u>	<u>Wind Direction</u>															
	<u>N</u>	<u>NNE</u>	<u>NE</u>	<u>ENE</u>	<u>E</u>	<u>ESE</u>	<u>SE</u>	<u>SSE</u>	<u>S</u>	<u>SSW</u>	<u>SW</u>	<u>WSW</u>	<u>W</u>	<u>WNW</u>	<u>NW</u>	<u>NNW</u>
Control Room Building																
West Wall																
High	0.0	2.0	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Low	0.0	2.5	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
East Wall																
High	2.3	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0
Low	2.3	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0



TABLE 6

## VENTILATION AIR INTAKE X/Q VALUES

COMBINED RADWASTE AND REACTOR BUILDING VENT RELEASE  
(SEC/M<sup>3</sup>)

<u>All Building Stand Ventilation Air Intake</u>	Time Period (Hours)				
	<u>0-2</u>	<u>0-8</u>	<u>8-24</u>	<u>24-96</u>	<u>96-720</u>
<u>Control Room Building</u>					
West Wall					
High	3.08E-04	1.90E-04	1.50E-04	8.87E-05	4.20E-05
Low	3.39E-04	2.11E-04	1.66E-04	9.88E-05	4.70E-05
East Wall					
High	2.93E-04	1.72E-04	1.32E-04	7.42E-05	3.25E-05
Low	2.93E-04	1.72E-04	1.32E-04	7.42E-05	3.25E-05
<u>Seismic Building Stand Ventilation Air Intake</u>					
<u>Control Room Building</u>					
West Wall					
High	2.95E-04	1.65E-04	1.24E-04	6.58E-05	2.68E-05
Low	3.69E-04	2.13E-04	1.62E-04	8.92E-05	3.80E-05
East Wall					
High	3.54E-04	2.05E-04	1.56E-04	8.65E-05	3.70E-05
Low	3.54E-04	2.05E-04	1.56E-04	8.65E-05	3.70E-05






Fig. 1

General Arrangement and  
 Vital Area Access Grid  
 All Buildings Stand  
 Wind Pattern

21 JUNE 1983

SOUTH ELEVATION  
 NINE MILE POINT NUCLEAR STATION

WIND DIRECTION  
 RADWASTE/REACTOR BUILDING VENT REFLECTOR  
 ALL BUILDINGS STAND






Fig. 2. General Arrangement and Vital Area Access Grid Seismic Buildings Stand





Figure 3

# BUILDING CONFIGURATION IN RELEASE AND INTAKE AREA








Figure 4

# EQUIVALENT EBR-II $K_c$ ISOPLETHS FOR TOP RELEASE









Figure 5

J. MALITSKY 27 JUNE 1968

SOUTH ELEVATION  
WIND BLOW POINT NUCLEAR STATION

WIND DIRECTION 060  
RADWASTE/REACTOR BUILDING VENT RELEASE  
ALL BUILDINGS STAND





J. HALITSKY 27 JUNE 1988


SOUTH ELEVATION  
 WIND MILL POINT NUCLEAR STATION

WIND DIRECTION 022.5  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND

Figure 6







J. MALITSKY 21 JUNE 1968






Figure 8







Figure 9

J HALITSKY 21 JUNE 1985

SOUTH ELEVATION  
MILLERS POINT NUCLEAR STATION

WIND DIRECTION 090  
RADWASTE/REACTOR BUILDING VENT RELEASE  
ALL BUILDINGS STAND






Figure 10:

J. HALITSKY 27 JUNE 1968

SOUTH ELEVATION  
 WINDS SCALE POINT NUCLEAR STATION

WIND DIRECTION 112.5  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND









Figure 1.1

Z. HALITSKY 27 JUNE 1968

SOUTH ELEVATION  
 WIND MILL POINT NUCLEAR STATION

WIND DIRECTION 135  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND





J. HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
 HMP MILE POINT NUCLEAR STATION

WIND DIRECTION 157.5  
 RABWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND

Figure 12






Figure 13

J. HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
 HUMBOLDT POINT NUCLEAR STATION

WIND DIRECTION 180  
 RADIATION/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND






Figure 14









Figure 15





J HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
MILL POINT NUCLEAR STATION

WIND DIRECTION 247.5  
RADWASTE/REACTOR BUILDING VENT RELEASE  
ALL BUILDINGS STAND

Figure 16

EAST ELEVATION






Figure #7

EAST ELEVATION






Figure 18

J. HALITSKY 27 JUNE 1968


SOUTH ELEVATION  
 HULLS POINT NUCLEAR STATION  
 WIND DIRECTION 292.5  
 RAPWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND












SOUTH ELEVATION  
 HINE MILLS POINT NUCLEAR STATION

WIND DIRECTION 337.5  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 ALL BUILDINGS STAND

J MALITSKY 27 JUNE 1983

Figure 20






J MALITSKY 27 JUNE 1983

SOUTH ELEVATION  
MILE POINT NUCLEAR STATION

WIND DIRECTION 000  
RADWASTE/REACTOR BUILDING VENT KELEA  
SEISMIC BUILDING STAND


Figure 21











J HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
 HANFORD SITE  
 HANFORD MILLS POINT NUCLEAR STATION

WIND DIRECTION 045  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 SEISMIC BUILDING STAND

Figure 23







Figure 24





J MALITSKY 27 JUNE 1983

SOUTH ELEVATION  
 WIND MILE POINT NUCLEAR STATION

WIND DIRECTION 090  
 RADWASTE/REACTOR BUILDING YENT KELEA  
 SEISMIC BUILDINGS STAND

Figure 25






Figure 2


J. HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
MILL POINT NUCLEAR STATION

WIND DIRECTION 112.5  
RADWASTE/REACTOR BUILDING VENT RELE  
SEISMIC BUILDINGS STAND







Z HALTSKY 27 JUNE 1963

THREE MILE POINT NUCLEAR STATION

WIND DIRECTION 135  
 RADWASTE/REACTOR BUILDING VENT KEEL  
 SEISMIC BUILDING STAND

Figure 27








Figure 281





J HAUTSKY 21 JUNE 1983

SOUTH ELEVATION  
 NINE MILE POINT NUCLEAR STATION

WIND DIRECTION 180  
 RADWASTE/REACTOR BUILDING VENT RELEASE  
 SEISMIC BUILDING STAND

Figure 129



1 1 1




Figure 30

J MALITSKY 27 JUNE 1983


SOUTH ELEVATION  
 NINE MILE POINT NUCLEAR STATION

WIND DIRECTION 202.5  
 RADWASTE/REACTOR BUILDING VENT RELEASES  
 SEISMIC BUILDINGS STAND



...





J. MALITSKY 27 JUNE 1983

NINE MILE POINT NUCLEAR STATION

WIND DIRECTION 225  
 RADWASTE/REACTOR BUILDING VENT RELIEF  
 SEISMIC BUILDING STAND

Figure 3/



.....




Figure 32



...




Figure 33


J HALITSKY 27 JUNE 1963

SOUTH ELEVATION  
HIGH MILE POINT NUCLEAR STATION

WIND DIRECTION 270  
RADWASTE/REACTOR BUILDING VENT RELEASE  
SEISMIC BUILDING STAND



...



J HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
 NINE MILE POINT NUCLEAR STATION

WIND DIRECTION 292.5°  
 RADWASTE/REACTOR BUILDING VENT RELIEF  
 SEISMIC BUILDINGS STAND

Figure 34 +



1111







Figure 35



11-11-53

11-11-53

1



J. HALITSKY 27 JUNE 1983

SOUTH ELEVATION  
MILLERS POINT NUCLEAR STATION

WIND DIRECTION 337.5  
RADWASTE/REACTOR BUILDING VENT RELEASE  
SEISMIC BUILDINGS STAND

Figure 36

