

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608250075 DDC DATE: 86/08/21 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Forwards list of util comments on SSER 3 reflecting differences between SER & suppls & FSAR through Amend 27.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DGAVT/QAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR RCE, M. L.	1 1	NRR/DHFT/MTB	1 1
	<u>REG FILE</u> 04	1 1	RGN1	3 3
	RM/DDAMI/MIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

August 21, 1986
(NMP2L 0834)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Enclosed is a list of Niagara Mohawk's comments on the Safety Evaluation Report Supplement 3. Our comments reflect differences between the Safety Evaluation Report and Supplements, and the Final Safety Analysis Report through Amendment 27. Generally, the comments do not address the status of open issues.

Very truly yours,

C. V. Mangan
C. V. Mangan
Senior Vice President

NLR:ja
1987G

Enclosure

xc: R. A. Gramm, NRC Resident Inspector
Project File (2)

8608250075 860821
PDR ADOCK 05000410
E PDR

Boal
1/1

... ..
... ..
... ..
... ..

... ..

... ..
... ..
... ..
... ..

... ..

... ..

... ..
... ..

... ..

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 21st day of August, 1986.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
~~My Commission Expires March 30, 1987~~

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4707687
My Commission Expires March 30, 19 -

SER SUPPLEMENT #3 COMMENTS

<u>PAGE #</u>	<u>COMMENTS</u>	<u>REFERENCE</u>
2-3	Section 2.5.6.2.4 1st paragraph 4th line: change <u>uniformly</u> to <u>randomly</u> .	FSAR Section 2.5.5.4.2
2-3	Section 2.5.6.2.4 1st paragraph 6th line: change No. <u>2</u> stones to No. <u>1</u> stones.	FSAR Figure 2.5-127
3-1	Section 3.6.2 2nd paragraph 3rd line: change "for ASME Code Class 1 piping when..." to "for ASME Code Class 1 piping within the NSSS scope of supply when...".	Question and Response F210.17 and F210.17A FSAR Section 3.6.2.15A (pg. 3.6A-12).
3-4	Section 3.9.6 1st paragraph 1st line: change "SFR" to "SER".	
3-4	Section 3.9.6 2nd paragraph 14th line: Change Winter <u>1981</u> to Winter <u>1980</u> .	PSI Plan Section 1.1.1; Question and Response F250.1
3-4	Section 3.9.6 Last Paragraph: The new criteria stated in this paragraph has been incorporated in the Technical Specification pg. 3/4 4-13 for Nine Mile Point Unit 2.	Technical Specification Pg. 3/4 4-13
4-2	Section 4.4.4.1 Last Paragraph 4th line: The SER states "... transient delta CPR of 0.18." This should be changed to "... transient delta CPR of 0.17".	FSAR Table 15.B.3-4 Appendix 15
6-18	First paragraph second line says "the applicant has committed to lock closed the 3/4-inch solenoid valves ..." These valves cannot be locked. The FSAR commitment is to de-energize the valves.	Table 6.2-56 Notes 2 (pg. 18 of 24)
7-1	Section 7.2.2.3 4th paragraph 3rd line: change "will be incorporated into the FSAR" to "will be incorporated into the FSAR prior to the startup following the first refueling outage".	Letter dated February 7, 1986.



SER SUPPLEMENT #3 COMMENTS
(Continued)

<u>PAGE #</u>	<u>COMMENTS</u>	<u>REFERENCE</u>
7-2	Section 7.2.26 3rd paragraph 1st line: change "FSAR Question 421.66" to "FSAR Question 421.26".	Question and Response F421.26
7-5	Section 7.2.2.8 2nd line of the page: change Model <u>iA</u> -184 should be <u>1A</u> -184.	
7-8	Section 7.6.2.1 4th paragraph 9th line: change "F042A, B, C, and D" to "E12-F042A, B, and C (LPCI) and E21-F005 (LPCS)".	FSAR Section 7.6.1.2 (Pg. 7.6-2a)
13-2	Section 13.3.2.8 last paragraph, 3rd line: remove words ", on an interim basis,". The Nine Mile Point emergency response facilities have been concluded by the NRC to be adequate to support a response effort in the event of an emergency.	NRC Inspection Report IR 86-23.

