

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608250154 DDC DATE: 86/08/21 NOTARIZED: YES DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 MANGAN, C. V. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Suppls 860807 response to NRC concern re Amend 27 to FSAR, deleting orifice in HPCS injection line to reflect as-built condition. Necessity of orifice will be reevaluated during preoperational sys testing. Drawing FSK 27-C.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DQAVT/QAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR ROE, M. L	1 1	NRR/DHFT/MTB	1 1
	<u>REG FILE</u> 04	1 1	RGN1	3 3
	RM/DDANI/MIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 36 ENCL 31

TO THE HONORABLE ATTORNEY GENERAL
FROM THE DIRECTOR, FBI
SUBJECT: [Illegible]

[Illegible text block]

[Illegible text block]

DATE	TO	FROM	RE
10/20/54	Director	Mr. Tolson	[Illegible]
10/20/54	Mr. Tolson	Director	[Illegible]
10/20/54	Mr. Boardman	Director	[Illegible]
10/20/54	Mr. Nichols	Director	[Illegible]
10/20/54	Mr. Belmont	Director	[Illegible]
10/20/54	Mr. Ladd	Director	[Illegible]
10/20/54	Mr. Clegg	Director	[Illegible]
10/20/54	Mr. Glavin	Director	[Illegible]
10/20/54	Mr. Harbo	Director	[Illegible]
10/20/54	Mr. Rosen	Director	[Illegible]
10/20/54	Mr. Tracy	Director	[Illegible]
10/20/54	Mr. Egan	Director	[Illegible]
10/20/54	Mr. Gurnea	Director	[Illegible]
10/20/54	Mr. Hendon	Director	[Illegible]
10/20/54	Mr. Pennington	Director	[Illegible]
10/20/54	Mr. Quinn	Director	[Illegible]
10/20/54	Mr. Nease	Director	[Illegible]
10/20/54	Miss Gandy	Director	[Illegible]

August 21, 1986
(NMP2L 0838)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

This letter documents the information shown a NRC staff reviewer on August 7, 1986 in response to his question as to the reason for the Nine Mile Point Unit 2 (NMP2) Final Safety Analysis Report (FSAR) Amendment 27 change deleting the orifice (2CSH*R0106) in the HPCS injection line. The reviewer was shown Engineering Change Notice (ECN) CSH-604 which added Note 14 to drawing FSK 27-4C. That Note states:

"2CSH*R0106 has been procured and delivered to the site as a blank orifice. Based upon calculation A10.1-G-28 Rev. 0, this RO is not required and shall not be installed. NMPC will retain the blank RO, and shall re-evaluate the need for this RO based upon pre-op test results.

The ECN had been approved by all required parties. The FSAR Amendment 27 change was initiated to reflect the as-built condition of the HPCS injection line, including the effect of ECN CSH-604 on drawing FSK 27-4C. The re-evaluation of the need (or no need for) for the orifice will be confirmed during the preoperational testing of this system as required by the engineering drawing. }

Very truly yours,

C. V. Mangan

C. V. Mangan
Senior Vice President

AP/ar
1993G

xc: W. A. Cook, NRC Resident Inspector
Project File (2)

8608250154 860821
PDR ADOCK 05000410
PDR
A

Boo
/



Handwritten scribbles or marks at the top right corner.

The main body of the page contains extremely faint, illegible text, likely bleed-through from the reverse side of the paper. The text is scattered across the page and is difficult to discern.

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Niagara Mohawk Power Corporation)
(Nine Mile Point Unit 2))

Docket No. 50-410

AFFIDAVIT

C. V. Mangan, being duly sworn, states that he is Senior Vice President of Niagara Mohawk Power Corporation; that he is authorized on the part of said Corporation to sign and file with the Nuclear Regulatory Commission the documents attached hereto; and that all such documents are true and correct to the best of his knowledge, information and belief.

C. Mangan

Subscribed and sworn to before me, a Notary Public in and for the State of New York and County of Onondaga, this 21st day of August, 1986.

Christine Austin
Notary Public in and for
Onondaga County, New York

My Commission expires:

CHRISTINE AUSTIN
Notary Public in the State of New York
Qualified in Onondaga Co. No. 4787687
My Commission Expires March 30, 1987

Handwritten scribble or mark at the top right corner.

1952
MAY 10 1952
U.S. DEPARTMENT OF AGRICULTURE
WASHINGTON, D. C.