

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608250217      DDC DATE: 86/08/21      NOTARIZED: NO      DOCKET #  
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha      05000410  
 AUTH. NAME      AUTHOR AFFILIATION  
 MANGAN, C. V.      Niagara Mohawk Power Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 ADENSAM, E. G.      BWR Project Directorate 3

SUBJECT: Forwards calculation, "Max Allowable Leakage Through Main Steam Valve Under Field Test Condition," in support of 860806 request to change Tech Spec Table 3.6.1.2-1 re main steam isolation valve leak rate.

DISTRIBUTION CODE: B001D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 12  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR EB	1 1	BWR EICSB	2 2
	BWR FOB	1 1	BWR PD3 LA	1 1
	BWR PD3 PD	1 1	HAUGHEY, M 01	2 2
	BWR PSB	1 1	BWR RSB	1 1
INTERNAL:	ACRS 41	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEPER/EPB 36	1 1	IE/DQAVT/QAB 21	1 1
	NRR BWR ADTS	1 0	NRR PWR-B ADTS	1 0
	NRR ROE, M. L.	1 1	NRR/DHFT/MTB	1 1
	<del>REG FILE</del> 04	1 1	RGN1	3 3
	RM/DDAMI/MIB	1 0		
EXTERNAL:	BNL (AMDTS ONLY)	1 1	DMB/DSS (AMDTS)	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	PNL GRUEL, R	1 1

1. The first part of the document discusses the general situation of the country and the role of the government.

2. The second part of the document discusses the economic situation and the measures taken to improve it.

3. The third part of the document discusses the social situation and the measures taken to improve it.

4. The fourth part of the document discusses the political situation and the measures taken to improve it.

5. The fifth part of the document discusses the international situation and the measures taken to improve it.

6. The sixth part of the document discusses the future prospects of the country.

7. The seventh part of the document discusses the role of the government in the future.

8. The eighth part of the document discusses the role of the people in the future.

9.

10. The tenth part of the document discusses the role of the government in the future.

11.

12. The twelfth part of the document discusses the role of the government in the future.

13.

14. The fourteenth part of the document discusses the role of the government in the future.

15.

16. The sixteenth part of the document discusses the role of the government in the future.

17.

18. The eighteenth part of the document discusses the role of the government in the future.

19.

19. The eighteenth part of the document discusses the role of the government in the future.

20.

20. The eighteenth part of the document discusses the role of the government in the future.

21.

21. The eighteenth part of the document discusses the role of the government in the future.

22.

August 21, 1986  
(NMP2L 0835)

Ms. Elinor G. Adensam, Director  
BWR Project Directorate No. 3  
U.S. Nuclear Regulatory Commission  
7920 Norfolk Avenue  
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2  
Docket No. 50-410

This letter provides a copy of the calculation to support our requested change to Technical Specification Table 3.6.1.2-1 for Nine Mile Point Unit 2. Our letter dated August 6, 1986 provided the requested change regarding the allowable Main Steam Isolation Valve leak rate.

The calculation, "Maximum Allowable Leakage Through the Main Steam Valve Under the Field Test Condition", by Stone and Webster Engineering Corporation, is provided in the enclosure of this letter.

Very truly yours,

*C. V. Mangan*

C. V. Mangan  
Senior Vice President

LL/CVM:ar  
1974G  
Enclosure

xc: W. A. Cook, NRC Resident Inspector  
Project File (2)

8608250217 860821  
PDR ADDCK 05000410  
A PDR

Boo  
/



ENCLOSURE



11

CALCULATION TITLE PAGE

\*SEE INSTRUCTIONS ON REVERSE SIDE

✓

▲ 501C 64 (FRONT)

CLIENT & PROJECT Niagara Mohawk Power Corp./Nine Mile Point Unit 2				PAGE 1 OF 10
CALCULATION TITLE (Indicative of the Objective): MAXIMUM ALLOWABLE LEAKAGE THROUGH THE MAIN STEAM VALVE UNDER THE FIELD TEST CONDITION				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER
CALCULATION IDENTIFICATION NUMBER				
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.
12177	ES	217	-	26N

* APPROVALS - SIGNATURE & DATE			REV. NO. OR NEW CALC. NO.	SUPERSEDES * CALC. NO OR REV. NO.	CONFIRMATION * REQUIRED (✓)	
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)			YES	NO
Robert King 1/29/86	Robert J. Kund 1/30/86	Robert J. Kund 1/30/86	0	N/A		✓
ES-Nuclear Technology/Engineered Safety Systems and Analysis Group (CHOC)						

DISTRIBUTION\*

GROUP	NAME & LOCATION	COPY SENT (✓)		GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	Job Book A10.5 NMP2 Document Control-CHOC/SY	Ro	RI			
ESSA (Boston)	J. Oddo 245/09 Supervisor					
Nuclear	M. Allen - SBL Principal Eng'r.					





STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ES	217-0		

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46

TABLE OF CONTENTS

	PAGE No
TITLE PAGE	1
TABLE OF CONTENTS	2
OBJECTIVE	3
RESULT	4
ASSUMPTION	4
REFERENCES	5
CALCULATION	6-10

CONFIRMATION REQUIRED : NONE



11

STONE & WEBSTER ENGINEERING CORPORATION  
 CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ES	CALCULATION NO. 217-0	OPTIONAL TASK CODE	

OBJECTIVE

THE ALLOWABLE LEAKAGE THROUGH THE MAIN STEAM VALVE UNDER THE SPECIFIED TEST CONDITION ( AS SHOWN IN FIG. 1 ) IS 6 SCFH\*. HOWEVER, THE FIELD TEST SETUP IS ARRANGED AS SHOWN IN FIG. 2. THE OBJECTIVE OF THIS CALCULATION IS TO DETERMINE THE NEW ALLOWABLE LEAKAGE RATE UNDER THE FIELD TEST CONDITION.




FIGURE 1.: PREFERRED TEST ARRANGEMENT




FIGURE 2: FIELD TEST ARRANGEMENT

\* REF 3 Pg 9



11

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010 65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>4</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ES	217-0		

1  
2  
3  
4  
5 RESULT  
6  
7

8 THE ALLOWABLE LEAKAGE UNDER FIELD TEST  
9  
10 CONDITION IS 14.86 SCFH.  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

21  
22 ASSUMPTIONS  
23

- 24 1. FLOW THROUGH VALVE SEAL IS ISENTROPIC .  
25  
26 2. TEMPERATURE AT STAGE 1 EQUAL TO AMBIENT  
27 TEMPERATURE OF 80°F  
28  
29 3. OTHER SPECIFIC ASSUMPTIONS STATED IN BODY  
30 OF THE CALC.  
31  
32  
33 4. STP CONDITIONS DEFINED HERE ARE  $P = 14.7 \text{ PSIA}$ ,  
34  $T = 68^\circ \text{F}$ .  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
12177	ES	217-0		

REFERENCES

1. "THE THERMAL - HYDRAULICS OF A BOILING WATER REACTOR" R. T. LAHEY, JR & F. J. MOODY.  
PUBLISHED BY AMERICAN NUCLEAR SOCIETY.
2. "THE DYNAMICS AND THERMODYNAMICS OF COMPRESSIBLE FLUID FLOW" A. H. SHAPIRO.
3. CALCULATION 12177 - ES - 177 - 3  
"SECONDARY CONTAINMENT BYPASS LEAKAGE"

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



11




STONE & WEBSTER ENGINEERING CORPORATION  
 CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 12177	DIVISION & GROUP ES	CALCULATION NO. 217-0	OPTIONAL TASK CODE
			PAGE 5

CALCULATION

• LEAKAGE AREA OF THE VALVE



ASSUME FLOW LEAKED THROUGH THE 1ST SEAL EXPANDED FULLY AT STAGE 1 WITH A PRESSURE OF  $P_1$  BEFORE LEAKING THROUGH THE SECOND SEAL. THE LEAKAGE AREA IN THE SEALS ARE ASSUMED TO BE EQUAL. THE PRESSURE AT STAGE 1,  $P_1$  CAN BE CALCULATED BASED ON THE FOLLOWING EXPRESSION(S):



11

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO. <u>12177</u>	DIVISION & GROUP <u>ES</u>	CALCULATION NO. <u>217-0</u>	OPTIONAL TASK CODE	

$$\dot{m} = A \left\{ 2g_c \left( \frac{k}{k-1} \right) P_0 \gamma_0 \left[ \left( \frac{P_1}{P_0} \right)^{2/k} - \left( \frac{P_1}{P_0} \right)^{\frac{k+1}{k}} \right] \right\}^{1/2} \quad (1)$$

(REF 1 EQN 9.37)  
Pg 347

IF  $\frac{P_1}{P_0} > 0.5283$

AND  $\dot{m} = 0.532 A \frac{P_0}{\sqrt{\gamma_0}} \quad (2) \quad (\text{REF 2 EQN 4.18})$

IF  $\frac{P_1}{P_0} \leq 0.5283$


BASED ON THE PRESSURES,  $P_0 = 54.7 \text{ PSIA}$  &  $P_2 = 14.7 \text{ PSIA}$ , IT APPEARS THAT 4 POSSIBILITIES CAN EXIST:

- ① CHOKE AT 1ST AND 2<sup>nd</sup> SEALS
- ② CHOKE AT 1ST SEAL, UNCHOKE AT 2<sup>nd</sup> SEAL
- ③ UNCHOKE AT 1ST AND 2<sup>nd</sup> SEALS.
- ④ UNCHOKE AT 1ST SEAL AND CHOKE AT 2<sup>nd</sup> SEAL

FOR CONDITION ① & ② WITH CHOKE AT 1ST SEAL, THEN

$$P_1 = P_0 (0.5283) = 28.9 \text{ PSIA OR LOWER}$$

WHICH WILL NOT SATISFY CONTINUITY WHEN CALCULATING FLOW RATE... THUS CONDITION ① & ② CAN'T EXIST.



STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE 8
J.O. OR W.O. NO. 12177	DIVISION & GROUP ES	CALCULATION NO. 217-0	OPTIONAL TASK CODE	

CONDITION ③ CAN NOT EXIST BECAUSE PRESSURE DROP IS LARGE ENOUGH TO CALL FOR CHOKE AT LEAST IN ONE LOCATION.

THUS APPLYING EQNS (1) & (2) FOR CONDITION ④ YIELDS:

$$\dot{m} = A \left\{ 2g_c \left( \frac{K}{K-1} \right) P_o \gamma_o \left[ \left( \frac{P_i}{P_o} \right)^{\frac{2}{K}} - \left( \frac{P_i}{P_o} \right)^{K+1/K} \right] \right\}^{1/2} \quad (3)$$

$$\dot{m} = A (0.532) \frac{P_i}{\sqrt{T_i}} \quad (4)$$

THE PARAMETERS ARE:

$$g_c = 32.2 \text{ lbm} \cdot \text{ft} / \text{lb} \cdot \text{sec}^2 \quad \dot{m} = 6 \text{ SCFH} = \frac{14.7(144)}{53.3(80+460)} \cdot 6 / 3600$$

$$K = 1.4 \text{ FOR AIR} \quad = 1.2536 \text{ E-4 lbm/sec}$$

$$P_o = 54.7 \text{ PSIA}$$

$$\gamma_o = \frac{P_o}{RT_o} = \frac{54.7(144)}{53.3(80+460)} = 0.27367$$

$$T_i = T_o = 80^\circ\text{F} \quad (\text{ASSUME } T_i = T_o = 80^\circ\text{F})$$

EQUATE (3) & (4) YIELDS:

$$0.532 \frac{P_i 144}{\sqrt{80+460}} = \left\{ 2(32.2) \left( \frac{1.4}{.4} \right) (54.7)(144) (0.27367) \left[ \left( \frac{P_i}{54.7} \right)^{2/1.4} - \left( \frac{P_i}{54.7} \right)^{2.4/1.4} \right] \right\}^{1/2}$$

$$\text{OR } P_i 3.2967 = 697.052 \left[ \left( \frac{P_i}{54.7} \right)^{3/1.4} - \left( \frac{P_i}{54.7} \right)^{2.4/1.4} \right]^{1/2}$$



11

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO. <u>12177</u>	DIVISION & GROUP <u>ES</u>	CALCULATION NO. <u>217-0</u>	OPTIONAL TASK CODE	

SOLVE FOR  $P_1$  USING TRIAL & ERROR AND  
OBTAINED:

$$P_1 = 44.177 \text{ PSIA}$$

$$\begin{aligned} \text{THEN: } A &= \dot{m} \sqrt{T_i} / (0.532) P_1 \\ &= 1.2536 \text{ E-4 } \sqrt{80+460} / (0.532) 44.177 (144) \\ &= 8.6078 \text{ E-7 FT}^2 = .0800 \text{ mm}^2 \approx .3191 \text{ mm } \phi \end{aligned}$$

• ALLOWABLE LEAKAGE RATE UNDER FIELD TEST  
CONDITION.

SUBSTITUTE EQN (2) WITH  $P_0 = 54.7 \text{ PSIA}$ ,  $T_0 = 80^\circ\text{F}$ ,

$$A_T = 2A = 2(8.6078 \text{ E-7}) = 1.7216 \text{ E-6 FT}^2 ;$$

AND YIELD :

$$\begin{aligned} \dot{m} &= 0.532 (1.7216 \text{ E-6}) (54.7) (144) / \sqrt{80+460} \\ &= 3.1045 \text{ E-4 lbm/SEC} \\ &= (3.1045 \text{ E-4 } \frac{\text{lbm}}{\text{SEC}}) \left( \frac{(53.3)(681460)}{144(14.7)} \frac{\text{FT}^3}{\text{lbm}} \right) (3600 \frac{\text{SEC}}{\text{HR}}) \\ &= 14.86 \text{ SCFH} \end{aligned}$$

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



100




STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO. 12177	DIVISION & GROUP ES	CALCULATION NO. 217	OPTIONAL TASK CODE	


SENSITIVITY STUDY TO DETERMINE THE ALLOWABLE  
LEAKAGE RATE WHEN INCOMPRESSIBLE FLOW IS CONSIDERED



FLOW RATE FOR THE ABOVE SETUP IS

$$\dot{m}_1 \propto \frac{A}{\sqrt{2K}} \quad \text{USING DARCY'S EXPRESSION}$$

FLOW RATE FOR THE FIELD SET UP IS



$$\dot{m}_2 \propto 2 \frac{A}{\sqrt{K}}$$

COMPARE  $\dot{m}_1$  &  $\dot{m}_2$  YIELD

$$\frac{\dot{m}_2}{\dot{m}_1} = \frac{2A}{\sqrt{K}} / \frac{A}{\sqrt{2K}} = 2\sqrt{2} = 2.828$$

THE ALLOWABLE LEAKAGE UNDER INCOMPRESSIBLE  
FLOW ASSUMPTION IS

$$\dot{m} = 6 \text{ SCFH } (2.828) = 16.97 \text{ SCFH}$$

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46



11-11-11