San Si

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8608250238 DDC. DATE: 86/08/20 NOTARIZED: YES DOCKET # FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410

AUTH. NAME AUTHOR AFFILIATION

MANGAN, C. V. Niagara Mohawk Power Corp. RECIP. NAME RECIPIENT AFFILIATION

DENTON, H. Office of Nuclear Reactor Regulation, Director (post 851125

SUBJECT: Forwards Page 2, Section 2. 6 of preoperational integrated leak rate inadvertently omitted from 860724 submittal.

DISTRIBUTION CODE: BOO1D COPIES RECEIVED: LTR __ ENCL __ SIZE: ______
TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME BUR EB		LTTR	ENCL	ID CODE/NA	ME	LTTR	ENCL
			1	1	BWR EICSB		2	2.
	BWR FOB	·	1	1	BWR PD3 LA		1	1
BWR PD3 PD			1	1	HAUGHEY, M	01	2	2
	BUR PSB		1	i	BWR RSB		1	1
INTERNAL:	ACRS	41	ઠ	6	ADM/LFMB		1	0
	ELD/HDS3		1	0	IE FILE		1	1
	IE/DEPER/EPB	36	1	1	IE/DQAVT/QAB	21	1	1
	NRR BWR ADTS		1	Q	NRR PWR-B AD	TS	1	0
	NRR ROE, M. L		1	1	NRR/DHFT/MTB		1	1
	REG FILE	04	1	1	RGN1		3	3
	RM7DDAMI/MIB		1	Q				
EXTERNAL:	BNL (AMDTS ONL	_Y	1	1	DMB/DSS (AMD	TS)	i	1
	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1	PNL GRUEL, R		1	1

erenn bester 🗢 er etteld solten. 😘 er et

ANTO SOLUTION OF TRANSPORT OF THE SOLUTION OF

త్రామ్కొంపులైన కి. లోపుల గ్రామం అధ్య అధ్య ఉంది. ఈ మొక్కారుకోందాని, గ్రామం కోస్ కొన్న గ్రామం కృష్ణి మంగాన్ - సిరుత్వేష్ట్ అక్ నామ్నమ్తింది. గ్రామం కోడ్డాడి అన్నాడుకోవడాని శ్రీగ్రామం కూడి మంగాన్ని కోస్తున్నారు.

A TERREPORTED VISION FOREST CONSISTER RECEDENCES OF THEFT OF THE STATES OF THE STATES

1-1-21

	\$3.34.4 *********************************	Ball of the second		5 3 18 x 5	s \$1\$	* 59	
		A CONTRACTOR OF THE SECOND	\$ 14.38	" H 1	· Sugar	the second of	
	h ₁	BMR of Miss	1			N 1 W 434	
ï	•	A Fig. 1984	ž å			g a st. F	
•	* *	HAUST TO THE TOTAL OF THE	Ĺ	1		riji din la bashber	
ā,	Ĭ.	BWR	*	¢		HARTON SELECTION	
4)	Ę	Are Mak	å	**		W The second	1 59 1 142
Ė,	•	بية ₂₀ الله الله الله الله الله الله الله الل	Ç	ř		> 16 30 2 K X X	
Ĭ,	î		*	*1	Special Fred	· 操 新原代。4.4	
Ö	A.	*SKA - SK SE SAM	Ü		g Fa	ather a flat offering.	
Þ	Ž.	PTA PTA	?		4	11 18 18 18 18	
•	5.	ək si	Ţ	\$	x 14.3	18 11 11 11	
			Ç	×	; °	er gert da skij	
	:	a ara a ara	'y £	,	- 4 - 4*	, ¹ 4 5 " 4 k k	Mahara 12
ž.	1	Maria Carina	>	*	4 д	* # k - \$	
ř	!	A 4 4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	*	1	ь.	C 14	



NIAGARA MOHAWK POWER CORPORATION/300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202/TELEPHONE (315) 474-1511

August 20, 1986 (NMP2L 0830)

Mr. Harold Denton, Director Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

Dear Mr. Denton:

Re: Nine Mil'e Point Unit 2
Docket No. 50-410

Enclosed is the Nine Mile Point Unit 2 preoperational integrated leak rate test results on page 2, section 2.6 which was inadvertently left out of the submittal letter dated July 24, 1986. This is submitted pursuant to 10.CFR 50, Appendix J for your use and information.

If you have any questions, please contact Mr. Rademacher of my staff.

Very truly yours,

C. V. Mangan Senior Vice President

NLR:ja 1829G

Enclosure Page 2

xc: W. A. Cook, NRC Resident Inspector
M. Haughey, NRC Project Manager
Project File (2)
R. B. Abbott
W. C. Drews

A. Zallnick, Jr.


8608250238 860820 PDR ADDCK 05000410 PDR

B091

• • 4 .

2.6 Correlation of Full Pressure Test with Reduced Pressure Test

Full pressure test at P_a =40 psig and reduced pressure tests at P_t =20 psig were conducted in the pre-operational test and respective correlation of leakage valves were observed. At full test pressure of 40 psig measured leakage was 61.29 SCFH. At reduced pressure of 20 psig the leakage was 50.27 SCFH. The leakage at 20 psig was lower than at 40 psig. The leakage rate ratio, L_a/L_t =1.2, is considered an expected value based on previous correlation studies by ANI/MAELU. Not only is the leakage ratio considered in the correlation but consideration is given to the pressure profile of the containment design basis accident. The time that the containment is at or above 20 psig for the above does not justify the need to perform future ILRT's at peak accident pressure. The measured leakage would be conservative to a greater extent if at full pressure for the duration (24 hrs). Performing the ILRT at 20 psig provides direct correlation and still conservative values of containment leakage.



UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

" in the

In the Matter of)
Niagara Mohawk Power Corporation) Docket No. 50-410
(Nine Mile Point Unit 2))
	AFFIDAVIT
part of said Corporation to sign	g duly sworn, states that he is Senior Vice Corporation; that he is authorized on the and file with the Nuclear Regulatory hereto; and that all such documents are true owledge, information and belief.
•	<u>Cervangan</u>
Subscribed and sworn to before me York and County of <u>Onendaga</u>	, a Notary Public in and for the State of New
	Christine Questin Notary Public in and for Onondago County, New York
My Commission expires: Christike Austria Notary Public in the State of New York Qualified in Onondaga Co. No. 4787687 My Commission Expires March 30, 1987	

CHRISTINE AUSTIN Hotory Public in the State of New York Publified in Grondege Co. No. 4787687 Volumersion Exches Reach 30, 19.